





Cold-Formed Steel Connectors

For Residential and Mid-Rise Construction

C-CFS10

(800) 999-5099 www.strongtie.com





Presenting our Lateral Systems

Little did we know

when we introduced our first holdown in 1966 that our product innovations would lead us to solutions that can help hold together five-story buildings during an earthquake or allow builders to install larger window and door openings in homes. Our offering of lateral-force resisting systems, including Wood and Steel Strong-Wall® shearwalls, Anchor Tiedown Systems and new Strong Frame™ moment frames, give Designers added flexibility when designing wood structures. In addition, our commitment to cold-formed steel construction is illustrated

by our new Steel Strong-Wall and Strong Frame applications, and the possibilities continue to grow.

At Simpson Strong-Tie, we believe that strength really does come in numbers. By offering the largest selection of lab and field-tested lateral-force resisting systems along with dedicated engineers and field support reps to back them up, you can count on the strength of our products and our people to perform.

Whether you're designing or building a single-family home, a six-story mixed-used building or a retail store, we know we have a solution to fit your project and meet the most stringent code requirements. And we're not done yet. The research, testing and structural system technology that's to come has us just as excited as we were when we developed that first holdown. With each new product and design innovation, we're working with the industry to increase the structural safety of homes and buildings around the country. And in light of all the hurricanes and earthquakes we've experienced during the last 40 years, that's a pretty good feeling.



To learn more, visit:

www.strongtie.com/lateralsystems

ALPHABETICAL INDEX



| | ABS Anchor Bolt Stabilizer | 16 | ICFVL Ledger Connector | 38 | Roof Slope Conversion | 11 | Screws | 14–15 |
|---|---|-------|-----------------------------------|-------|--------------------------------------|------|-------------------------------------|--------|
| 愈 | AHEP Adjustable Hip End Purlin . | 60 | L Angle | 73 | S/B Hanger | 57 🥯 | SET-XP Epoxy-Tie Adhesive | 20-21 |
| | AnchorMate® Bolt Holder | 16 | LBP Bearing Plate | 17 🕸 | S/BA Hanger | 57 🥯 | SP Stud Plate Tie | 66 |
| | BP/BPS Bearing Plate | 17 | LCB Column Base | 19 | S/DSC Drag Strut Connector | 59 | SSP Stud Plate | 66 |
| | CMST Coiled Strap | 65 🚎 | LCE Column Cap | 19 | S/GTC Girder Truss | 61 | SSTB Anchor Bolt | 27-28 |
| | CNW Coupler Nuts | 17 | LSTA Strap Tie 63- | -64 쬴 | S/H Seismic & Hurricane Tie | 67 | SSWAB Anchor Bolts | 50-51 |
| | Code Listing Key Chart | . 8 | LSTI Strap Tie 63- | -64 | S/H1A Seismic & Hurricane Tie | 68 | SSWT Template | 55 |
| | $Conversion \ Charts \dots \dots \dots$ | 11 | LTA1 Masonry Connector | 71 | S/HDB Holdown | 33 | ST Strap Tie | 63-64 |
| | Corrosion Resistance 12- | -13 | LTB Bridging | 59 | S/HDS Holdown | 33 | Standard Steel Thickness | 11 |
| | CS Coiled Strap | 65 | LTP Framing Anchor | 72 | S/HDU Holdown | 31 | STC, STCT Roof Truss | 61 |
| | Custom Clips and Angles | 74 | LTS Twist Strap | 62 | S/HGAM Masonry Connector | 71 | STHD Strap Tie Holdown | 34–35 |
| | DSP Stud Plate Tie | 66 쬴 | MASA Mudsill Anchor | 18 | S/HJCT Hanger | 56 | StrapMate® Strap Holder | 16 |
| | $\textbf{DTC} \ Double \ Truss \ Clips \ldots \ldots$ | 61 | Metric Conversions | 11 | S/HPAHD Holdown | 36 🚎 | Strong Frame™ OMF | 39 |
| | FHA Strap Tie 63- | -64 | MSTA Strap Tie 63- | -64 | S/HTC Heavy Truss Clip | 62 | TB Bridging | 59 |
| 靊 | GCN Gas Actuated Nailer | 23 | MSTC Strap Tie 63- | -64 | S/HTT Tension Tie | 32 🚎 | TBD22 Truss Bracing Diagonal | I 60 |
| | General Notes 8- | -11 | MSTI Strap Tie 63- | -64 | S/JCT Hanger | 56 | Titen® Screw | 22 |
| 靊 | GDP Concrete Pins | 23 | MTS Twist Strap | 62 | S/LBV Hanger | 57 | Titen HD® Threaded Anchor | 20, 22 |
| 靊 | H Seismic & Hurricane Tie. 67-69, | 71 | MTSM Twist Strap | 71 | S/LS Skewable Angle | 73 | TJC37 Jack Truss Connector . | 59 |
| | HPA Purlin Anchor | 37 | PA Purlin Anchor | 37 | S/LTT Tension Tie | | TP Tie Plate | |
| | HPAHD Holdown | 36 | PAB/PABH Anchor Bolts 29- | | S/MST Strap Tie 63- | _ | TPA Tie Plate | |
| | HRS Strap 63- | -64 🗐 | PAF Powder Actuated Fasteners 24- | -25 | S/PAHD Holdown | 36 🥶 | TSBR Truss Spacer Restraint. | 60 |
| | HSCNW High-Strength Coupler Nut | 17 | PS Strap | 63 | S/PSPN Shield Plate | 68 | TSP Stud Plate | 66 |
| | HTS Twist Strap | _ | PSCA Sheathing Clip | = | | _ | VGT Variable Girder Tiedown. | 70 |
| | HTSM Twist Strap | 71 | PSCL Sheathing Clip | 73 🚎 | S/TSR Truss Spacer Restraint | 60 | W Hanger | 58 |
| 鳡 | HTT Tension Tie | 32 | Quik Drive® Fasteners | 14 🚎 | S/VGT Variable Girder Tiedown | 70 | WP Hanger | 58 |
| | HUC Hanger | 58 | RFB Retrofit Bolt | 28 | SB Anchor Bolts | 26 | | |

HOW TO USE THIS CATALOG

NEW PRODUCTS

New products are shown with the symbol. There are also new sizes within existing model series.



EXTRA CORROSION PROTECTION

This icon identifies products that are available with additional corrosion protection (ZMAX®, Hot-Dip Galvanized or Stainless Steel). Check with Simpson Strong-Tie for availability. The end of the product name will indicate what type of extra corrosion protection is provided (Z = ZMAX, HDG = Hot-Dip Galvanized or SS = Stainless Steel). See page 12–13 for information on corrosion. Visit our website www.strongtie.com/info for more technical information on this topic.

HOW WE DETERMINE ALLOWABLE LOADS

Allowable loads in this catalog are determined using calculations and/ or one or more of the following methods:


- a minimum of 3 static load tests in CFS assemblies;
- a minimum of 3 static load tests in structural steel jigs;
- a minimum of 3 static load tests of products embedded in concrete or masonry.

Some tests include only portions of a product such as purlin anchor tests—only the embedded hook is tested, not the screwed or bolted section of the strap, which is calculated. Testing to determine allowable loads in this catalog is not done on connection systems in buildings. Testing is conducted in an IAS accredited laboratory. Typically the allowable load is limited to an average test load at 1/8" deflection, an average or lowest test value (nominal load) divided by a safety factor or the calculation value. The safety factor is prescribed by Section F1 of the 2001 AISI NAS. For LRFD, the nominal connector strength is multiplied by a resistance factor, also prescribed by Section F1 of the 2001 NAS.

For detailed information regarding how Simpson Strong-Tie tests specific products, contact Simpson Strong-Tie.

Dimensions: This shows the product dimensions (*material thickness*, *length and width in this case*.) The product drawing includes these callouts as a cross-reference.

Allowable Design Loads: The maximum load imposed on a connection during the life of a structure. There may be multiple design loads acting in different directions (*up*, *down*, *lateral*, *perpendicular*, *etc.*) imposed on a connection. When connectors are attached to 2 CFS members of different thicknesses, the Designer shall use the thinner of the 2 members for calculating allowable loads.



OTHER CATALOG DEFINITIONS:

Deflection: The distance a point moves when a load is applied.

Nominal Tension Load (Strength): The capacity of a structure or component to resist the effects of loads, as determined in accordance with 2001 AISI NAS using specified material strengths and dimensions. Typically taken as the average value of at least 3 tests.

The Nominal Tension Load should not be compared against design loads (ASD, LRFD), but used only where the AISI Lateral Design Standard requires the holdown to have nominal tension load (strength) to resist lesser of amplified seismic load or what the system can deliver.

COMPANY PROFILE



14-15 l

31-38


56-58

The Simpson Strong-Tie Company was founded in Oakland, California and has been manufacturing wood-to-wood and wood-to-concrete connectors since 1956. Since then, Simpson Strong-Tie Company Inc. has grown to be the world's largest manufacturer of construction connectors. In recent years the company's growth has included expanding its product offering to include pre-manufactured shearwalls, anchor systems for concrete and masonry and collated fastening systems, and steel-to-steel connectors since 1994.

The Simpson Strong-Tie Company Inc. "NO EQUAL" program includes:

- Quality products value-engineered for the lowest installed cost at the highest rated performance levels.
- Most thoroughly tested and evaluated products in the industry.
- Strategically-located manufacturing and/or warehouse facilities.
- · National Code Agency listings.
- Largest number of patented connectors in the industry.
- · International sales team.
- In-house R & D, and tool and die professionals.
- In-house product testing and quality control engineers.
- Member of AITC, ASTM, ASCE, CSI, NBMDA, NLBMDA, SETMA, STAFDA, NFBA, SBCA, Steel Framing Alliance (SFA), Cold Formed Steel Engineer's Institute (CFSEI), Hawaii

Pacific Steel Framing Alliance (HSA), Mid-Atlantic Steel Framing Alliance (MASFA), California Steel Framing Alliance (CASFA), American Iron and Steel Institute (AISI's) Committee on Framing Standards, and local organizations.



SIMPSON STRONG-TIE QUALITY POLICY

We help people build safer structures economically. We do this by designing, engineering and manufacturing "No Equal" structural connectors and other related products that meet or exceed our customers' needs and expectations. Everyone is responsible for product quality and is committed to ensuring the effectiveness of the Quality Management System.

Tom Fitzmyers
Chief Executive Officer

Terry Kingsfather

President

GETTING FAST TECHNICAL SUPPORT

When you call for engineering technical support, we can help you quickly if you have the following information at hand. This will help us to serve you promptly and efficiently.

- Which Simpson Strong-Tie catalog are you using? (See the front cover for the form number).
- Which Simpson Strong-Tie product are you using?
- · What is your load requirement?
- · What is the carried member's thickness, width and height?
- · What is the supporting member's thickness, width and height?
- What is the carried and supporting members' material and application?

800-999-5099 | www.strongtie.com

520

Fasteners

Concrete Connectors 16−19 ►

CONNECTOR SELECTION KEY

Products are divided into ten general categories.

identified by tabs along the page's outer edge.

Anchors 20−30 ►

Holdowns and Tension Ties

Lateral Systems 39-55 ▶

Hangers

Truss Connectors

59-62 ▶

Straps and Ties and Masonry

63-71

Miscellaneous

72-73

Custom Clips and Angles 74

WE ARE ISO 9001-2000 REGISTERED



Simpson Strong-Tie is an ISO 9001-2000 registered company. ISO 9001-2000 is an internationally-recognized quality assurance system which lets our domestic and international customers know that they can count on the consistent quality of Simpson Strong-Tie's products and services.



AHEP Adjustable Hip-End Purlin

The AHEP adjustable purlin is a structural purlin that also serves as an installation aid during the truss erection process. It attaches to the step-down hip trusses at the leading edge eliminating the need for drop-top chords and C-stud fillers. Designed to accommodate a roof-pitch range of 3/12 to 9/12, the AHEP installs linearly, aligned with the end jacks, to maintain sheathing spacing from eave to hip or peak. **Available June 2010**.

Page 60



H10S Hurricane Tie

The H10S hurricane tie provides a high-capacity connection from the truss/rafter to the stud or masonry. A flexible fastening pattern allows installation where the stud is offset

Pages 67 and 69



H2A Hurricane Tie

The new H2A hurricane tie is an improved version of the S/H2 hurricane tie with higher uplift capacity.

Pages 67 and 69



HTT4 and HTT5 Tension Ties

The HTT series of tension ties offers tension-resisting solutions that install with screws. These new additions to the HTT line feature an optimized fastener pattern which results in better performance with less deflection. Designed to meet new code standards, the HTT4 and HTT5 offer higher loads than the S/HTT14.

Page 32



LCE4 Column Cap

The universal design of the LCE provides high capacity while eliminating the need for left and right versions. For use with multiple header thicknesses.

Page 19

NEW PRODUCTS FOR 2010





S/BA Cold-Formed Steel Hanger

The S/BA top-flange hanger is a cost-effective alternative to heavier, special-order hangers. The S/BA is value engineered and tested to achieve higher allowable loads and increased performance. It may be fastened with screws or powder-actuated fasteners or welded to the header, providing more design options and greater versatility.

Page 57



S/TSR Truss Spacer Restraint

The S/TSR truss spacer restraint captures the on-center spacing of cold-formed steel truss chords and webs in linear alignment. The S/TSR laterally restrains the truss members, allowing quicker, easier and safer installations. Its tubular shape provides strength in both compression and tension. S/TSR has a low profile that can be sheathed over, eliminating the need to remove bracing prior to applying the sheathing or decking. **Available June 2010**.

Page 60



S/VGT Variable Girder Tiedown

The S/VGT tiedown is a higher capacity tiedown for girder trusses. It attaches with screws to the side of the truss and features a predeflected crescent washer that allows it to accommodate top chord pitches up to 8/12.

Page 70



Strong Frame® Ordinary Moment Frame

The Strong Frame ordinary moment frame is a cost-effective alternative to traditional frames, which are time intensive to design and labor intensive to install. The Strong Frame ordinary moment frame allows larger openings and smaller wall sections while still providing the loads that structural designers need. Simpson Strong-Tie offers 196 pre-designed solutions and 100% bolted connections to make building with moment frames more convenient than ever.

Page 39



TBD22 Truss Brace

Everything about the new TBD truss brace is designed to make diagonal truss bracing easier. It travels in a box like a coiled strap and is formed into shape as it is pulled from the carton, making it rigid and easy to position across trusses. Once fastened into place, the braces lay flat so that they remain in place as the roof is sheathed, eliminating the need to remove braces. And since the braces stay in place, trusses maintain better alignment and are safer for sheathing crews to work on.

Page 60

SIMPSON Strong-Tie

Codes

Code Reference Column in Load Tables

The alpha-numeric "Code Reference numbers" that appear in the "Code Reference" column in load tables throughout this catalog are intended to identify products listed in evaluation agency reports, typically called "code reports", and the specific reports that cover them. The letter designates the evaluation agency from which the report was obtained. The Code reference column, used in conjunction with the chart at right, indicates which code listing applies to a product. The reference numbers also clearly identify:

- Products submitted for evaluation report listing (160)
- Products with no evaluation report listing (170)
- Products not submitted because they have no load rating and an evaluation report listing is not necessary (180)
- Products that meet prescriptive or conventional construction code requirements (190)

Where a model has been submitted for listing (160) or does not have an evaluation report listing (170), Simpson Strong-Tie can supply complete test data to support our published loads. Please contact us for a copy of our product test documentation at (800) 999-5099. Product acceptance may be obtained through the Alternate Methods and Materials section of the applicable building code.

Some loads and applications may not be covered in the code report and specific reductions and restrictions may be required by other product evaluation agencies. Visit **www.strongtie.com** or visit the product evaluation agencies' web sites for the current evaluation reports.

Simpson Strong-Tie® connectors are recognized by most product evaluation agencies. Agencies that recognize some or all of our products include ICC-ES (formerly ICBO, BOCA, SBCCI, NES); IAPMO ES; the City of Los Angeles, California; and State of Florida.

Multiple types of ICC-ES evaluation reports are shown in the Code Reference Key Chart. ICC-ES NER, ICC-ES ER, and ICC-ES ES reports are referred to as Legacy Reports and have been obtained over the years to verify that Simpson Strong-Tie products are in compliance with the code. These Legacy reports were evaluated under the 2000 IBC codes. In order to obtain evaluation for the 2003 or later I-codes, manufacturers must submit for ICC-ES ESR reports.

Simpson Strong-Tie has many ICC-ES ESR reports, but currently not all products have been evaluated to the latest codes. This does not mean that the information in those reports is inaccurate. Simpson Strong-Tie has submitted our Legacy Reports to ICC-ES to obtain product evaluation service reports (ESR's) evaluated to the 2006 IBC/IRC or later editions, but due to the large number of reports they have to evaluate and several new acceptance criteria (AC) that have only recently been adopted, ICC-ES has not been able to process all the reports in time for this catalog.

It is anticipated that in 2010, our remaining Legacy Reports will have been converted. To help understand which of our stamped and welded connector products are listed in an ESR report, we have obtained an ICC-ES index evaluation services report, ICC-ES ESR-2523, for these products. This report is a reference document to other ESR reports held by Simpson Strong-Tie and will be updated frequently by ICC-ES as new stamped and welded connector evaluation services reports are issued or converted. Please visit www.strongtie.com for the latest information or contact ICC Evaluation Services at www.icc-es.org.

IAPMO Evaluation Service has been evaluating products for over 80 years and has the same ANSI accreditation as ICC Evaluation Services for evaluating structural building products to the building codes. IAPMO ES began evaluating structural building products in 2004, utilizing licensed structural engineers to perform quality reviews, and currently are reviewing many other manufacturers' products. Please visit **www.strongtie.com** for the latest information or contact IAPMO Evaluation Services at **www.iapmoes.org**.

In November 2007 the Department of State Architecture, California, issued a revised IR 23-1. The Revised Interpretation of Regulation addresses and clarifies issues relating to connectors. IR 23-1 defines the Purpose and Scope and clarifies Listing Requirements, Acceptable Load Capacities, Design Requirements, Installation Requirements and Connector Fabrication which addresses corrosion resistant material and/or coatings. Also, I RA-5 was revised in June of 2008 and is entitled "Acceptance of Products, Materials, and Evaluation Reports. Please contact the DSA at www.dsa.dgs.ca.gov/Publications/default.htm for more information.

On October 1, 2003, the State of Florida's Statewide Product Approval System became effective. The purpose of this system is to provide a single product evaluation and approval system that applies statewide to operate in coordination with the Florida Building Code. This Florida product evaluation and approval system is governed by Florida Statutes, Chapter 553, Section 553.842. Since this law specifies that the product approval system is to apply statewide, Notice of Acceptance are no longer necessary where a product has a statewide approval that is applicable in the High Velocity Hurricane Zone (HVHZ) and is installed in accordance with its conditions of use.

CODE REPORT REFERENCE KEY CHART

| AGENCY | CODE REPORT | CODE Ref. | |
|----------------------------|-------------------------------------|--------------|--|
| ICC-ES LEGACY REPORTS | ER5275 | ILC1 | |
| City of Los Angeles, CA | RR 25489 RR 25293 | LC1 L8 | |
| State of Florida | FL9601 FL11470 | FC1 F26 | |
| Submitted for Listing | Call us for Status and Test Data | 160 | |
| No Code Listing | Call us for Test Data | 170 | |
| No Load Rating | _ | 180 | |
| Prescriptive Code | _ | 190 | |

^{*} As of the printing of this catalog, products coded 160 either have been submitted and are awaiting issuance from the respective product evaluation agency or are to be submitted. Because code reports can be issued throughout the year, we encourage the user to visit www.strongtie.com, www.icc-es.org, www.lapmoes.org, www.ladbs.org, www.dsa.dys.ca.gov, and www.floridabuilding.org for the most current information, call Simpson Strong-Tie at 800-999-5099, or contact the code agency directly.

IMPORTANT INFORMATION & GENERAL NOTES



WARNING

Simpson Strong-Tie Company Inc. structural connectors, anchors, and other products are designed and tested to provide specified design loads. To obtain optimal performance from Simpson Strong-Tie Company Inc. products and achieve maximum allowable design load, the products must be properly installed and used in accordance with the installation instructions and design limits provided by Simpson Strong-Tie Company Inc. To ensure proper installation and use, designers and installers must carefully read the following General Notes, General Instructions For The Installer and General Instructions For The Designer, as well as consult the applicable catalog pages for specific product installation instructions and notes. Proper product installation requires careful attention to all notes and instructions, including these basic rules:

- 1. Be familiar with the application and correct use of the connector.
- Follow all installation instructions provided in the applicable catalog, website, Pocket Installers Guide or any other Simpson Strong-Tie publications.
- 3. Install all required fasteners per installation instructions provided by Strong-Tie Company Inc.: a) use proper fastener type; b) use proper fastener quantity; c) fill all fastener holes; d) do not overdrive or underdrive nails, including when using gun nailers; and e) ensure screws are completely driven.
- Only bend products that are specifically designed to be bent. For those products that require bending, do not bend more than once.
- 5. Cut joists to the correct length, do not "short-cut". The gap between the end of the joist and the header material should be no greater than 1/4" unless otherwise noted. In addition to following the basic rules provided above as well as all notes, warnings and instructions provided in the catalog, installers, designers, engineers and consumers should consult the Simpson Strong-Tie Company Inc. website at www.strongtie.com to obtain additional design and installation information, including:
- Instructional builder/contractor training kits containing an instructional video, an instructor guide and a student guide in both English and Spanish;

- Installer's Pocket Guide (form S-INSTALL, contact Simpson Strong-Tie for more information) which is designed specifically for installers and uses detailed graphics and minimal text in both English and Spanish to explain visually how to install many key products;
- Information on workshops Simpson Strong-Tie conducts at various training centers throughout the country;
- · Product specific installation videos;
- Specialty catalogs;
- Code reports;
- Technical fliers and bulletins;
- Master format specifications;
- Material safety data sheets;
- Corrosion information;
- Connector selection guides for engineered wood products (by manufacturer);
- Simpson Strong-Tie connector selector software;
- · Simpson Strong-Tie Autocad menu;
- · Simpson Strong-Tie Strong-Wall® Selector software;
- · Simpson Strong-Tie Anchor Tiedown System Selector and anchor related software; and
- · Answers to frequently asked questions and technical topics.

Failure to follow fully all of the notes and instructions provided by Simpson Strong-Tie Company Inc. may result in improper installation of products. Improperly installed products may not perform to the specifications set forth in this catalog and may reduce a structure's ability to resist the movement, stress, and loading that occurs from gravity loads as well as short-term load even such as wind and earthquake loading. Simpson Strong-Tie Company Inc. does not guarantee the performance or safety of products that are modified, improperly installed or not used in accordance with the design and load limits set forth in this catalog.

These notes are provided to ensure proper installation of Simpson Strong-Tie® products and must be followed fully.

- a. Simpson Strong-Tie Company Inc. reserves the right to change specifications, designs, and models without notice or liability for such changes.
- Steel used for each Simpson Strong-Tie product is individually selected based on the product's steel specifications, including strength, thickness, formability, finish, and weldability. Contact Simpson Strong-Tie for steel information on specific products.
- c. Unless otherwise noted, dimensions are in inches, loads are in pounds.
- d. Unless otherwise noted, welds, bolts, screws and nails may not be combined to achieve highest load value.
- e. Catalog loads are based on cold-formed steel members having a minimum yield strength, Fy, of 33 ksi and tensile strength, Fu, of 45 ksi for 43 mils (18 ga) and thinner, and a minimum yield strength, Fy, of 50 ksi and tensile strength, Fu, of 65 ksi for 54 mils (16 ga) and thicker.
- f. Simpson Strong-Tie Company Inc. will manufacture non-catalog products provided prior approval is obtained and an engineering drawing is included with the order. Steel specified on the drawings as ½, ¾, 6, and ½, will be 11 gauge (0.120), 7 gauge (0.179), and 3 gauge (0.29), respectively. The minimum yield and tensile strengths are 33 ksi and 52 ksi, respectively.
- g. RFB is A307, Grade C; SSTB is ASTM A36.
- Unless otherwise noted, bending steel in the field may cause fractures at the bend line. Fractured steel will not carry load and must be replaced.
- Top flange hangers may cause unevenness. Possible remedies should be evaluated by a professional and include using a face mount hanger or cutting the subfloor to accommodate the top flange thickness.
- Built-up members (multiple members) must be fastened together to act as one unit to resist the applied load (excluding the connector fasteners).
 This must be determined by the Designer/Engineer of Record.
- Do Not Overload. Do not exceed catalog allowable loads, which would jeopardize the connection.
- Some model configurations may differ from those shown in this catalog. Contact Simpson Strong-Tie for details.

- m. Some combinations of hanger options are not available. In some cases, combinations of these options may not be installable. Horizontal loads induced by sloped joists must be resisted by other members in the structural system. A qualified designer must always evaluate each connection, including carried and carrying member limitations, before specifying the product. Fill all fastener holes with fastener types specified in the tables, unless otherwise noted. Hanger configurations, height, and fastener schedules may vary from the tables depending on joist size, skew and slope. See the allowable table load for the non-modified hanger, and adjust as indicated. Material thickness may vary from that specified depending on the manufacturing process used. W hangers normally have single stirrups; occasionally, the seat may be welded. S/B, S/LBV, W and WP hangers for sloped seat installations are assumed backed.
- n. Simpson Strong-Tie will calculate the net height for a sloped seat. The customer must provide the H1 joist height before slope.
- o. Do not weld products listed in this catalog unless this publication specifically identifies a product as acceptable for welding, or unless specific approval for welding is provided in writing by Simpson Strong-Tie. Some steels have poor weldability and a tendency to crack when welded. Cracked steel will not carry load and must be replaced.
- p. Steel for the framing members must comply with ASTM A 1003 Grade 33 minimum.
- q. Quik Drive screws have been tested per AISI Standard Test Method TS-04
- Consideration should be given to the screw head specified as this may affect the attached materials.
- s. Do not add fastener holes or otherwise modify Simpson Strong-Tie Company Inc. products. The performance of modified products may be substantially weakened. Simpson Strong-Tie will not warrant or guarantee the performance of such modified products.
- All references to bolts or machine bolts (MBs) are for structural quality through bolts (not lag screws or carriage bolts) equal to or better than ASTM Standard A307, Grade A.

Instructions to the Installer

- All specified fasteners must be installed according to the instructions in this catalog. Incorrect fastener quantity, size, type, material, or finish may cause the connection to fail
- b. Holes for ½" diameter or greater bolts shall be no more than a maximum of ¼s" larger than the bolt diameter per 2001 American Iron and Steel Institute North American Specification for the Design of Cold-Formed Steel Structural Members, (AISI NAS) Section E3a.
- c. Install all specified fasteners before loading the connection.
- d. Some hardened fasteners may have premature failure if exposed to moisture. The fasteners are recommended to be used in dry interior applications.
- e. Use proper safety equipment.
- f. When installing a joist into a connector with a seat, the joist shall bear completely on the seat. The gap between the end of the joist and the connector or header shall not exceed 1/8" per ICC-ES AC 261 and ASTM D1761 test standards, unless otherwise noted.

- g. For holdowns, anchor bolt nuts should be finger-tight plus ½ to ½ turn with a hand wrench. Care should be taken to not over-torque the nut, impact wrenches should not be used. This may preload the holdown.
- h. All screws shall be installed in accordance with the screw manufacturer's recommendations. All screws shall penetrate and protrude through the attached materials a minimum of 3 full exposed threads per AISI Standard for Cold-Formed Steel Framing General Provisions Section D1.3.
- Welding galvanized steel may produce harmful fumes; follow proper welding procedures and safety precautions. Welding should be in accordance with (AWS) standards. Unless otherwise noted Simpson Strong-Tie connectors cannot be welded.
- j. Temporary lateral support for members may be required during installation.

IMPORTANT INFORMATION & GENERAL NOTES



Instructions to the Designer

- a. The allowable load is typically limited to an average test load at 1/6" deflection, an average or lowest test value (nominal load) divided by a safety factor or the calculation value. The safety factor is prescribed by Section F1 of the 2001 AISI NAS.
- Allowable simultaneous loads in more than one direction on a single connector must be evaluated as follows:
 - Design Uplift/Allowable Uplift + Design Lateral Parallel to Track/Allowable Lateral Parallel to Track + Design Lateral Perpendicular to Track/Allowable Lateral Perpendicular to Track ≤ 1.0. The three terms in the unity equation are due to the three possible directions that exist to generate force on a hurricane tie. The number of terms that must be considered for simultaneous loading is at the sole discretion of the Designer and is dependant on their method of calculating wind forces and the utilization of the connector within the structural system.
- c. Loads are based on the 2001 AISI Standard North American Specification for the Design of Cold-Formed Steel Structural Members (NAS), unless otherwise specified. Other code agencies may use different allowable loads.
- d. The term "Designer" used throughout this catalog is intended to mean a licensed/certified building design professional, a licensed professional engineer, or a licensed architect.
- e. All connected members and related elements shall be designed by the Designer.
- Unless otherwise noted, member strength is not considered in the loads given and, therefore, reduce allowable loads when member strength is limiting.
- g. The average ultimate breaking strength for some models is listed under "nominal tension load".
- h. Simpson Strong-Tie strongly recommends the following addition to construction drawings and specifications: "Simpson Strong-Tie connectors and fasteners are specifically required to meet the structural calculations of plan. Before

- substituting another brand, confirm load capacity based on reliable published testing data or calculations. The Engineer/Designer of Record should evaluate and give written approval for substitution prior to installation."
- Verify that the dimensions of the supporting member are sufficient to receive the specified fasteners, and develop the top flange bearing length.
- Simpson Strong-Tie will provide, upon request, code testing data on all products that have been code tested.
- k. Most of the allowable loads published in this catalog are for use when utilizing the traditional Allowable Stress Design (ASD) methodology. A method for using Load and Resistance Factor Design (LRFD) for cold-formed steel is also included in the 2001 AISI NAS. When designing with LRFD, the nominal connector strength multiplied by the resistance factor must be used. If not listed or noted in a table footnote, contact Simpson for the LRFD values of products listed in this catalog.
- I. All steel-to-steel connector screws must comply with ASTM C1513.
- m. Screw strength shall be calculated in accordance to 2001 AISI NAS Section E4 or shall be based upon manufacturers design capacity determined from testing.
- n. Simpson Strong-Tie recommends that hanger height be at least 60% of joist height for stability.
- o. Local and/or regional building codes may require meeting special conditions. Building codes often require special inspection of anchors installed in concrete and masonry. For compliance with these requirements, it is necessary to contact the local and/or regional building authority. Except where mandated by code, Simpson's products do not require special inspection.
- p. When connectors are attached to 2 CFS members of different thicknesses, the Designer shall use the thinner of the 2 members for selecting allowable loads.

Additional Important Information & General Notes for Hybrid (Steel-to-Wood) Connections

These notes are in addition to the previous notes for steel to steel connections and are provided to ensure proper installation of Simpson Strong-Tie® Company Inc. products and must be followed fully.

a. Unless otherwise noted, allowable loads are for Douglas Fir-Larch under continuously dry conditions. Allowable loads for other species or conditions must be adjusted according to the code. In many cases, Simpson Strong-Tie code reports will indicate loads derived from Douglas Fir header material only. However under ICC-ES AC13, loads for Douglas Fir are the same as LVL, LSL, PSL, Glulam's and Southern Pine, since the specific gravity of these wood species fall within the specific gravity range of the AC13 criteria. The chart below gives specific gravity for the different wood species as listed by NDS (National Design Specifications). For your convenience we have placed the section from the AC13 criteria indicating the range of specific gravity. 3.2.3 The species of lumber used shall have a specific gravity of, but not greater than 0.55 as determined in accordance with the NDS.

| Species | Fc⊥ | Specific Gravity |
|-------------------------------|---------|------------------|
| Douglas Fir-Larch (DFL) | 625 psi | 0.50 |
| Southern Pine (SP) | 565 psi | 0.55 |
| Spruce-Pine-Fir (SPF) | 425 psi | 0.42 |
| Hem Fir (HF) | 405 psi | 0.43 |
| Glulam | 560 psi | 0.50 |
| LVL (DF/SP) | 750 psi | 0.50 |
| TimberStrand® LSL (E=1.3x106) | 680 psi | 0.50 |
| TimberStrand® LSL (E>1.5x106) | 880 psi | 0.50 |
| Parallam® PSL | 750 psi | 0.50 |

- b. For face-mount hangers and straight straps, use 0.86 of table loads for Spruce-Pine-Fir.
- c. A fastener that splits the wood will not take the design load. Evaluate splits to determine if the connection will perform as required. Dry wood may split more easily and should be evaluated as required. If wood tends to split, consider pre-boring holes with diameters not exceeding .75 of the nail diameter (2005 NDS 11.1.5.3).
- d. Wood shrinks and expands as it loses and gains moisture, particularly perpendicular to its grain. Take wood shrinkage into account when designing and installing connections. Simpson Strong-Tie manufactures products to fit common dry lumber dimensions. If you need a connector with dimensions other than those listed in this catalog, Simpson Strong-Tie may be able to vary connector dimensions; contact the Simpson Strong-Tie. The effects of wood shrinkage are increased in multiple lumber connections, such as floor-to-floor installations. This may result in the vertical rod nuts becoming loose, requiring post-installation tightening.
- e. Top flange hangers may cause unevenness. Possible remedies should be evaluated by a professional and include using a face mount hanger, and routering the beam or cutting the subfloor to accommodate the top flange thickness.
- f. Built-up lumber (multiple members) must be fastened together to act as one unit to resist the applied load (excluding the connector fasteners). This must be determined by the Designer/Engineer of Record.

Additional Instructions for the Installer for Hybrid (Steel-to-Wood) Connections

- a. Bolt holes into wood members shall be at least a minimum of ½2" and no more than a maximum of ½6" larger than the bolt diameter (per the 2005 NDS 11.1.2.2).
- b. The joist shall bear completely on the connector seat, and the gap between the joist end and the header shall not exceed 1/6" per ICC-ES AC 13 and ASTM D1761 test standards.
- c. For holdowns, anchor bolt nuts should be finger-tight plus 1/2 turn with a hand wrench, with consideration given to possible future wood shrinkage. Care should be taken to not over-torque the nut, impact wrenches should not be used. This may preload the holdown.

Additional Instructions for the Designer for Hybrid (Steel-to-Wood) Connections

- a. Loads are based on the 2001 AISI Standard North American Specification for the Design of Cold-Formed Steel Structural Members (NAS) and the 2005 AF&PA National Design Specifications (NDS), unless otherwise specified. Other code agencies may use different allowable loads.
- b. Duration of load adjustments for fasteners into wood as specified by the code are as follows:
 - "FLOOR" and "DOWN" (100) no increase for duration of load.
 - "SNOW" (115) 115% of design load for 2 month duration of load. "ROOF LOAD" (125) — 125% of design load for 7 day duration of load.
 - "EARTHQUAKE/WIND" (160) 160% of design load for earthquake/wind loading.
- Some catalog illustrations show connections that could cause cross-grain tension or bending of the wood during loading if not sufficiently reinforced. In this case, mechanical reinforcement should be considered.
- Most of the allowable loads published in this catalog are for use when utilizing the traditional Allowable Stress Design (ASD) methodology. A method for using
- Load and Resistance Factor Design (LRFD) for cold-formed steel is also included in the 2001 AISI NAS. When designing with LRFD, the nominal connector strength multiplied by the resistance factor must be used. If not listed or noted in a table footnote, contact Simpson for the LRFD values of products listed in this catalog. For more information, refer to the American Forest and Paper Association "Guideline to Pre-engineered Metal Connectors" and ASCE 16. The "Guideline" contains a soft-conversion procedure that can be used to derive reference lateral resistances.
- Simpson Strong-Tie recommends that hanger height be at least 60% of joist height for stability.
- f. Pneumatic or powder-actuated fasteners may deflect and injure the operator or others. Powder-actuated fasteners should not be used to install connectors. Pneumatic nail tools may be used to install connectors, provided the correct quantity and type of fasteners are properly installed in the fastener holes. Tools with fastener hole-locating mechanisms should be used. Follow the manufacturer's instructions and use the appropriate safety equipment. Over driving fasteners may reduce allowable loads. Contact Simpson Strong-Tie.

IMPORTANT INFORMATION & GENERAL NOTES



Limited Warranty

Simpson Strong-Tie Company Inc. warrants catalog products to be free from defects in material or manufacturing. Simpson Strong-Tie Company Inc. products are further warranted for adequacy of design when used in accordance with design limits in this catalog, and properly specified and installed. This warranty does not apply to uses not in compliance with specific applications and installation procedures set forth in this catalog, or to non-catalog or modified products, or to deterioration due to environmental conditions.

Simpson Strong-Tie® connectors are designed to enable structures to resist the movement, stress and loading that occurs from gravity loads as well as short-term load events such as wind and earthquake loading. Properly-installed Simpson Strong-Tie connectors will perform in accordance with the specifications set forth in the applicable Simpson Strong-Tie catalog. Additional performance limitations for specific products may be listed on the applicable catalog pages.

Due to the particular characteristics of the natural event, the specific design and location of the structure, the building materials used, the quality of construction,

This catalog reflects changes in the allowable loads and configurations of some Simpson Strong-Tie Company Inc. products. This catalog is effective until December 31, 2011, and supersedes all information in all earlier publications, including catalogs, brochures, fliers, technical bulletins, etc. Use this edition as a current reference. Information on allowable loads and configurations may be updated periodically (see www.strongtie.com for the latest information). After December 31, 2011, contact Simpson Strong-Tie for current product information.

and the condition of the soils involved, damage may nonetheless result to a structure and its contents even if the loads resulting from the natural event do not exceed Simpson Strong-Tie catalog specifications and Simpson Strong-Tie connectors are properly installed in accordance with applicable building codes.

All warranty obligations of Simpson Strong-Tie Company Inc. shall be limited, at the discretion of Simpson Strong-Tie Company Inc., to repair or replacement of the defective part. These remedies shall constitute Simpson Strong-Tie Company Inc.'s sole obligation and sole remedy of purchaser under this warranty. In no event will Simpson Strong-Tie Company Inc. be responsible for incidental, consequential, or special loss or damage, however caused.

This warranty is expressly in lieu of all other warranties, expressed or implied, including warranties of merchantability or fitness for a particular purpose, all such other warranties being hereby expressly excluded. This warranty may change periodically—consult our website www.strongtie.com for current information.

Allowable loads in this catalog are for the described specific applications of properly-installed products. Product modifications, improper loading or installation procedures, or deviations from recommended applications will affect connector allowable load-carrying capacities. Connectors are steel and will corrode and lose load-carrying capacity if exposed to ocean salt air, corrosive fire-retardant chemicals, fertilizers, pressure treated lumber, or other substances or environments that adversely affect steel.

Terms & Conditions of Sale

PRODUCT USE

Products in this catalog are designed and manufactured for the specific purposes shown, and should not be used with other connectors not approved by a qualified designer. Modifications to products or changes in installation procedures should only be made by a qualified designer. The performance of such modified products or altered installation procedures is the sole responsibility of the designer.

INDEMNITY

Customers or designers modifying products or installation procedures, or designing non-catalog products for fabrication by Simpson Strong-Tie Company Inc. shall, regardless of specific instructions to the user, indemnify, defend, and hold harmless Simpson Strong-Tie Company Inc. for any and all claimed loss or damage occasioned in whole or in part by non-catalog or modified products.

NON-CATALOG AND MODIFIED PRODUCTS

Consult Simpson Strong-Tie Company Inc. for applications for which there is no catalog product, or for connectors for use in hostile environments, with excessive wood shrinkage, or with abnormal loading or erection requirements.

Non-catalog products must be designed by the customer and will be fabricated by Simpson Strong-Tie in accordance with customer specifications.

Simpson Strong-Tie cannot and does not make any representations regarding the suitability of use or load-carrying capacities of non-catalog products. Simpson Strong-Tie provides no warranty, express or implied, on non-catalog products. F.O.B. Shipping Point unless otherwise specified.

CONVERSION CHARTS

US Standard Steel Gauge Equivalents in Nominal Dimensions

| Min. Thick. | Design Thick. | Ref. | Thickness of Steel Sheets (in) | | | | | |
|----------------|------------------|------|--------------------------------|---------------------------|-----------------|--|--|--|
| mils | in | Ga² | Uncoated Steel | Galvanized Steel (G90) | ZMAX® (G185) | | | |
| 229 | 0.2405 | 3 | 0.239 | _ | | | | |
| 171 | 0.1795 | 7 | 0.179 | 0.186 | _ | | | |
| 118 | 0.1240 | 10 | 0.134 | 0.138 | 0.140 | | | |
| 111 | 0.1163 | 11 | 0.120 | 0.123 | 0.125 | | | |
| 97 | 0.1017 | 12 | 0.105 | 0.108 | 0.110 | | | |
| 68 | 0.0713 | 14 | 0.075 | 0.078 | 0.080 | | | |
| 54 | 0.0566 | 16 | 0.060 | 0.063 | 0.065 | | | |
| 43 | 0.0451 | 18 | 0.048 | 0.052 | 0.054 | | | |
| 33 | 0.0346 | 20 | 0.036 | 0.040 | 0.042 | | | |
| 27 | 0.0283 | 22 | 0.030 | 0.033 | 0.035 | | | |

- 1. Steel thickness may vary according to industry mill standards.
- 2. Gauge numbers shown are for reference only.

Bolt Diameter

| in | mm |
|-----|------|
| 3/8 | 9.5 |
| 1/2 | 12.7 |
| 5/8 | 15.9 |
| 3/4 | 19.1 |
| 7/8 | 22.2 |
| 1 | 25.4 |

Metric Conversion

| Imperial | Metric |
|------------|----------|
| IIIIheiiai | MEHIC |
| 1 in | 25.40 mm |
| 1 ft | 0.3048 m |
| 1 lb | 4.448N |
| 1 Kip | 4.448 kN |
| 1 psi | 6895 Pa |

mm = millimeter m = meter N = newton kN = kilonewton Pa = pascal

If Common Rafter Roof Pitch is...

| Rise/Run | Slope |
|----------|-------|
| 1/12 | 5° |
| 2/12 | 10° |
| 3/12 | 14° |
| 4/12 | 18° |
| 5/12 | 23° |
| 6/12 | 27° |
| 7/12 | 30° |
| 8/12 | 34° |
| 9/12 | 37° |
| 10/12 | 40° |
| 11/12 | 42° |
| 12/12 | 45° |

Then Hip/Valley Rafter Roof Pitch becomes...

| NOOI FILCH DECOME | | | | | |
|-------------------|-------|--|--|--|--|
| Rise/Run | Slope | | | | |
| 1/17 | 3° | | | | |
| 2/17 | 7° | | | | |
| 3/17 | 10° | | | | |
| 4/17 | 13° | | | | |
| 5/17 | 16° | | | | |
| 6/17 | 19° | | | | |
| 7/17 | 22° | | | | |
| 8/17 | 25° | | | | |
| 9/17 | 28° | | | | |
| 10/17 | 30° | | | | |
| 11/17 | 33° | | | | |
| 12/17 | 35° | | | | |
| | | | | | |

CORROSION INFORMATION



Understanding the Issues

Metal connectors, anchors, and fasteners will corrode and may lose load-carrying capacity when installed in corrosive environments or exposed to corrosive materials. There are many environments and materials which may cause corrosion including ocean salt air, fire-retardants, fumes, fertilizers, preservative-treated wood, dissimilar metals, and other corrosive elements.

The many variables present in a single building environment make it impossible to accurately predict if, or when, significant corrosion will begin or reach a critical level. This relative uncertainty makes it crucial that specifiers and users be knowledgeable of the potential risks and select a product coating or metal suitable for the intended use. It is also important that regular maintenance and periodic inspections are performed, especially for outdoor applications.

It is common to see some corrosion on connectors especially in outdoor applications. Even Stainless Steel can corrode. The presence of some corrosion does not mean that load capacity has necessarily been affected or that a failure will occur. If significant corrosion is apparent or suspected, then the wood, fasteners and connectors should be inspected by a professional engineer or general contractor and may need to be replaced.

In the last several years, preservative-treated wood formulations have changed significantly. Many of the new formulations are more corrosive to steel connectors and fasteners than the traditionally used formulation of CCA-C. Simpson Strong-Tie testing has shown that ACQ-C, ACQ-D (Carbonate), CBA-A and CA-B treated woods are approximately 2 times more corrosive than CCA-C, while SBX-DOT (Sodium Borate) treated woods were shown to be less corrosive than CCA-C. Refer to technical bulletin T-PTWOOD for more information.

Due to the many different pressure treatment formulations, fluctuating retention levels, moisture content, and because the formulations may vary regionally, or change without warning, understanding which connectors and fasteners to use with these materials has become a complex task. We have attempted to provide basic knowledge on the subject here, but it is important to fully educate yourself by reviewing our technical bulletins on the topic, and also by viewing information and literature provided by others. Additionally, because the issue is evolving, it is important to get the very latest connector information on the topic by visiting our website at **www.strongtie.com/info**.

Stainless steel is always the most effective solution to corrosion risk. However, it is also more expensive and sometimes more difficult to obtain. To best serve our customers, Simpson Strong-Tie is evaluating the options to identify the safest and most cost-effective solutions. Based on our testing and experience there are some specific applications that are appropriate for ZMAX®/HDG or G90 connectors (see chart on page 13.)

Because increased corrosion from some newer preservative-treated wood is a new issue with little historical data, we have to base our recommendations on the testing and experience we have to date. It is possible that as we learn more, our recommendations may change, but these recommendations are based on the best information we have at this time.

See www.strongtie.com/info for additional critical information.

CORROSION INFORMATION




General Simpson Strong-Tie Recommendations

- Outdoor environments are generally more corrosive to steel. If you choose to
 use ZMAX or HDG on an outdoor project (i.e. deck, patio cover), you should
 periodically inspect your connectors and fasteners or have a professional
 inspection performed. Regular maintenance including water-proofing of the
 wood used in your outdoor project is also a good practice.
- For wood with actual retention levels greater than 0.40 pcf for ACQ and MCQ, 0.41 pcf for CBA-A, or 0.21 pcf for CA-B (Ground Contact), Stainless Steel connectors and fasteners are recommended. Verify actual retention level with the wood treater.
- When using Stainless Steel connectors, use Stainless Steel fasteners.
 When using ZMAX/HDG galvanized connectors, use fasteners that meet the specifications of ASTM A153.
- Testing indicates wood installed dry reduces potential corrosion. If dry wood is used, see our website for additional information.
- Using a barrier membrane can provide additional corrosion protection, see Technical Bulletin T-PTBARRIER.

Due to the many variables involved, Simpson Strong-Tie cannot provide estimates on service life of connectors, anchors or fasteners. We suggest that all users and specifiers also obtain recommendations for HDG, ZMAX (G185), mechanically galvanized, or other coatings from the treated wood supplier for the type of wood used. However, as long as the Simpson Strong-Tie recommendations are followed, Simpson Strong-Tie stands behind its product performance and our standard warranty (page 11) applies.

Guidelines for Selecting the Proper Connector



Consider the type of structure and how it will be used. These recommendations may not apply to non-structural applications such as fences.

2 Evaluate the Environment.

Testing and experience indicate that indoor dry environments are less corrosive than outdoor environments. Determining the type of environment where a connector or fastener will be used is an important factor in selecting the most appropriate material and finish for use on the connectors and fasteners. To help in your decision making, consider the following general exposure information:

Interior Dry Use: Includes wall and ceiling cavities, and raised floor applications of enclosed buildings that have been designed to ensure that condensation and other sources of moisture do not develop.

Exterior – Dry: Includes outdoor installations in low rainfall environments and no regular exposure to moisture.

Exterior – Wet: Includes outdoor installations in higher moisture and rainfall environments.

Higher Exposure Use: Includes exposure to ocean salt air, fire retardants, large bodies of water, fumes, fertilizers, soil, some preservative treated woods, industrial zones, acid rain, and other corrosive elements.

3 Evaluate and select a suitable pressure-treated wood for the intended application and environment.

The treated wood supplier should provide all the information needed regarding the wood being used. This information should include: the specific type of wood treatment used, if ammonia was used in the treatment, and the chemical retention level. If the needed information is not provided then Simpson Strong-Tie would recommend the use of Stainless Steel connectors and fasteners. You should also ask the treated wood supplier for a connector coating or material recommendation.

Use the chart on the right, which was created based on Simpson Strong-Tie testing and experience to select the connector finish or material.

If a pressure treated wood product is not identified on the chart, Simpson Strong-Tie has not evaluated test results regarding such product and therefore cannot make any recommendation other than the use of Stainless Steel with that product. Manufacturers may independently provide test results or other product use information; Simpson Strong-Tie expresses no opinion regarding any such information.

Compare the treated wood supplier's recommendation with the Simpson Strong-Tie recommendation.

If these recommendations are different, Simpson Strong-Tie recommends that the most conservative recommendation be followed.

Low = Use Simpson Strong-Tie standard painted and G90 galvanized connectors as a minimum.

Med = Use ZMAX/HDG galvanized connectors as a minimum. Use fasteners which meet the specifications of ASTM A153 or SDS screws with double-barrier coating.

High = Use Type 303, 304, 305 or 316 Stainless Steel connectors and fasteners.

| CONNECTO | CONNECTOR COATING RECOMMENDATION – STRUCTURAL APPLICATIONS | | | | | | | | |
|-----------------|--|---------------------|--------------------|--------------------|------------------------|--|-------|-----------------|--|
| | Untreated Wood | SBX/ DOT | мса | | CQ-D (Car A-B & CBA | | Other | | |
| Environment | | & Zinc Borate | | No Ammonia | With Ammonia | Higher Chemical Content ¹ | ACZA | or Uncertain | |
| Interior – Dry | Low | Low | Low ⁵ | Med ⁵ | Med | High | High | High | |
| Exterior – Dry | Low | N/A ² | Med | Med | High | High | High | High | |
| Exterior – Wet | Med | N/A² | Med ^{3,4} | Med ^{3,4} | High | High | High | High | |
| Higher Exposure | High | N/A² | High | High | High | High | High | High | |
| Uncertain | High | N/A ² | High | High | High | High | High | High | |

- Woods with actual retention levels greater than 0.40 pcf for ACQ and MCQ, 0.41 pcf for CBA-A, or 0.21 pcf for CA-B (Ground Contact level).
- 2. Borate treated woods are not appropriate for outdoor use.
- Test results indicate that ZMAX/HDG and the SDS double-barrier coating will perform adequately, subject to regular maintenance and periodic inspection. However, the nationally-approved test method used, AWPA E12-94, is an accelerated test, so data over an extended period of time is not available. If uncertain, use stainless steel.
- Some treated wood may have excess surface chemicals making it potentially more corrosive. If you suspect this or are uncertain, use stainless steel.
- Where noted in the table, applications where the wood is dry (moisture content less than 19%) when installed and will remain dry in-service may use a minimum coating recommendation of "Low".
- Type 316 stainless-steel connectors and fasteners are the minimum recommendation for ocean-salt air and other chloride environments.

COATINGS AVAILABLE Not all products are available in all finishes. Contact Simpson Strong-Tie for product availability, ordering information and lead times.

| Finish | Description L | | | | |
|-------------------------------------|--|--------|--|--|--|
| Gray Paint | Gray Paint Water-based paint intended to protect the product while it is warehoused and in transit to the jobsite. Powder Coating Baked on paint finish that is more durable than our standard paint and produces a better looking finished product. | | | | |
| Powder Coating | | | | | |
| Standard G90 Zinc Coating | tandard G90 Zinc Coating Zinc galvanized finish containing 0.90 oz. of zinc per square foot of surface area (total both sides). | | | | |
| 7/MAX: G185 | Galvanized (G185) 1.85 oz. of zinc per square foot of surface area (hot-dip galvanized per ASTM A653 total both sides). These products require hot-dip galvanized fasteners (fasteners which meet the specifications of ASTM A153). | Medium | | | |
| HOTPIPD G GALVANIZED® | Products are hot-dip galvanized after fabrication 68 MIL (14 ga.) and thicker. The coating weight increases with material thickness. The minimum specified coating weight is 2.0 oz./ft² (per ASTM A123 total both sides). These products require hot-dip galvanized fasteners (fasteners which meet the specifications of ASTM A153). | Medium | | | |
| Double-Barrier Coating (SDS Screws) | | | | | |
| STAINLESS STEEL | Products manufactured from Type 316L stainless steel, and provide greater durability against corrosion. Stainless steel nails are required with stainless steel products, and are available from Simpson Strong-Tie. | High | | | |

QUIK DRIVE® Auto-Feed Screw Driving Systems



Quik Drive auto-feed screw driving systems offer a labor saving method for installing specialty fasteners engineered for a wide range of cold-formed steel commercial and residential construction applications.

The systems offer several easy-to-use attachments that bring speed and reliability to applications that require the fastening power of screws.

Featuring patented collation technology, Quik Drive fasteners are designed to meet or exceed industry standards for strength and longevity while offering easy-to-load strips for efficient performance in auto-feed systems.

Some applications include:

- Subflooring, sheathing, wallplates and stairtreads
- · Decks and docks
- · Drywall
- · Fiber cement siding and backerboard
- · Composite or wood underlayment
- · Metal roofing and siding
- Tile roofing
- · Steel to steel

See **www.strongtie.com** or **Quik Drive**® catalog C-QD08 for more detailed information.

Screws for Cold-Formed Steel

X Series

#12 and #10 hex head screws, 5/16" drive





ER-1976

XQ114S1224 (QuikGuard) (QuikGuard) 12 x 1½" (32 mm) 12 x 1½" (38 mm) #5 drill point, 24 tpi #5 drill point, 24 tpi

TRSD Series

#10 screw, #3 drill point, truss head, clear zinc coating.



TRSD34S1016 3/4" (19mm)

PHSD Series

#8 screw, #2 drill point, pan head, clear zinc coating.



PHSD34S0818 3/4" (19mm) **Quik Drive Screw Strength**

| Model No. | Screw Size | Nominal | Strength | Factor | sistance Design (FD) | Allowable Stress Design (ASD) | | |
|----------------|---------------|---------------|-------------|------------------|----------------------------|----------------------------------|--------------------|--|
| NU. | 3126 | Shear Tension | | Shear Tension | | Shear Tension | | |
| | | Pss | Pts | ΦP _{ss} | ΦPts | P_{ss}/Ω | P _{ts} /Ω | |
| Steel to Steel | | | | | | | | |
| PHSD34S0818 | #8 x ¾" | 1495 | 1810 | 750 | 905 | 500 | 605 | |
| TRSD34S1016 | #10 x ¾" | 1885 | 2120 | 945 | 1060 | 630 | 705 | |
| X1S1016 | #10 x 1" | 1835 | 2885 | 920 | 1145 | 610 | 960 | |
| XQ1S1016 | #10 x 1" | 1835 | 2885 | 920 | 1145 | 610 | 960 | |
| X1S1214 | #12 x 1" | 2485 | 4045 | 1240 | 2020 | 830 | 1350 | |
| XQ1S1214 | #12 x 1" | 2485 | 4045 | 1240 | 2020 | 830 | 1350 | |
| | | Ste | el Deckind | | | | | |
| X78S1224 | #12 x 1/8" | 2665 | 4680 | _ | _ | _ | _ | |
| XQ78S1224 | #12 x 1/8" | 2800 | 4260 | 1400 | 2130 | 935 | 1420 | |
| XQ114S1224 | #12 x 11/4" | 2800 | 4260 | 1400 | 2130 | 935 | 1420 | |
| XQ112S1224 | #12 x 1½" | 2800 | 4260 | 1400 | 2130 | 935 | 1420 | |
| | | Metal-Roo | fing Clip t | o Steel | • | | | |
| PCSD1S1016 | #10 x 1" | 1705 | 2380 | 850 | 1190 | 570 | 795 | |
| PCSD1S1214 | #12 x 1" | 1760 | 3180 | 880 | 1590 | 585 | 1060 | |
| | | Metal-Roo | fing Clip t | o Wood | | | | |
| PC1BS1012 | #10-12 x 1" | 1415 | 2080 | 710 | 1040 | 470 | 695 | |
| PC1BS1211 | #12-11 x 1" | 1715 | 3080 | 860 | 1540 | 570 | 1025 | |
| PCULP1BS1012 | #10-12 x 1" | 1625 | 2275 | 815 | 1140 | 540 | 760 | |
| | | | Drywall | | • | | • | |
| DWF114PS | #6 x 1 1/4" | 1255 | 1575 | 630 | 790 | 420 | 525 | |
| DWF158PS | #6 x 1 %" | 1255 | 1575 | 630 | 790 | 420 | 525 | |
| DWFSD114PS | #6 x 1 1/4" | 1260 | 1720 | 630 | 860 | 420 | 575 | |
| DWFSD158PS | #6 x 1 5/8" | 1260 | 1720 | 630 | 860 | 420 | 575 | |
| | | | Cement Bo | | | | | |
| CB3BLG112S | #10 x 1 ½" | 1515 | 2045 | 755 | 1020 | 505 | 680 | |
| CB3BLG134S | #10 x 1 ¾" | 1540 | 2030 | 770 | 1015 | 515 | 675 | |
| | | | od to Stee | | | | | |
| PPSD11516S | #8 x 1 15/16" | 1565 | 2160 | 785 | 1080 | 520 | 720 | |

- Quik Drive screws have been tested per AISI Standard Test Method TS-04.
- Factor of Safety (Ω) , and Resistance Factor (Φ) are determined per 2001 AISI NAS & 2004 NAS Supplement Chapter F. P_{ss} and P_{ts} are nominal shear strength and nominal tension strength values for the screw itself respectively and are also known as the average (ultimate) values of all tests determined by independent laboratory testing.

Screws for Other Applications

DWF Series

#6 drywall screw, fine thread, sharp point, bugle head, gray phosphate finish.



DWF114PS DWF158PS 11/4" (32mm) 15/8" (41mm)

CB3BLG Series

#10 fiber cement board screw, coarse thread, type 17 point, bugle head, C3 mechanical galvanized corrosion protection.



CB3BLG134S CB3BLG112S 1¾" (45mm) 1½" (38mm)

DWF and CB3BLG Series for application attaching to CFS with thickness of 33-18 mil (20-25 ga).

PC Series

#10 and #12 metal roofing-to-wood, #2 square drive – BIT2S, coarse threads, type 17 point, pancake head, clear zinc coating



 PC1BS1012
 PC1BS1211

 (Clear Zinc)
 (Clear Zinc)

 10 x 1" (25 mm)
 12 x 1" (25 mm)

 Type 17 point, 12 tpi
 Type 17 point, 11 tpi

PCULP Series

#10 metal roofing-to-wood, #2 square drive – BIT2S, coarse threads, type 17 point, ultra-low profile pancake head, clear zinc coating



PCULPIBS1012 (Clear Zinc) 10 x 1" (25 mm) Type 17 point, 12 tpi

PCSD Series

#10 and #12 metal roofing-to-steel, #2 square drive – BIT2S, coarse threads, drill point, pancake head, available in clear zinc and Quik Guard® coatings.



 PCSD1S1016
 PCSDQ1S1016

 (Clear Zinc)
 (QuikGuard)

 10 x 1"
 10 x 1"

(QuikGuard)

DWFSD Series

(Clear Zinc)

#6 drywall screw, fine thread, #2 drill point, bugle head, yellow zinc coating.



 DWFSD158PS
 DWFSD114PS /

 15/6" (41mm)
 DWFSD114PS (clear zinc coating)

 DWFSG114PS (N2000 Coating)
 11/4" (32mm)

 ER-5623
 11/4" (32mm)

PPSD Series

#8 wood to steel screw, #2 drill point, flat head, yellow zinc coating.



PPSD11516S

115/16" (49mm)

DWFSD and PPSD Series for application attaching to CFS with thickness of 54-43 mil (16-18 ga).

Design values for shearwalls and diaphragms built with the PPSD, DWF or DWFSD series screws used to attach the structural sheathing to the framing; and in accordance with the AISI Lateral Standard are found in shearwall Tables C2.2-1 to C2.1-3 and diaphragm Table D2.1 of that document

SIMPSON Strong-Tie

Quik Drive Fasteners: Minimum Coating or Material Recommendation

| 4 | | | | | | | | |
|-----------------|-----------|--------------------------|------|---------------------------|---------------|-------------------------------|--|--|
| | | 27V/727 0 | | ACQ-C, ACQ-D, CA-B, CBA-A | | | | |
| Environment | Untreated | SBX/DOT & Zinc Borate | MCQ | w/o Ammonia | w/ Ammonia | Higher Chemical Content | | |
| Interior Dry | Low | Low | Low | Med | Med | High | | |
| Exterior | Med | N/A | Med | Med | High | High | | |
| Higher Exposure | High | N/A | High | High | High | High | | |

Low – Heavy zinc electroplate, yellow zinc dichromate, gray phosphate, C-3 mechanically galvanized, Climaseal®, TufCote®, clear zinc, 410 stainless steel

Med - N2000®. Quik Guard®

High - 305/316 stainless steel


- 1. Use 305/316 stainless steel with any treatment chemical not listed above or in uncertain environmental exposure conditions.
- 2. For wood with actual retention levels higher than 0.10 pcf (above ground) for CA-B and 0.20 pcf for CBA-A, or 0.25 pcf (above ground) for ACQ-D, ACQ-C and MCQ 305/316 stainless steel fasteners are recommended. Verify actual retention level with wood treater.
- 3. Borate treated woods are not appropriate for outdoor use.
- 4. Test results indicate that N2000 and Quik Guard will perform adequately, subject to regular maintenance and periodic inspection. However, the test protocol followed was a modified version of the nationally recognized test method AWPA E12-94. This test method is an accelerated test, so data over an extended period of time is not available. Also noteworthy is that tests run in a laboratory may not correlate to service conditions. If uncertain, use 305/316 stainless steel.
- Some treated wood may have excess surface chemicals making it potentially more corrosive. If you suspect this or are uncertain, use 305/316 stainless steel.
- 6. Ammonia is typically used as a chemical carrier for difficult to treat wood species, such as, but not exclusive to, Douglas Fir and Hem Fir, which are usually found in the Western United States. Amine carriers are used in some of the Eastern species, such as Southern Yellow Pine. If uncertain, verify chemical chemical with wood treater.

For the latest Simpson Strong-Tie® Quik Drive coating information and additional technical information on this topic, visit our website at www.strongtie.com/info.

SCREWS Self-Drilling Fasteners

To achieve the loads shown in this catalog, the Designer must verify that the self-tapping screws used have an allowable load capacity equal to or greater than those shown in the table below.

Hex head screw sizes shown are required for connectors in this catalog. Where sheathing or finishes will be applied over the screws and low profile heads are needed, such as with bracing connectors, hurricane ties, and stud-plate ties, the Designer is to ensure that the minimum screw head diameter complies with ASME B18.6.4.



Minimum ASD Loads for C-CFS10 Connector Screws

| | | | | | Sh | ear | | | | Tension | | | | | |
|------------------|----------|----------------|-----------------|---------|----------|---------------------------|-----------------|---------|-----------------|---------|------------|-------------------|------|------|--|
| Screw No. | Nominal | Washer | | | Shear | $(P_{ns}/\Omega, F_{ns})$ | O_{SS}/Ω | | | Te | ension: Pu | 2) | | | |
| | Diameter | Diameter | D /O | | Steel Ti | nickness: | mil (ga) | | D /O | | | ickness: mil (ga) | | | |
| Designation | d⁴ | d _w | P_{ss}/Ω | 33-33 | 43-43 | 54-54 | 68-68 | 97-97 | P_{ts}/Ω | 33 | 43 | 54 | 68 | 97 | |
| | | •• | | (20-20) | (18-18) | (16-16) | (14-14) | (12-12) | | (20) | (18) | (16) | (14) | (12) | |
| #8 | 0.164 | 0.318 | 335 | 165 | 245 | 335 | 335 | | 655 | 70 | 95 | 145 | 150 | | |
| #10 | 0.190 | 0.375 | 555 | 175 | 265 | 535 | 555 | 555 | 880 | 85 | 110 | 180 | 220 | 355 | |
| #14 ⁷ | 0.242 | 0.500 | 810 | 200 | 295 | 605 | 810 | 810 | 1225 | 80 | 140 | 185 | 200 | 320 | |

- 1. The tabulated loads may be multiplied by a Factor of Safety (Ω) of 3 to determine the screw nominal strength. The LRFD load may be determined by multiplying the nominal screw load by a Resistance Factor (Φ) of 0.50.
- Self-tapping screw fasteners for steel-to-steel connections used for connectors in this catalog shall be in compliance with ASTM C1513.
- 3. Values are based on cold-formed steel (CFS) members with a minimum yield strength, Fy, of 33 ksi and tensile strength, Fu of 45 ksi for 43 mils (18 ga) and thinner and a minimum yield strength of 50 ksi and tension strength of 65 ksi for 54 mils (16 ga) and thicker.
- Minimum base metal thickness is based on AISI General Provisions Standard Table A5.1-1. Design thickness shall be the minimum base metal thickness divided by 0.95. Design thickness for the steel sheets are: 33 mil=0.0346", 43 mil=0.0451", 54 mil=0.0566", 68 mil = 0.0713", and 97 mil = 0.1017".
- Minimum required screw length is the greater of 3/4" and the minimum length required for the screw to extend through the steel connection a minimum of (3) exposed threads per AISI General Provisions Standard Section D1.3.
- 6. Screw diameters per 2001 AISI NAS Commentary Table C-E4-1.
- 7. $\frac{1}{2}$ self-tapping screws may be substituted for #14 screws.

ANCHORMATE® Anchor Bolt Holders


Designed to hold the anchor in place before the concrete pour, as required in some jurisdictions.

FEATURES:

- Built-in 2x4 and 2x6 stops eliminate measuring.
- · Elevated bolt grippers allow easy trowel finishing.
- · Color-coded for easy size identification.
- · Lightweight, durable and easy to use.
- · Reusable yet cost-efficient for single application.
- Threaded grippers hold each bolt in the exact same location and height. They secure the bolt in place without a nut for quicker set-up and tear-down, and protect threads from splashing concrete.
- Use the 5/8" and 7/8" AnchorMate to secure the anchor bolt to the formboard before the concrete pour. Alignment arrows (left or right) match the anchor bolt
- · Available in cartons of 100 parts or bags of 10 parts.

MATERIAL: Nylon

CODES: See page 8 for Code Listing Key Chart.



.. Installation for a 2x6 Mudsill

180

AM¾

AM%

3/4

7/8

Red

Green

Typical AnchorMate Installation for a 2x4 Mudsill

ABS Anchor Bolt Stabilizer

The ABS stabilizes the anchor bolt to prevent it from being pushed against the form during the concrete pour.


FEATURES:

- Supports the bolt approx. 8" below the top of the
- Model ABS% is for the %" anchor bolts and ABS% is for 1/8" anchor bolts.
- Thin section limits the effect of a cold joint.
- Sized for 2x4 and 2x6 mudsills.

MATERIAL: Engineered Composite Plastic.

CODES: See page 8 for Code Listing Key Chart.

| Model No. | Diameter | Color | Code Ref. | | |
|-----------|----------|-------|-----------|--|--|
| ABS% | 5/8 | Blue | 180 | | |
| ABS% | 7/8 | Green | | | |



STRAPMATE® Strap Holder

The StrapMate is designed to keep the STHD. S/HPAHD and S/PAHD straps vertically aligned during the concrete pour to minimize possibility of spalling. The friction fit allows for quick and easy installation.


FEATURES:


- The StrapMate is reusable.
- Works with STHD, S/HPAHD, S/PAHD.

MATERIAL: Engineered Composite Plastic

- Designed to fit 3/4" plywood forms up to 13/4" LVL forms and
- The strap is positioned off the front edge of the form board. CODES: See page 8 for Code Listing Key Chart.

| Model No. | Nails | Code Ref. | | | |
|-----------|-------------|-----------|--|--|--|
| SM1 | 2-8d Duplex | 180 | | | |





BP/LBP Bearing Plates

Bearing plates give greater bearing surface than standard cut washers, and help distribute the load at these critical connections.

The BP½-3 and BP5⁄s-3 are available uncoated or with a hot-dip galvanized (HDG) finish.

MATÉRIAL: See table

FINISH: LBP, LBPS & BP%S—Galvanized; BP%-2—Zinc Plated; BPS, BP—None. BP's may be ordered HDG; LBP and LBPS products may be ordered ZMAX®; check with Simpson Strong-Tie. Refer to page 12–13 for Corrosion Information.

INSTALLATION: See General Notes.


CODES: See page 8 for Code Listing Key Chart.


These products are available with additional corrosion protection. Additional products on this page may also be available with this option, check with Simpson Strong-Tie for details.

| Model | Thickness | Dimer | nsions | Bolt | Code |
|----------|-----------|--------|--------|------|---------|
| No. | THICKHESS | W | L | Dia. | Ref. |
| LBP½ | 9/64 | 2 | 2 | 1/2 | 180 |
| LBP% | 9/64 | 2 | 2 | 5/8 | 100 |
| LBPS½ | 9/64 | 3 | 3 | 1/2 | 180 |
| LBPS% | 9/64 | 3 | 3 | 5/8 | 100 |
| BPS½-3 | 3 ga | 3 | 3 | 1/2 | 180 |
| BPS%-3 | 3 ga | 3 | 3 | 5% | 100 |
| BP½ | 3/16 | 2 | 2 | 1/2 | L8, 180 |
| BP½-3 | 3 ga | 3 | 3 | 1/2 | 180 |
| BP5/8-2 | 3/16 | 2 | 2 | 5/8 | 100 |
| BP% | 1/4 | 21/2 | 21/2 | 5/8 | L8 |
| BP5/8-3 | 3 ga | 3 | 3 | 5/8 | 180 |
| BP¾ | 5⁄16 | 23/4 | 23/4 | 3/4 | L8 |
| BP3/4-3 | 3 ga | 3 | 3 | 3/4 | 180 |
| BPS3/4-3 | 3 ga | 3 | 3 | 3/4 | 100 |
| BP%-2 | 3/8 | 115/16 | 21/4 | 7/8 | 180 |
| BP% | 5/16 | 3 | 3 | 7/8 | L8 |
| BP1 | 3/8 | 3½ | 3½ | 1 | LO |

^{1.} Standard cut washer required with BPS½-3 and BPS54-3 and BPS34-3 (not provided) per the 2006 IRC and IBC.







Typical BP Installed with a Bottom Track Anchor Bolt

CNW Coupler Nuts

Simpson Strong-Tie coupler nuts are tested and load rated to join threaded rod and anchor bolts. "Witness" holes in the nut provide a means to verify when rods are properly installed. The holes are aligned to allow inspection of both rods from one viewpoint. The positive stop feature helps ensure even threading into each end of the nut. CNW's meet and exceed the capacity of corresponding ASTM F1554 Grade 36 bolts and threaded rod. HSCNW's meet and exceed the capacity of corresponding ASTM A449 and ASTM A193 Grade B7 bolts and threaded rod. Contact Simpson Strong-Tie for other coupler nut sizes.


FINISH: Zinc Plated

INSTALLATION:

- Tighten the two rods until each all-thread rod is visible in the witness hole.
- For reducer couplers, tighten the coupler into the larger rod first.
- · For non-hot dipped galvanized all-thread rod only.
- %" and %" diameter couplers available with oversized threads for installation to galvanized bolts (order CNW%-%OST).

CODES: See page 8 for Code Listing Key Chart.

| Model No. | Rod Diameter | H Min | Code Ref. | | | |
|--------------|--------------------|----------|--------------|--|--|--|
| CNW½ | 0.500 | 1½ | | | | |
| CNW5/8 | 0.625 | 1% | | | | |
| CNW¾ | 0.750 | 21/4 | | | | |
| CNW7/8 | 0.875 | 21/2 | | | | |
| CNW1 | 1.000 | 23/4 | | | | |
| CNW11/4 | 1.250 | 3 | | | | |
| HSCNW¾ | 0.750 | 21/4 | 170 | | | |
| HSCNW1 | 1.000 | 23/4 | | | | |
| 1 | ransition Couplers | | | | | |
| CNW5/8-1/2 | 0.625 to 0.500 | 1½ | | | | |
| CNW3/4-5/8 | 0.750 to 0.625 | 13/4 | | | | |
| CNW7/8-5/8 | 0.875 to 0.625 | 2 | | | | |
| CNW1-7/8 | 1.000 to 0.875 | 21/4 | | | | |



MASA/MASAP Mudsill Anchor

The new MASA and MASAP mudsill anchors are easy to install for both the concrete and framing contractor. The anchors are suitable for either stemwall or slab foundations and easily mount on the forms before the pour, simplifying finishing and reducing anchor mislocation problems. The MASA features higher loads and provides an alternative to % and % anchor bolts. The MASA eliminates both the need to drill bolt holes in the track and the need for 3" square-plate washers.

The different models of mudsill anchors are designed for specific applications:

MASA—installed at the top of the form

MASAP—for panelized forms

MATERIAL: 54 mil. (16 ga.)


FINISH: Galvanized, all available in ZMAX® coating.

See Corrosion Information, page 12-13.


INSTALLATION: • Use all specified fasteners. See General Notes.


MASA/MASAP

- Concrete shall have a minimum f'c = 2500 psi.
- Spalling—Full published capacity is achieved so long as a maximum height of 1¼" and a maximum depth of ¾" is not exceeded. Any exposed portion of the mudsill anchor must be protected against possible corrosion.
- Testing shows that these mudsill anchors can be used in lieu of code-required anchor bolts and square washers in high seismic zones.










Standard MASAP **Installation in Concrete**



Standard MASA/MASAP Installation on CFS Track

ALLOWABLE LOADS FOR MASA/MASAP CAST-IN-PLACE MUDSILL ANCHOR ON CFS SILL

| | Faste | ners | | Allo | owable Loads (STANDARD II | lbs) 43mil (18 NSTALLATION | ga) | | | |
|-----------|--------|-----------------|----------------------|------------------------------------|-------------------------------|-------------------------------|------------------------------------|------------------|-----|--|
| Model No. | | _ | Wi | nd & SDC A and | 1 B ⁶ | | SDC C-F | SDC C-F | | |
| | Sides | Top of Track | Uplift | Parallel-to- Track ⁷ | Perpto- Track | Uplift | Parallel-to- Track ⁷ | Perpto- Track | | |
| | | | Non-Cracked Concrete | | | | | | | |
| MASA or | 0 #10 | C #10 | 740 | 1325 | 985 | 625 | 1115 | 825 | 170 | |
| MASAP | 3- #10 | 6- #10 | | | Cracked | Concrete | | | 170 | |
| | | | 560 | 1325 | 720 | 470 | 1115 | 605 | | |



For SI: 1 inch = 25.4 mm, 1 pound = 4.45 N, 1 psi = 6.895 kPa

- Allowable loads are governed by tests and may not be increased (C_D = 1.0).
 To obtain the LRFD loads, the tabulated allowable (ASD) loads shall be multiplied by 1.6 for designs for wind and in SDC A & B, and by 1.43 for designs in SDC C through F.
- 3. Minimum concrete compression strength, f'c is 2500 psi.
- 4. Allowable loads are based on a minimum stemwall width of 6".
- For simultaneous loads in more than one direction, the connector must be evaluated using the Unity Equation. See page 10, Instructions to the Designer, paragraph b.
- Per Section 1613 of the 2006 IBC, detached one- and two- family dwellings in SDC C may use the 'Wind & SDC A&B" allowable loads.
- Parallel-to-Track loads for One-Leg-Up Installation: Wind and SDC A-B = 1000 lbs, SDC C-F = 835 lbs.
- 8. MASA/P loads are based on testing procedures and calculations from ICC-ES Acceptance Criteria, AC398.

LCB column bases use screws, which allows for fast installation, reduced reveal and high capacity, while maintaining the net section of the column.

FINISH: LCB - galvanized. MATERIAL: See table

INSTALLATION: • Use all specified fasteners. See General Notes.

- For full loads, minimum side cover required is 2" for LCB.
- Install all models with bottom of base plate flush with concrete.
- · Post bases do not provide adequate resistance to prevent members from rotating about the base and therefore are not recommended for non top-supported installations (such as fences or unbraced carports).


OPTIONS: • The LCB may be shipped unassembled; specify "Disassembled".

CODES: See page 8 for Code Reference Key Chart.

| וווסנמוומנוטוו וטו |
|---------------------|
| cold-formed steel |
| built-up column. |
| Note: The engineer |
| record is responsit |

Installation for

r of ible for design of column and beam member.



LCB44 (LCB46, LCB66 similar)

| Model No. | Column | Connector Materi mil (ga | | Din | nensi | ons | Column Fasteners | Allov Uplift | vable Loads | Code | | |
|--------------|-----------|-----------------------------|------------|----------------|----------------|-----|---------------------|-------------------|-------------------|------|--|--|
| | Size | Strap | Base | W ₁ | W ₂ | D | Screws | 43 mil (18 ga) | 54 mil (16 ga) | Ref. | | |
| LCB44 | 3.5 x 3.5 | 97 (12 ga) x 2" | 54 (16 ga) | 3 %16 | 3 ½ | 6 ½ | | | | | | |
| LCB46 | 3.5 x 3.5 | 97 (12 ga) x 2" | 54 (16 ga) | 3 %16 | 5 ½ | 6 ½ | 12- #10 | 3155 | 5760 | FC1 | | |
| LCB66 | 3.5 x 5.5 | 97 (12 ga) x 2" | 54 (16 ga) | 5 ½ | 5 ½ | 5 ½ | | | | | | |

- 1. Sizes indicate nominal dimensions.
- 2. Designer is responsible for concrete design.

LCE Post Cap

The universal design of the LCE4 provides high capacity while eliminating the need for rights and lefts. For use with 3½" to 6" framing members.

MATERIAL: LCE4—33 mil. (20 ga)
FINISH: Galvanized, ZMAX® coating or stainless steel:

see Corrosion Information, page 12-13.


INSTALLATION: • Use all specified fasteners. See General Notes.

· Install in pairs.

CODES: See page 8 for Code Reference Key Chart.

These products feature additional corrosion protection. Additional products on this page may also be available with this option, check with Simpson Strong-Tie for details.

| Model | Dimo | | Fasteners | | | | | | |
|-------|---------|--------|-----------|---------|-------------------|-------------------|--------------------|-------------------|--------------|
| | Dilliel | nsions | (To | tal) | Up | lift | Late | eral | Code |
| No. | W | L | Beam | Post | 33 mil (20 ga) | 43 mil (18 ga) | 33 mill (20 ga) | 43 mil (18 ga) | Code Ref. |
| LCE4 | _ | 5% | 14- #10 | 10- #10 | 1700 | 2355 | 1420 | 2150 | 170 |



cold-formed steel built-up column.

Note: The Designer is responsible for design of column and beam member.

C-CFS10 @ 2010 SIMPSON STRONG-TIE COMPANY INC

IBC

SIMPSON Strong-Tie

Simpson Strong-Tie Anchor Systems® manufactures a full line of anchoring and fastening products for concrete and masonry. The product line includes adhesives for anchoring and crack injection, mechanical anchors, powder-actuated fasteners, gas-actuated concrete nailer and drill bits. Anchor Systems products offer unique solutions to applications in the light-framed construction market when used with, and without, Simpson Strong-Tie® connectors.

For complete information on product performance, installation requirements and appropriate code listings for Simpson Strong-Tie Anchor Systems® products, please call Simpson Strong-Tie and request an Anchor Systems CD-ROM which contains all of the information you need for your anchoring and fastening needs. In addition to complete product information and the Anchor Designer, Drill Bit Selector and Adhesive Estimator programs, the CD also contains product code reports, MSDS sheets and product fliers.

SET-XP[™] Structural Epoxy-Tie Anchoring Adhesive for Cracked and Uncracked Concrete

SET-XP™ is a 1:1 two component, high solids epoxy-based anchoring adhesive formulated for optimum performance in both cracked and uncracked concrete. SET-XP1 adhesive has been rigorously tested in accordance with ICC-ES AC308 and 2006 IBC requirements and has proven to offer increased reliability in the most adverse conditions, including performance in cracked concrete under static and seismic loading. SET-XP™ adhesive is teal in color in order to be identified as a high-performance adhesive for adverse conditions. Resin and hardener are dispensed and mixed simultaneously through the mixing nozzle. SET-XP™ adhesive exceeds the ASTM C881 specification for Type I and Type IV, Grade 3, Class C epoxy.

USES: • When SET-XP™ adhesive is used with the IXP™ anchor, all-thread rod or rebar, the system can be used in tension and seismic zones where there is a risk of cracks occurring that pass through the anchor location. It is also suitable for uncracked concrete conditions.



CODES: ICC-ES ESR-2508; City of L.A. RR 25744; Florida FL 11506.5 NSF/ANSI Standard 61 (216 in²/1000 gal). M The load tables list values based upon results from the most recent testing and may not reflect those in current code reports. Where code jurisdictions apply, consult the current reports for applicable load values.

APPLICATION: Surfaces to receive epoxy must be clean. The base-material temperature must be 50° F or above at the time of installation. For best results, material should be 70-80° F at the time of application. Cartridges should not be immersed in water to facilitate warming. To warm cold material, the cartridges should be stored in a warm, uniformly-heated area or storage container for a sufficient time to allow epoxy to warm completely. Mixed material in nozzle can harden in 5-7 minutes at a temperature of 40° F or above.

SET-XP Cartridge System

| Model No. | Capacity ounces (cubic inches) | Cartridge Type | Carton Quantity | Dispensing tool(s) | Mixing Nozzle | |
|-----------|---|-------------------|--------------------|---------------------------------|---------------|--|
| SET-XP22 | 22 (39.7) | side-by-side | 10 | EDT22B, EDT22AP, EDT22CKT | EMN22i | |

- 1. Cartridge estimation guides are available on page 64 of 2009-2010 Simpson Strong-Tie Anchoring and Fastening Systems for Concrete and Masonry catalog.
- 2. Detailed information on dispensing tools, mixing nozzles and other adhesive accessories is available on pages 87–92 2009-2010 Simpson Strong-Tie Anchoring and Fastening Systems for Concrete and Masonry catalog.
- 3. Use only appropriate Simpson Strong-Tie mixing nozzle in accordance with Simpson Strong-Tie instructions. Modification or improper use of mixing nozzle may impair

Cure Schedule

| Base M Temer | | Cure Time |
|-----------------|----|-----------|
| ٥F | °C | |
| 50 | 10 | 72 hrs. |
| 70 | 21 | 24 hrs. |
| 90 | 32 | 24 hrs. |
| 110 | 43 | 24 hrs. |

SET-XP™ Adhesive

system supplied in manufacturer's

SUGGESTED SPECIFICATION: Anchoring adhesive shall be a twocomponent high-solids, epoxy-based

standard cartridge and dispensed through a static-mixing nozzle supplied by the manufacturer. The adhesive

anchor shall have been tested and qualified for performance in cracked and uncracked concrete per ICC-ES AC308. Adhesive shall be SET-XP™ Epoxy-Tie® adhesive from Simpson Strong-Tie, Pleasanton, CA. Anchors shall be installed per Simpson Strong-Tie instructions for SET-XP Epoxy-Tie adhesive.

$oldsymbol{\mathsf{TIT}}oldsymbol{\mathsf{EN}}\,oldsymbol{\mathsf{HD}}^{ exttt{@}}$ Heavy-Duty Screw Anchor for Concrete and Masonry

The Titen HD® anchor is a patented, high-strength screw anchor for concrete and masonry. It is designed for optimum performance in both cracked and uncracked concrete; a requirement that the 2006 IBC places on post-installed anchors. The high-strength, easy-to-install Titen HD anchor has been tested and shown to provide outstanding performance in cracked and uncracked concrete under both static and seismic loading conditions. The self-undercutting, non-expansion characteristics of the Titen HD anchor make it ideal for structural applications, even at reduced edge distances and spacings. Recommended for permanent dry, interior, non-corrosive environments or temporary outdoor applications.

INSTALLATION: Holes in metal fixtures to be mounted should be \(\lambda \)" oversized for material thicker than 171 mil (7 ga). Use \(\lambda \) " oversized holes for material 171 mil (7 ga) and thinner.

Caution: Oversized holes in the base material will reduce or eliminate the mechanical interlock of the threads with the base material and will reduce the anchor's load capacity. Use a Titen HD screw anchor one time only. Installing the anchor multiple times may result in excessive thread wear and reduced load capacity.

 Drill a hole in the base material using a carbide drill bit the same diameter as the nominal diameter of the anchor to be installed. Drill the hole to the specified embedment depth plus 1/2" minimum to allow the thread tapping dust to settle and blow it clean using compressed

- air. Overhead installations need not be blown clean. Alternatively, drill the hole deep enough to accommodate embedment depth and dust from drilling and tapping.
- · Insert the anchor through the fixture and into the hole.
- · Tighten the anchor into the base material until the hex washer head contacts the fixture.
- · If the anchor will not install completely, remove the anchor and assure that all dust has been evacuated or drill the hole deeper. Begin re-installation of the anchor by hand to prevent cross-threading.
- · Do not use impact wrenches to install into hollow CMU.

SUGGESTED SPECIFICATIONS: Screw anchors shall have 360-degree contact with the base material and shall not require oversized holes for installation. Fasteners shall be manufactured from carbon steel and are heat-treated. Anchors shall be zinc-plated in accordance with ASTM B633 or mechanically galvanized in accordance with ASTM B695. Anchors are not to be reused after initial installation. Screw anchors shall be Titen HD® anchors from Simpson Strong-Tie, Pleasanton, CA. Anchors shall be installed per the Simpson Strong-Tie instructions for the Titen HD anchor.

*Some iurisdictions require an additional square-plate washer for sill-plate applications.



IBC

Titen HD® screw anchor U.S. Patent 5,674,035 and 6,623,228

ANCHOR SYSTEMS SET-XP™ Structural Epoxy-Tie Anchoring Adhesive for Cracked and Uncracked Concrete



Simpson Strong-Tie Anchor Systems® products offer several post-installed anchorage solutions for holdowns and bases. Often times these products are used when cast-in-place anchors are omitted or mislocated, or in retrofit applications. The following design values provide solutions to common applications encountered in the light frame construction market.

For complete information on product performance, installation requirements and appropriate code listings for Anchor Systems products please refer to the Anchor Systems catalog (form C-SAS) or visit www.simpsonanchors.com. Also refer to page 10 for Important Instructions to the Designer.

For Corrosion Information, see pages 12-13.

SEISMIC VALUES: IBC Section 1908.1.16 requires that concrete anchors in Seismic Design Categories C through F be governed by the strength of a ductile steel anchor. Anchors noted as limited by the steel capacity satisfy this requirement (footnote 9). Alternately, for anchor solutions limited by the concrete capacity, the IBC requires that either the attachment to the structure shall undergo ductile yielding at a load level less than the anchor design capacity, or the anchor strength shall be at least 2.5 times the demand force.

ANCHORING ADHESIVE SOLUTIONS


Shear Loads for Threaded Rod in Normal-Weight Concrete

| | | | | | Concrete Thick. | | Shear Loads ⁶ (lbs /ft) | | | | | | | |
|--------|-------|----------|----------|-------|--------------------|---------|------------------------------------|------------------------------|---------------------------------|-------------------------------|--------------------------|-------------------|-------------------|--|
| Anchor | Drill | Edge | End | Emb. | | Spacing | | Cond | rete4 | Cold-F | Cold-Formed Steel (ASD)⁵ | | | |
| Size | Bit | Distance | Distance | Depth | | Opacing | LRFD¹ (seismic) | LRFD ¹¹ (wind) | ASD ^{1,2} (seismic) | ASD ^{2,11} (wind) | 33 mil (20 ga) | 43 mil (18 ga) | 54 mil (16 ga) | |
| | | | | | | 0' - 8" | 1,360 | 1,815 | 970 | 1,130 | 895 | 1,320 | 2,485 | |
| | | | | | | 1'- 0" | 905 | 1,205 | 645 | 755 | 595 | 880 | 1,655 | |
| | | | | | | 1'- 4" | 680 | 905 | 485 | 565 | 445 | 660 | 1,240 | |
| 1/2 | 5/8 | 1¾ | 5 | 4 | 6½ | 2' - 0" | 455 | 605 | 325 | 375 | 300 | 440 | 830 | |
| | | | | | | 2' - 8" | 340 | 450 | 240 | 285 | 225 | 330 | 620 | |
| | | | | | | 4' - 0" | 225 | 300 | 160 | 190 | 150 | 220 | 415 | |
| | | | | | | 6' - 0" | 150 | 200 | 110 | 125 | 100 | 145 | 275 | |
| | | 1¾ | 5 | 5 | 8½ | 0' - 8" | 1,525 | 2,035 | 1,090 | 1,270 | 960 | 1,490 | 2,995 | |
| | | | | | | 1'- 0" | 1,015 | 1,355 | 725 | 845 | 640 | 995 | 2,000 | |
| | | | | | | 1'- 4" | 760 | 1,015 | 545 | 635 | 480 | 745 | 1,500 | |
| 5/8 | 3/4 | | | | | 2' - 0" | 510 | 680 | 365 | 425 | 320 | 495 | 1,000 | |
| | | | | | | 2' - 8" | 380 | 510 | 270 | 315 | 240 | 375 | 750 | |
| | | | | | | 4' - 0" | 255 | 340 | 180 | 210 | 160 | 250 | 500 | |
| | | | | | | 6' - 0" | 170 | 225 | 120 | 140 | 105 | 165 | 335 | |
| | | | | | | 0' - 8" | 1,675 | 2,235 | 1,195 | 1,395 | 965 | 1,600 | 3,320 | |
| | | | | | | 1'- 0" | 1,115 | 1,485 | 795 | 930 | 640 | 1,065 | 2,215 | |
| | | | | | | 1'- 4" | 835 | 1,115 | 595 | 700 | 480 | 800 | 1,660 | |
| 3/4 | 7/8 | 13/4 | 5 | 6 | 10 | 2' - 0" | 560 | 745 | 400 | 465 | 320 | 535 | 1,110 | |
| | | | | | | 2' - 8" | 420 | 555 | 300 | 350 | 240 | 400 | 830 | |
| | | | | | | 4' - 0" | 280 | 375 | 200 | 230 | 160 | 265 | 555 | |
| | | | | | | 6' - 0" | 185 | 245 | 135 | 155 | 105 | 180 | 370 | |

Tension Loads for Threaded Rod in Normal-Weight Concrete

| | | Bit Emb. Depth | | Tension Loads ⁶ (lbs) | | | | | | | | | | Tension Loads ¹⁰ | |
|--------|-----------|-------------------|----------------|----------------------------------|------------------------------|---------------------------------|-------------------------------|------------------|-----------------|------------------------------|---------------------------------|-------------------------------|-------------|-----------------------------|--|
| Anchor | Drill Bit | | | Edge an | d End Dista | nce (C _C) | | | linimum Edg | e (C _{min}) + Cı | ritical End (C | c) | Fu = 58 ksi | | |
| Dia. | Dilli bit | | C _C | LRFD¹ (seismic) | LRFD ¹¹ (wind) | ASD ^{1,2} (seismic) | ASD ^{2,11} (wind) | C _{min} | LRFD¹ (seismic) | LRFD ¹¹ (wind) | ASD ^{1,2} (seismic) | ASD ^{2,11} (wind) | LRFD | ASD | |
| 1/2 | | 4 | 6 | 3,175 | 4,235 | 2,270 | 2,645 | 1¾ | 1,620 | 2,160 | 1,155 | 1,350 | | | |
| | 5/8 | 7 | 8 | 5,525 | 6,175 ⁹ | 3,945 | 3,860 | 1¾ | 2,750 | 3,665 | 1,965 | 2,290 | 6,175 | 4,265 | |
| | | 10 | 8 | 6,175 ⁹ | 6,175 ⁹ | 4,410 | 3,860 | 1¾ | 3,925 | 5,235 | 2,805 | 3,270 | | | |
| | 3/4 | 5 | 8 | 3,415 | 4,555 | 2,440 | 2,845 | 1¾ | 1,630 | 2,175 | 1,165 | 1,360 | 9,830 6,675 | | |
| 5/8 | | 81/2 | 8 | 5,820 | 7,760 | 4,155 | 4,850 | 13/4 | 2,735 | 3,645 | 1,950 | 2,280 | | 6,675 | |
| | | 12 | 9 | 8,230 | 9,830 ⁹ | 5,880 | 6,145 | 1¾ | 3,870 | 5,160 | 2,765 | 3,225 | | | |
| | 7/8 | 6 | 9 | 6,085 | 8,115 | 4,345 | 5,070 | 13/4 | 2,750 | 3,665 | 1,965 | 2,290 | | 9,615 | |
| 3/4 | | 10½ | 12 | 10,150 | 13,535 | 7,250 | 8,460 | 13/4 | 5,050 | 6,735 | 3,605 | 4,210 | 14,530 | | |
| | | 15 | 15 | 14,530 ⁹ | 14,530 ⁹ | 10,380 | 9,080 | 13/4 | 7,800 | 10,400 | 5,575 | 6,500 | 1 | | |
| | | 8 | 10 | 5,305 | 8,845 | 3,790 | 5,530 | 13/4 | 2,380 | 3,965 | 1,700 | 2,480 | | | |
| 7/8 | 1 | 12 | 12 | 7,960 | 13,265 | 4,975 | 8,290 | 13/4 | 3,570 | 5,950 | 2,550 | 3,720 | 20,095 | 13,070 | |
| | | 18 | 14 | 11,610 | 19,355 | 8,295 | 12,095 | 13/4 | 5,205 | 8,675 | 3,720 | 5,420 | | | |
| | | 8 | 12 | 9,375 | 12,500 | 6,695 | 7,815 | 13/4 | 3,990 | 5,320 | 2,850 | 3,325 | | | |
| 1 | 11/8 | 14 | 18 | 17,890 | 23,855 | 12,780 | 14,910 | 13/4 | 7,910 | 10,545 | 5,650 | 6,590 | 26,360 | 17,075 | |
| | | 20 | 23 | 26,360 ⁹ | 26,360 ⁹ | 18,830 | 16.475 | 13/4 | 11.645 | 16.570 | 8,320 | 10,355 | 1 | | |

- Anchorage designs conform to ACI 318 Appendix D and assume cracked concrete with no supplementary reinforcement.
- Allowable Stress Design (ASD) values are obtained by dividing Load Resistance Factor Design (LRFD) capacities by 1.4 for seismic and 1.6 for wind.
- Load values based on the following: minimum concrete strength of 2,500 psi, dry hole temperature range 1 and continuous special inspection. Reference ICC-ES ESR-2508 for further information.
- Shear load is applied parallel to the edge of concrete. Anchor is considered as an individual anchor without influence from other anchors.
- 5. Cold-Formed Steel (CFS) shear values are based on 2001 AISI NAS, Eq. E3.3.1-1, m_f = 0.75, Ω =2.5. Reference General Notes for CFS properties. To convert from ASD to LRFD multiply value by 1.5.
- Governing shear load is the lesser of concrete and CFS. Governing tension load is the lesser of concrete and steel.
- For conditions not covered by these tables use the Simpson Anchor Designer ACI 318 Software available at www.simpsonanchors.com.
- Third and fourth edge distances must be ≥ 1.5 x Embedment Depth.
- 9. Failure mode governed by ductile steel rod (A307 Grade C). ≥ 1.5 x Emil
- LRFD steel strength based on ACI 318 Appendix D. ASD steel strength based on AISC Steel Construction Manual 13th Edition, Fu=58 ksi.
- 11. Wind design includes SDC A & B.



ANCHOR SYSTEMS — TITEN HD® Heavy-Duty Screw Anchor for Cracked and Uncracked Concrete



The Titen HD is a patented, high-strength threaded anchor for concrete and masonry. The self-undercutting, non-expansion characteristics of the Titen HD makes it the ideal anchor for structural applications, even at minimum edge distances and under reduced spacing conditions. The proprietary cutting teeth enable the Titen HD to be installed in significantly less time than traditional expansion anchors, and at significantly reduced installation torques. This heat-treated anchor undercuts the concrete to form a strong mechanical interlock over the entire length of the anchor. The anchor can be installed with a standard ANSI masonry drill bit and is removable. The Titen HD is recommended for permanent dry, non-corrosive applications or temporary outdoor applications.


FEATURES:

- · Higher load capacity and vibration resistance: Threads along the length of the anchor efficiently transfer the load to the base material.
- · Less spacing and edge distance required: The anchor does not exert expansion forces on the base material.
- No special drill bit needed: Designed to install using standard sized drill bits
- Installs with 50% less torque: Testing shows that when compared with a major competitor, the Titen HD requires 50% less torque to be installed in concrete.
- Less installation time: No secondary setting or torquing is required.
- Stamped Hex-washer head: Requires no separate washer and provides a clean installed appearance. The head is stamped with the Simpson Strong-Tie # sign and the anchor length in inches for easy inspection. (Some local building jurisdictions may require a separate washer.)
- Removable: Ideal for temporary anchoring (e.g. formwork, bracing) or applications where fixtures may need to be moved.

· Mechanical galvanized coating is available. Refer to www.strongtie.com/info for corrosion information.

CODES: ICC ESR-2713; ICC ESR-1056; City of L.A. RR25560: City of L.A. RR25741: Florida FL 11506.7. SEISMIC VALUES: IBC Section 1908.1.16 requires that concrete anchors in Seismic Design Categories C through F be governed by the strength of a ductile steel anchor. Alternately, for anchor solutions limited by the concrete capacity, the IBC requires that either the attachment to the structure shall undergo ductile yielding at a load level less than the anchor design capacity, or the anchor strength shall be at least 2.5 times the demand force.

For complete technical information please refer to the Simpson Strong-Tie® Anchoring and Fastening Systems for Concrete and Masonry catalog.



Edge and end distances for Titen HD in concrete slab corner condition U.S. Patent 5.674.035

CMU¹ Cold-Formed Steel²

Titen HD® – Shear and Tension Loads Attaching Cold-Formed Steel To Normal-Weight Concrete

| Anchor | Drill | Edao | End | Min. | Concrete | | | Concrete ^{3,4} | ¹ (seismic) | | | Cold-Formed | Steel (ASD)5 | |
|--------|-------|----------|----------|-------|--------------------|---------|------------|-----------------------------|----------------------------|--------------------|---------|-------------|--------------|---------|
| Anchor | | Edge | | Emb. | Concrete Thick. | Spacing | LRFD1 | LRFD8 | ` ASD ^{1,2} | ASD ^{2,8} | 33 mil | 43 mil | 54 mil | 68 mil |
| Size | Bit | Distance | Distance | Depth | Thick. | ' ' | (seismic) | (wind) | (seismic) | (wind) | (20 ga) | (18 ga) | (16 ga) | (14 ga) |
| | | | | | | | Shear Load | s Parallel-to-E | dge ⁶ (lbs /ft) | | | | | |
| | | | | | 3¾ | 0' - 8" | 660 | 880 | 475 | 550 | 765 | 1,030 | 1,860 | 2,350 |
| | | | 7 | | | 1' - 0" | 440 | 585 | 315 | 365 | 510 | 685 | 1,240 | 1,565 |
| | | | | 2½ | | 1' - 4" | 330 | 440 | 235 | 275 | 385 | 515 | 930 | 1,175 |
| % x 3 | 3/8 | 1¾ | | | | 2' - 0" | 220 | 295 | 155 | 185 | 255 | 340 | 620 | 780 |
| | | | | | | 2' - 8" | 165 | 220 | 120 | 135 | 190 | 255 | 465 | 585 |
| | | | | | | 4' - 0" | 110 | 145 | 80 | 90 | 130 | 170 | 310 | 390 |
| | | | | | | 6' - 0" | 75 | 100 | 55 | 60 | 85 | 115 | 205 | 260 |
| | | | 8 | 31/4 | 5 | 0' - 8" | 1,065 | 1,420 | 760 | 890 | 895 | 1,320 | 2,485 | 3,130 |
| | | | | | | 1'- 0" | 710 | 945 | 505 | 590 | 595 | 880 | 1,655 | 2,085 |
| | | | | | | 1'- 4" | 535 | 710 | 380 | 445 | 445 | 660 | 1,240 | 1,565 |
| ½ x 4 | 1/2 | 13/4 | | | | 2' - 0" | 355 | 475 | 255 | 295 | 300 | 440 | 830 | 1,045 |
| | | | | | | 2' - 8" | 265 | 355 | 190 | 220 | 220 | 330 | 620 | 780 |
| | | | | | | 4' - 0" | 180 | 240 | 130 | 150 | 150 | 220 | 415 | 520 |
| | | | | | | 6' - 0" | 120 | 160 | 85 | 100 | 100 | 145 | 275 | 350 |
| | | | | | | | | nsion Loads ⁶ (l | | | | | | |
| % x 3 | 3/8 | 13/4 | 3 | 2½ | 3¾ | 6 | 600 | 800 | 430 | 500 | 390 | 505 | 920 | 1,160 |
| ½ x 4 | 1/2 | 13/4 | 4 | 31/4 | 5 | 8 | 940 | 1,255 | 670 | 785 | 390 | 505 | 920 | 1,160 |
| /2 A T | 72 | 4 | 4 | 31/4 | 5 | 8 | 1,490 | 1,985 | 1,065 | 1,240 | 030 | 000 | 320 | 1,100 |

- Seismic tabulated values are for cracked concrete; an adjustment factor of 0.75 is assumed per ACI 318 Section D.3.3.3 for SDC C through F. See note regarding SEISMIC VALUES.
- Converting LRFD to ASD assume LRFD values divided by 1.4 and 1.6 for seismic and wind respectively
- Shear load is applied parallel to the edge of concrete. Anchor is considered as an individual anchor without influence from other anchors Concrete shall have a minimum f'c of 2,500 psi. Reference ICC-ES ESR-2713 for
- CFS values are based on 2001 AISI NAS, Eq. E3.3.1-1 for shear (m_f = 0.75, Ω = 2.5) and Eq. E4.4.2-1 for tension (Ω = 3.0, d_w = 0.5"). Reference General Notes for CFS properties. Governing load is the lesser of Concrete and CFS.
- For conditions not covered by this table use the Simpson Anchor Designer ACI 318 Software available at www.simpsonanchors.com.
- Wind tabulated values are for uncracked concrete without supplemental reinforcement. Wind design includes SDC A and B.

TITEN® Concrete & Masonry Screws

Titen screws are 3/16" and 1/4" diameter masonry screws for attaching all types of components to masonry. Carbon-steel Titen screws are available in hex and phillips head designs in blue, white or silver colors. Use with appropriately sized Titen drill bits included with each box.

CODES: FL 2355.1 (Carbon-steel Titen)

Titen Installation Sequence







WARNING: Carbon Steel: Industry studies show that hardened fasteners can experience performance problems in wet environments. Accordingly, use this product in dry, interior applications

only. Stainless Steel: Acceptable for use in exterior environments. See corrosion on page 16 of C-SAS-2009.



Special hex adapter on the bit allows the Titen Installation Tool to slide over the bit and lock in, ready to drive screws.

Titen

Stainless-

Steel

Hex Head

Titen

Titen

Titen

Drill Bit

/ Driver

Titen® Screws - Shear and Tension Loads

| Anchor | Embed | Edao | | | | 0014 1 0111 | 0.00. |
|----------------|-------|------------------|------------|-------------|--------------------------|-------------|------------|
| Anchor Size | Depth | Edge Distance | Spacing | Screw S | teel Type | 33 mil | 43 mil |
| 3126 | Dehm | Distance | | Carbon | Stainless | (20 ga) | (18 ga) |
| | | (ASE |) Allowab | le Shear Lo | ad3,4 (lbs/ft) | | |
| | | | 0'-4" | 615 | _ | 795 | 1020 |
| | | | 0'-6" | 410 | _ | 530 | 680 |
| 3/16 | 4 | 11/8 | 1'-0" | 205 | _ | 265 | 340 |
| 716 | 1 | 1 78 | 1'-6" | 135 | _ | 175 | 225 |
| | | | 2'-0" | 100 | _ | 135 | 170 |
| | | | 3'-0" | 70 | _ | 90 | 115 |
| | | | 0'-4" | 750 | 300 | 1050 | 1365 |
| | | | 0'-6" | 500 | 200 | 700 | 910 |
| | | | 1'-0" | 250 | 100 | 350 | 910 455 |
| 1/4 | 1 | 1 1/2 | 1'-6" | 165 | 65 | 235 | 305 |
| | | | 2'-0" | 125 | 50 | 175 | 230 |
| | | | 3'-0" | 85 | 35 | 115 | 150 |
| | | | 4'-0" | 60 | 25 | 90 | 115 |
| | | (ASD |) Allowabl | e Tension l | Load ^{3,4} (lbs |) | |
| 3/16 | 1 | 11/8 | 21/4 | 110 | | 240 | 315 |
| 1/4 | 1 | 1½ | 4 | 150 | 110 | 290 | 380 |

- Allowable loads are based on a safety factor of 5.0 for installations under the IBC and IRC.
- Cold-Formed Steel (CFS) values are based on 2001 AISI NAS, Section E4, Ω =3.0, d_W =%16 (%16" Titen) and d_W =%1 (%1" Titen). Reference General Notes for CFS properties.
- Governing load is the lesser of CMU and CFS.
- Use interaction formula for combined tension and shear (Ps/Pt)+(Vs/Vt) ≤ 1.0.



The GCN150 gas-actuated concrete nailer is a portable fastening tool for attaching light-duty fixtures such as drywall track, furring strips, hat track and angle track to concrete, steel, CMU and metal deck. The GCN150 has a portable gas fuel supply that does not require electrical cords or hoses. The GCN150 sets up quickly and offers maximum productivity. With a 500 shot-per-hour capacity and a pin iam release door, the GCN150 makes fastening pins fast and easy. Additional attributes include 2-step pin loading into the magazine, light and well-balanced weight, a battery indicator light and a sure-grip rubber handle pad.

The GDP concrete pins are designed to work with the GCN150 Gas-Actuated Concrete Nailer as well as with most major brand gas concrete nailer tools. The patent-pending plastic collation of the 10-pin strip is a break-away design that minimizes the possibility of a jam. The GDP pins are designed for use in A36 and A572 steel, concrete and CMU block.

GDP pins are code listed under ICC-ES ESR-2811. This report covers the fastening of building components, such as cold-formed-steel framing members, to normal-weight concrete, structural sand-lightweight concrete, structural sand-lightweight concrete on metal deck, concrete masonry units (CMU) and steel base materials. GDP gas-actuated pins were tested in accordance with ICC-ES Acceptance Criteria AC70 for recognition under the 2006 IBC, the 2006 IRC and the 1997 UBC.

CODES: ICC-ES ESR-2811



(Patent Pending)



0.106 Diameter Shank Drive Pins for the GCN150

| Model No. | Length | Qty Pins / pack +1 Fuel Cell | Packs/ Carton | Compatible with these Tools | | | | |
|-----------|--------|---------------------------------|------------------|-----------------------------|--|--|--|--|
| GDP-50KT | 1/2" | 1,000 | 5 | | | | | |
| GDP-62KT | 5/8" | 1,000 | 5 | | | | | |
| GDP-75KT | 3/4" | 1,000 | 5 | Simpson Strong-Tie GCN150 | | | | |
| GDP-100KT | 1" | 1,000 | 5 | Others: TF1100, C3 | | | | |
| GDP-125KT | 11/4" | 1,000 | 5 | | | | | |
| GDP-150KT | 1½" | 1,000 | 5 | | | | | |

GDP Pin - Shear and Tension Loads

| | Dia. | Spacing | | | Base Material | Attached Material | | | | | | | |
|-------|---------------------------------|---------|------------|---------------|---------------|--------------------------|-------|--------------------------------|-------------------|-------------------|--|--|--|
| Model | | | Normal-Wei | pht Concrete¹ | | A36 Steel ² | | Cold-Formed Steel ³ | | | | | |
| Туре | | | 2,000 psi | 4,000 psi | 1/4" | 3/16" | 1/8" | 33 mil (20 ga) | 43 mil (18 ga) | 54 mil (16 ga) | | | |
| | Allowable Shear Load 4 (lbs/ft) | | | | | | | | | | | | |
| | 0.400 | 0'-4" | 135 | 225 | 435 | 675 | 855 | 445 | 580 | 1055 | | | |
| | | 0'-6" | 90 | 150 | 290 | 450 | 570 | 295 | 385 | 700 | | | |
| | | 0'-8" | 70 | 115 | 215 | 340 | 430 | 225 | 290 | 525 | | | |
| GDP | 0.106 | 1'-0" | 45 | 75 | 145 | 225 | 285 | 150 | 195 | 350 | | | |
| | | 2'-0" | 25 | 40 | 75 | 115 | 145 | 75 | 95 | 175 | | | |
| | | 3'-0" | 15 | 25 | 50 | 75 | 95 | 50 | 65 | 115 | | | |
| | | | | | Allowable T | ension Load ⁴ | (lbs) | | | | | | |
| | 0.106 | _ | 30 | 30 | 185 | 210 | 125 | 195 | 255 | 460 | | | |

- 1. For Normal-Weight Concrete the minimum edge distance and spacing is 3" and 4" respectively with ¾" minimum embedment.
- 2. For A36 Steel the minimum edge distance and spacing is 0.5" and 1" respectively. Fastener must fully penetrate steel base material.
- 3. Cold-Formed Steel (CFS) values are based on 2001 AISI NAS, Section E4. Reference General Notes for CFS properties.
- 4. Governing load is the lesser of the base material and CFS.

POWDER-ACTUATED FASTENERS

Powder-actuated fasteners provide a quick and economical method for fastening cold-formed steel to concrete or steel base materials. CODES: ICC-ES ESR-2138; City of LA RR 25469; FL 11506.3

In Normal-Weight Concrete

| PDP-Series Fasteners | | | | | | | | | |
|----------------------|----------|-----------|--|--|--|--|--|--|--|
| PDP* | PDPW | PDPWL* | | | | | | | |
| PDP-125 | PDPW-125 | PDPWL-125 | | | | | | | |
| PDP-150 | PDPW-150 | PDPWL-150 | | | | | | | |
| PDP-175 | PDPW-175 | PDPWL-175 | | | | | | | |
| PDP-200 | PDPW-200 | PDPWL-200 | | | | | | | |
| PDP-225 | _ | _ | | | | | | | |
| PDP-250 | PDPW-250 | PDPWL-250 | | | | | | | |

PDPW-300

1. *Including stainless steel models.

| PHN-26 | ries Fasteners | |
|--------|----------------|----------|
| PHN | PHNW | PHSNA |
| PHN-27 | 7 PHNW-27 | PHSNA-27 |
| PHN-32 | PHNW-32 | PHSNA-32 |
| PHN-37 | 7 PHNW-37 | PHSNA-37 |
| PHN-42 | PHNW-42 | PHSNA-42 |
| PHN-47 | 7 PHNW-47 | PHSNA-47 |
| PHN-52 | PHNW-52 | PHSNA-52 |
| PHN-57 | 7 PHNW-57 | PHSNA-57 |
| PHN-62 | PHNW-62 | PHSNA-62 |
| PHN-72 | 2 PHNW-72 | PHSNA-72 |

In Lightweight Concrete Over Steel Deck

PDPT-Series Fasteners

| PDPT | |
|----------|-----------|
| PDPT-50K | (knurled) |
| PDPT-62K | (knurled) |
| PDPT-75 | |
| PDPT-100 | |
| | |

In Steel

PDP-225 PDP-250

PDP-300

PDP-Series Fasteners

PDP-300

PDP **PDPW PDPWL** PDP-100 PDPW-100 PDP-125 PDPW-125 PDP-150 PDPW-150 PDP-175 PDPW-175 PDPW-200 PDP-200

PDPW-250

PDPW-300

PDPWL-100 PDPWL-125 PDPWL-150 PDPWL-175 PDPWL-200 PDPWL-250


PDPWL-300

PDPWL-300

PDPWL-400

| PHN-Series | Fasteners |
|-------------------|------------------|
|-------------------|------------------|

| PHNW | PHSNA |
|---------|--|
| PHNW-27 | PHSNA-27 |
| PHNW-32 | PHSNA-32 |
| PHNW-37 | PHSNA-37 |
| PHNW-42 | PHSNA-42 |
| PHNW-47 | PHSNA-47 |
| PHNW-52 | PHSNA-52 |
| PHNW-57 | PHSNA-57 |
| PHNW-62 | PHSNA-62 |
| PHNW-72 | PHSNA-72 |
| | PHNW-27 PHNW-32 PHNW-37 PHNW-42 PHNW-47 PHNW-52 PHNW-57 PHNW-62 |



PRODUCT NOMENCLATURE

EXAMPLE:

PDP-175 = 0.145 Dia. PIN x 13/4" length (no washer)

0.145 Dia. PIN PHN-52 = x 52mm length (no washer)


PDPT-100 = 0.145 Dia. PIN x 1" length (no washer)


 $\mathbf{W} = \frac{3}{4}$ " Dia. metal washer (PDP) 1" Dia. metal washer (PHN)

WL = 1" Dia. metal washer (PDP)

Refer to the latest Simpson Strong-Tie® Anchor and Fastening Systems for Concrete and Masonry catalog for further information on powder-actuated fasteners







PDPT In Lightweight Concrete Over Steel Deck

PDP/PHN Pin - Shear and Tension Loads

POWDER-ACTUATED FASTENERS

| | Dia. | Spacing | | Base N | laterial | | Attached Material | | | |
|------------|-------|---------|------------|-----------------|-----------------------------|------------------------|-------------------|-------------------|-------------------|--|
| Madel Tone | | | Norn | nal Weight Cond | rete ¹ | A36 Steel ² | C | old Formed Stee | J 3 | |
| Model Type | | | Emb. Depth | 2,000 psi | 4,000 psi | 3/16" | 33 mil (20 ga) | 43 mil (18 ga) | 54 mil (16 ga) | |
| | | | | Allowa | ble Shear Load ⁴ | (lbs/ft) | | | | |
| | | 0'-4" | 1 | 360 | 615 | 1185 | 610 | 795 | 1440 | |
| | 0.145 | 0 -4 | 11/4 | 795 | 795 | 1100 | 610 405 305 | 795 | 1440 | |
| | | 0'-6" | 1 | 240 | 410 | 790 | 405 | E20 | 960 | |
| | | 0 -0 | 11/4 | 530 | 530 | 790 | | 900 | | |
| | | 0'-8" | 1 | 180 | 310 | 595 | 205 | 205 | 720 | |
| | | 0 -0 | 11/4 | 400 | 400 | 595 | 305 | 393 | 720 | |
| PDP | | 1'-0" | 1 | 120 | 205 | 395 | 205 | 065 | 400 | |
| PHN | | 1 -0 | 11/4 | 265 | 265 | 393 | 203 | 200 | 480 | |
| | | 2'-0" | 1 | 60 | 105 | 200 | 100 | 130 | 240 | |
| | | 2 -0 | 11/4 | 135 | 135 | 200 | 100 | 130 | 240 | |
| | | 3'-0" | 1 | 40 | 70 | 130 | 70 | 90 | 160 | |
| | | 3 -0 | 11/4 | 90 | 90 | 130 | 70 | 90 | 100 | |
| | | | | Allowa | ble Tension Loa | d4 (lbs) | | | | |
| | 0.145 | | 1 | 45 | 150 | 155 | 235 | 305 | 550 | |
| | 0.140 | _ | 11/4 | 140 | 370 | 100 | 233 | 303 | 550 | |

- 1. For Normal-Weight Concrete the minimum edge distance and spacing is 3" and 4" respectively.
- 2. For A36 Steel the minimum edge distance and spacing is 0.5" and 1" respectively. Fastener must fully penetrate steel base material.
- 3. Cold-Formed Steel (CFS) values are based on 2001 AISI NAS, Section E4. Reference General Notes for CFS properties.
- 4. Governing load is the lesser of the base material and CFS.
- 5. Allowable loads for Base Material are based on ESR-2138.

PDPT Pin - Shear and Tension Loads

| | Dia. | Spacing | | Base M | laterial | Attached Material | | | | | |
|------------|--|---|-------------------|--|------------|--------------------|--------------------------------|-------------------|-------------------|--|--|
| Model Type | | | | t Concrete ^{1, 2} eel Deck | A36 Steel⁴ | | Cold Formed Steel ⁵ | | | | |
| | | | Concrete (Top) | Lower Flute ³ (Bottom) | 1/4" | 3/ ₁₆ " | 33 mil (20 ga) | 43 mil (18 ga) | 54 mil (16 ga) | | |
| | Allowable Shear Load ⁶ (lbs/ft) | | | | | | | | | | |
| | 0.145 | 0'-4" | 750 | 825 | 2100 | 1980 | 610 | 795 | 1440 | | |
| | | 0'-6" | 500 | 550 | 1400 | 1320 | 405 | 530 | 960 | | |
| | | 0'-8" | 375 | 415 | 1050 | 990 | 305 | 395 | 720 | | |
| PDPT | | 1'-0" | 250 | 275 | 700 | 660 | 205 | 265 | 480 | | |
| | | 2'-0" | 125 | 135 | 350 | 330 | 100 | 130 | 240 | | |
| | | 3'-0" | 85 | 90 | 235 | 220 | 70 | 90 | 160 | | |
| | | Allowable Tension Load ⁶ (lbs) | | | | | | | | | |
| | 0.145 | _ | 85 | 40 | 340 | 290 | 235 | 305 | 550 | | |

- 1. For Light-Weight Concrete the minimum edge distance and spacing is 3" and 4" respectively with %" minimum embedment. Concrete shall have a minumum compressive strength of f'c=3000 psi.
- 2. For steel deck the minimum depth and thickness is 3" and 33mil (20ga) respectively.
- 3. For deck web the minimum edge and end distance is $1\frac{1}{2}$ and 4" respectively with 4" minimum spacing.
- 4. For A36 Steel the minimum edge distance and spacing is 0.5" and 1" respectively. Fastener must fully penetrate steel base material.
- 5. Cold-Formed Steel (CFS) values are based on 2001 AISI NAS, Section E4. Reference General Notes for CFS properties.
- 6. Governing load is the lesser of the base material and CFS.
- 7. Allowable loads for Base Material are based on ESR-2138.

C-CFS10 @ 2010 SIMPSON STRONG-TIE COMPANY INC.

The geometry of the SB bolt is the latest development in high-capacity anchors. The smooth transition angle of the bolt positions the head of the anchor into an optimum position in the concrete stem wall without creating excessive horizontal forces. The SB7/6x24 is designed to maximize performance with minimum embedment while the SB1x30 is intended to cover holdown devices which exceed the capacity of SSTB anchor bolts.

Special Features:


- Identification on the bolt head showing embedment angle and model
- · Stamped embedment line
- · Rolled thread for higher tensile capacity
- Tested in different compressive strength concretes for versatility in specification

MATERIAL: ASTM F1554 Grade 36

FINISH: None. May be ordered hot-dip galvanized (HDG). Contact Simpson Strong-Tie.

INSTALLATION:

- SB is only for concrete applications poured monolithically unless otherwise noted.
- Install 1-#4 rebar in the area 3" to 5" (may be foundation rebar not post-tension cable) from the top of the foundation.
- Top nuts and washers for holdown attachment are not supplied with the SB; install standard nuts, couplers and/or washers as required.



Recent testing by Simpson Strong-Tie to the new ICC-ES Acceptance Criteria for *Cast-In-Place Proprietary Bolts* in concrete for Light-Frame Construction (AC399) has been submitted to ICC-ES for code approval. Reference **www.strongtie.com** for published load information and new ICC-ES code report with evaluation scope in compliance with the 2006 and 2009 IBC and 2006 and 2009 IRC.

The SSTB is designed for maximum performance as an anchor bolt for holdowns and Strong-Wall® shearwalls. Extensive SSTB testing has been done to determine the design load capacity at a common application, the garage stem wall. Design loads are based on recent testing by Simspon Strong-Tie to the new ICC-ES acceptance criteria for cast-in-place proprietary bolts in concrete for light-frame construction (AC 399).

SPECIAL FEATURES: • Rolled threads for higher tensile capacity.

- Offset angle reduces side-bursting, provides more concrete cover.
- · Stamped embedment line aids installation.
- · Configuration results in minimum rebar interference.

MATERIAL: ASTM F1554 Grade 36

FINISH: None. May be ordered hot-dip galvanized (HDG); check with Simpson Strong-Tie

INSTALLATION: • SSTB is used for monolithic and two-pour installations.


 Nuts and washers are not supplied with the SSTB: install standard nuts. couplers and/or washers as required. On HDG SSTB anchors, chase the threads to use standard nuts or couplers or use overtapped products in accordance with ASTM A563 (Simpson Strong-Tie NUT%-OST, NUT%-OST, CNW%-%OST, CNW%-%OST).

REINFORCED CONCRETE FOUNDATION


- Install SSTB before the concrete pour using AnchorMates (see page 16). Install the SSTB per plan view detail shown on page 28. Install one #4 rebar 3" to 5" (may be foundation rebar not post-tension cable) from the top of the foundation.
- . The SSTB does not need to be tied to the rebar.
- Minimum concrete compression strength is 2500 psi. Unless noted otherwise, no special inspection is required for foundation concrete when the structural design is based on concrete no greater than 2500 psi (IBC Section 1704.4).
- · Unless otherwise noted, do NOT install where: (a) a horizontal cold joint exists within the embedment depth between the slab and foundation wall or footing beneath, unless provisions are made to transfer the load, or the slab is designed to resist the load imposed by the anchor; or (b) slabs are poured over concrete block foundation walls.

REINFORCED CONCRETE BLOCK


- · Before concrete grout is poured, install diagonally at approx. 45° in the cell per plan view detail shown on next page.
- Horizontal #4 rebar (minimum 56" long centered about the anchor bolt)—approximately one rebar 12" from the top and two rebars approximately 28" from the top. Vertical #4 rebar (minimum 24" long) install with maximum 24" o.c. spacing.
- Grout all cells with minimum 2000 psi concrete. Vibrate the grout per the International Building Code, Section 2104.1.
- Refer to Simpson Strong-Tie[®] Wood Construction Connectors catalog for allowable tension loads in masonry.



Recent testing by Simpson Strong-Tie to the new ICC-ES Acceptance Criteria for Cast-In-Place Proprietary Bolts in concrete for Light-Frame Construction (AC399) has been submitted to ICC-ES for code approval. Reference www.strongtie.com for published load information and new ICC-ES code report with evaluation scope in compliance with the 2006 and 2009 IBC and 2006 and 2009 IRC.




Typical SSTB Installation Maintain minimum rebar cover, per ACI-318 concrete code requirements



Two-Pour Installation (SSTB20, 24 and 34)

Corner **Non-Corner** Corner Installation Installation Installation (Install with arrow (Bolt may be installed @ 45° to 135° as shown) (Install with arrow on top of the bolt oriented as shown) on top of the bolt oriented as shown) 135°/90°/45° 45° Anchor Bolt ر (Typ.) 0° Outer Edge of Concrete (Typ.)

Plan View of SSTB Placement in Concrete Stemwall



RFB Retrofit Bolts


RFBs are clean, pre-cut threaded rod, supplied with nut and washer for use with Simpson Strong-Tie® anchoring adhesives. May be ordered in bulk without the nut and washer. Use with Simpson Strong-Tie anchoring adhesives to anchor into existing concrete and masonry. Offers a complete engineered anchoring system when used with Simpson Strong-Tie anchoring adhesives. Inspection is easy; each end of the threaded rod is stamped with rod length in inches and "No-Equal" symbol for identification after installation.

MATERIAL: A307, Grade C

FINISH: Zinc-Plated, Hot-Dip Galvanized (per ASTM 153). Stainless Steel (RFB#%x8SS)

INSTALLATION:

 Request the current Anchoring and Fastening Systems for Concrete and Masonry catalog for more information.



These products feature additional corrosion protection. Additional products on this page may also be available with this option, check with Simpson Strong-Tie for details.

| Description Dia. Length | Zinc Plated Model No. | Hot-Dip Galvanized Model No. | Ctn Qty | Bulk ¹ Qty | Retail ² Pack |
|-------------------------|--------------------------|---------------------------------|------------|--------------------------|-----------------------------|
| ½" x 4" | RFB#4x4 | RFB#4x4HDG | 50 | 50 | _ |
| ½" x 5" | RFB#4x5 | RFB#4x5HDG | 50 | 50 | 10 |
| ½" x 6" | RFB#4x6 | RFB#4x6HDG | 50 | 50 | 10 |
| ½" x 7" | RFB#4x7 | RFB#4x7HDG | 50 | 50 | 10 |
| ½" x 8" | _ | RFB#4x8HDG | _ | _ | 10 |
| ½" x 10" | RFB#4x10 | RFB#4x10HDG | 25 | _ | 10 |
| 5⁄8" x 5" | RFB#5x5 | RFB#5x5HDG | 50 | 50 | 10 |
| 5⁄8" x 8" | RFB#5x8 | RFB#5x8HDG | 50 | _ | 10 |
| %" x 10" | RFB#5x10 | RFB#5x10HDG | 50 | | 10 |
| %" x 12" | _ | RFB#5x12HDG | _ | _ | 10 |
| %" x 16" | RFB#5x16 | RFB#5x16HDG | 25 | 25 | 10 |
| 3/4" x 10 1/2" | RFB#6x10.5 | RFB#6x10.5HDG | 25 | 25 | _ |

- 1. Bulk quantities do not include the nut and washer and must be ordered with a "-B" suffix (example: RFB#4x5-B). Hot-dip galvanized RFB's not available in bulk.
- 2. Retail Packs must be ordered with a "-R" suffix (example: RFB#5x12HDG-R).

The PAB anchor bolt is a versatile new cast-in-place anchor bolt ideal for high-tension-load applications. It features a plate washer at the embedded end sandwiched between two fixed hex nuts and a head stamp for easy identification after the pour.

- Available in diameters from ½" to 1¼" in lengths from 6" to 36" (in ½" increments)
- · Available in standard and high-strength steel
- · Head stamp contains the No Equal sign, diameter designation and an "HS" on high-strength rods

MATERIAL: Standard Steel – F_{IJ} = 58 ksi

High-Strength Steel (up to 1" dia.) - Fu = 120 ksi

High-Strength Steel (11/8" and 11/4" dia.) – F_U = 125 ksi

FINISH: None

The Simpson Strong-Tie® Anchor Designer Software™ for ACI 318 analyzes and suggests anchor solutions using the ACI 318 Appendix D strength-design methodology (or CAN/CSA A23.3 Annex D Limit States Design methodology). It provides cracked and uncracked-concrete anchorage solutions for numerous



Simpson Strong-Tie Anchor Systems® mechanical and adhesive anchors as well as the PAB anchor bolt. With its easy-to-use graphical user interface, the software makes it easy for the Designer to identify anchorage solutions without having to perform time-consuming calculations by hand.


PAB Anchor Bolt - Standard Steel

| Diameter (in.) | Plate Washer Size (in.) | l ₁ (in.) | Root Model No. | Length Range |
|----------------|-------------------------|----------------------|----------------|--------------|
| 1/2 | 1/4 x 11/4 x 11/4 | 1 | PAB4-XX | |
| 5/8 | % x 1½ x 1½ | 11/4 | PAB5-XX | |
| 3/4 | 3% x 2 x 2 | 1% | PAB6-XX | 6" to 36" |
| 7/8 | 3/8 x 21/4 x 21/4 | 1½ | PAB7-XX | (in ½" |
| 1 | % x 2½ x 2½ | 1% | PAB8-XX | increments) |
| 11//8 | 3/8 x 23/4 x 23/4 | 1¾ | PAB9-XX | |
| 11/4 | ½ x 3 x3 | 2½ | PAB10-XX | |

How to specify and order:

When calling out PAB anchor bolts. substitute the desired length for the "XX" in the Root Model Number. So for a %"x161/2"

anchor bolt, the model number would be PAB5-16.5 (or PAB5H-16.5 for high strength).



PAB Anchor Bolt - High-Strength Steel

| Diameter (in.) | Plate Washer Size (in.) | l ₁ (in.) | Root Model No. | Length Range |
|----------------|-------------------------|----------------------|----------------|--------------|
| 1/2 | 1/4 x 11/4 x 11/4 | 1 | PAB4H-XX | |
| 5/8 | % x 1½ x 1½ | 11/4 | PAB5H-XX | |
| 3/4 | % x 2 x 2 | 1% | PAB6H-XX | 6" to 36" |
| 7/8 | 3/8 x 21/4 x 21/4 | 1½ | PAB7H-XX | (in ½" |
| 1 | 3/8 x 21/2 x 21/2 | 1% | PAB8H-XX | increments) |
| 11/8 | 3/8 x 23/4 x 23/4 | 13/4 | PAB9H-XX | |
| 11/4 | ½ x 3 x 3 | 2½ | PAB10H-XX | |

^{1.} Plate washers are designed to develop the capacity of the bolt.

Naming Scheme:



* Units in 1/8" Increments (Ex: 9 = %" or 11/8")


Strong-Tie

In addition to anchorage solutions provided by the SB and SSTB anchor bolts, the following table provides design options using the new PAB anchor bolts. These solutions may be used with Simpson Strong-Tie holdowns and are calculated per ACI 318 Appendix D. For special loads or footing geometries not addressed in the table below, the new PAB anchor bolts are also included in Simpson Strong-Tie Anchor Systems Anchor Designer ACI 318 software, which is available for download at **www.simpsonanchors.com**.

PAB ANCHOR BOLT ANCHORAGE SOLUTIONS

| Design | Diameter | Anchor Bolt | | 2500 psi | Concrete | | | 3000 psi | Concrete | | |
|----------|----------|-------------|----------------|----------|----------|--------|----------------|----------|----------|--------|--------|
| Criteria | Diameter | Model No. | d _e | F | ASD | LRFD | d _e | F | ASD | LRFD | |
| | 5/8 | PAB5 | 4 | 6 | 4,200 | 6,720 | 4 | 6 | 4,600 | 7,360 | |
| | 78 | FADO | 5 | 7½ | 5,870 | 9,390 | 5 | 7½ | 6,140 | 9,830 | |
| | 3/4 | PAB6 | 5 | 7½ | 5,870 | 9,390 | 5 | 7½ | 6,430 | 10,290 | |
| | | PAB7 | 6 | 9 | 7,720 | 12,350 | 5 | 7½ | 6,430 | 10,290 | |
| | 7∕8 | PAD/ | 8 | 12 | 11,880 | 19,010 | 7 | 10½ | 10,650 | 17,040 | |
| | | PAB7H | 10 | 15 | 16,600 | 26,560 | 10 | 15 | 18,190 | 29,100 | |
| | | PAD/II | 14 | 28 | 25,970 | 41,560 | 13 | 26 | 25,970 | 41,560 | |
| Wind | 1 11/8 | PAB8 | 8 | 12 | 11,880 | 19,010 | 7 | 10½ | 10,650 | 17,040 | |
| | | PADO | 10 | 15 | 16,470 | 26,350 | 9 | 13½ | 15,530 | 24,840 | |
| | | PAB8H | 11 | 16½ | 19,040 | 30,470 | 11 | 16½ | 20,860 | 33,380 | |
| | | | 16 | 24 | 34,070 | 54,520 | 15 | 22½ | 34,070 | 54,520 | |
| | | PAB9 | | 6 | 9 | 7,720 | 12,350 | 6 | 9 | 8,450 | 13,520 |
| | | | 9 | 13½ | 14,180 | 22,680 | 9 | 13½ | 15,530 | 24,840 | |
| | | | 11 | 16½ | 19,040 | 30,470 | 10 | 15 | 18,190 | 29,100 | |
| | 11/4 | PAB10 | 12 | 24 | 22,010 | 35,220 | 11 | 16½ | 20,860 | 33,380 | |
| | 5% | PAB5 | 7 | 10½ | 6,870 | 9,830 | 6 | 9 | 6,870 | 9,830 | |
| | 3/4 | PAB6 | 9 | 13½ | 10,170 | 14,550 | 8 | 12 | 10,170 | 14,550 | |
| | 7/8 | PAB7 | 11 | 16½ | 14,050 | 20,090 | 10 | 15 | 14,050 | 20,090 | |
| Coiomio | 78 | PAB7H | 16 | 24 | 29,060 | 41,560 | 15 | 22½ | 29,060 | 41,560 | |
| Seismic | 1 | PAB8 | 12 | 18 | 18,430 | 26,350 | 12 | 18 | 18,430 | 26,350 | |
| | | PAB8H | 19 | 28½ | 38,120 | 54,520 | 18 | 27 | 38,120 | 54,520 | |
| | 11/8 | PAB9 | 14 | 21 | 23,220 | 33,200 | 13 | 19½ | 23,220 | 33,200 | |
| | 11/4 | PAB10 | 16 | 24 | 29,480 | 42,160 | 16 | 24 | 29,480 | 42,160 | |

- 1. Anchorage designs conform to ACI 318 Appendix D and assume cracked concrete with no supplementary reinforcement.
- Seismic indicates Seismic Design Category C through F. Detached 1 and 2 family dwellings in SDC C may use wind anchorage solutions. Seismic anchorage designs conform to ACI 318-05 Section D3.3.4
- 3. Wind includes Sesmic Design Category A and B.
- Foundation dimensions are for anchorage only. Foundation design (size and reinforcement) by Designer. The registered design professional may specify alternate embedment, footing size, and anchor bolt.
- Allowable Stress Design (ASD) values are obtained by by dividing Load Resistance Factor Design (LRFD) capacities by 1.43 for Seismic and 1.6 for Wind.



C-CFS10 @ 2010 SIMPSON STRONG-TIE COMPANY INC

Anchor with Nut/Washer/Nut

Design loads are calculated using a full shear cone. Coverage on each side of the bolt shall be a minimum of Dimension F (above) or reductions must be taken.

S/HDU Holdowns

The S/HDU series of holdowns combines performance with ease of installation. The pre-deflected geometry virtually eliminates material stretch, resulting in low deflection under load. Installation using self-drilling tapping screws into the studs reduces installation time and saves labor cost.

MATERIAL: 118 mil (10 ga)


FINISH: Galvanized


INSTALLATION: • Use all specified fasteners.

See General Notes.

. Use #14 screws to fasten to studs

CODES: See page 8 for Code Listing Key Chart.





Typical S/HDU Installation

These products are available with additional corrosion protection. Additional products on this page may also be available with this option, check with Simpson Strong-Tie for details.

| | | | Faste | eners | | AS | SD | LR | FD | Nominal | |
|--|-----------|------|------------------------|-------------------|---------------------------------------|--------------|-------------------------------------|-----------------|--------------------------------------|------------------------------|-----------|
| | Model | Н | Fdn Anchor Dia ¹ | Stud Fasteners | Stud Member Thickness ⁴ | Tension Load | Deflection at ASD Load ⁷ | Tension Load | Deflection at LRFD Load ⁷ | Tension Load ⁸ | Code Ref. |
| | | | | | 2-33 (2-20ga) | 2320 | 0.093 | 3705 | 0.149 | 5685 | |
| | S/HDU4 | 71/8 | 5/8 | 6-#14 | 2-43 (2-18ga) | 3825 | 0.115 | 6105 | 0.190 | 9365 | |
| | 3/11/04 | 1 78 | 78 | 0-#14 | 2-54 (2-16ga) | 3970 | 0.093 | 6345 | 0.156 | 9730 | |
| | | | | | Steel Fixture | 4470 | 0.063 | 7165 | 0.103 | 12120 | |
| | | | | | 2-33 (2-20ga) | 4895 | 0.125 | 8495 | 0.250 | 10470 | |
| | S/HDU6 | 10% | 5/8 | 12-#14 | 2-43 (2-18ga) | 6125 | 0.119 | 9690 | 0.250 | 15460 | |
| | 3/11000 | 10% | 78 | 12-#14 | 2-54 (2-16ga) | 6125 | 0.108 | 9785 | 0.234 | 15005 | |
| | | | | | Steel Fixture | 5995 | 0.060 | 9580 | 0.136 | 14695 | |
| | | | | | 2-33 (2-20ga) | 6965 | 0.103 | 11125 | 0.189 | 13165 | FC1 |
| | S/HDU9 | 12% | 7/8 | 18-#14 | 2-43 (2-18ga) | 9255 | 0.125 | 15485 | 0.250 | 21810 | |
| | 3/HDU9 | 1278 | 78 | 10-#14 | 2-54 (2-16ga) | 9990 | 0.106 | 15960 | 0.225 | 24480 | |
| | | | | | Steel Fixture | 12715 | 0.125 | 20510 | 0.177 | 31455 | |
| | | | | | 2-33 (2-20ga) | 6965 | 0.103 | 11125 | 0.189 | 13165 | |
| | | | 7/8 | 27-#14 | 2-43 (2-18ga) | 9595 | 0.096 | 15330 | 0.162 | 23515 | |
| | S/HDU11 | 16% | | | 2-54 (2-16ga) | 9675 | 0.110 | 15460 | 0.158 | 23710 | |
| | 3/11/01/1 | 1078 | 7/8 | | 2-43 (2-18ga)6 | 11100 | 0.125 | 17500 | 0.250 | 24955 | |
| | | | w/ heavy | 27-#14 | 2-54 (2-16ga)6 | 12175 | 0.125 | 19445 | 0.243 | 29825 | |
| | | | hex nut | | Steel Fixture ⁶ | 12945 | 0.111 | 20680 | 0.163 | 31715 | |

- 1. Designer shall specify the foundation anchor material type, length, embedment and configuration. Tabulated loads may exceed anchor bolt ASTM A36 or A307 tension capacities.
- 2. See pages 26-30 for anchor bolt options.
- See page 21 for anchor bolt retrofit options.
- Stud design by Specifier. Tabulated loads are based on a minimum studs thickness for fastener connection.
- 5. 1/4" self-drilling tapping screws can be substituted for #14.

- 6. Heavy hex nut is required to achieve the table loads for S/HDU11.
- 7. Deflection at ASD and LRFD Loads includes fastener slip, holdown elongation and anchor bolt elongation (L=4").
- Nominal Tension Load is based on the average ultimate (peak) load from tests. AISI Lateral Design standard requires holdown to have nominal strength to resist lesser of amplified seismic load or the maximum force the system can deliver.

The HTT and S/HTT is a single-piece formed tension tie—no rivets, and a 4-ply formed seat. No washers are required.

The S/LTT, S/HTT and HTT Tension Ties are ideal for retrofit or new construction projects. They provide high-strength, post-pour, concrete-to-steel connections.


MATERIAL: S/HTT14, HTT4, HTT5 111 mil (11 ga) S/LTT20B - Strap: 97 mil (12 ga) Plate: 229 mil (3 ga)

FINISH: Galvanized


INSTALLATION: • Use all specified fasteners.


- Use the specified number and type of screws to attach the strap portion to the steel stud. Bolt the base to the wall or foundation with a suitable anchor; see table for the required bolt diameter.
- Do not install S/LTT20 raised off of the bottom track.


CODE: See page 8 for Code Listing Key Chart.



Typical HTT5 Installation as a Holdown







Available with additional corrosion protection. Check with Simpson Strong-Tie.

| | | Dimensions | | Fasteners | | Stud | A | SD | LR | RFD | Nominal | | |
|-------|---------|-------------|------|-----------|------------------------------|-------------------|---------------------------------|-----------------|---|-----------------|--|------------------------------|--------------|
| Model | | W | Н | CL | Found. Anchor Diameter | Stud Fasteners | Member Thickness mil (ga) | Tension Load | Deflection at ASD Load ⁵ | Tension Load | Deflection at LRFD Load ⁵ | Tension Load ⁶ | Code Ref. |
| | S/LTT20 | 2 | 20 | 1½ | 1/2 | 8 - #10 | 33 (20ga) | 1200 | 0.125 | 1890 | 0.250 | 4625 | ILC1, |
| | S/HTT14 | 2½ | 16 | 1% | 5/8 | 16 - #10 | 33 (20ga) | 2775 | 0.108 | 4430 | 0.172 | 6800 | LC1, |
| | 3/H1114 | 2 72 | 10 | 178 | 78 | 10 - #10 | 2-33 (2-20ga) | 3850 | 0.125 | 6700 | 0.250 | 11590 | FC1 |
| | HTT4 | 2½ | 12% | 1% | 5/8 | 18 - #10 | 33 (20ga) | 3180 | 0.104 | 4770 | 0.187 | 8215 | |
| | ппч | Z72 | 1278 | 178 | 78 | 10 - #10 | 2-33 (2-20ga) | 4395 | 0.125 | 6675 | 0.250 | 11835 | |
| | | | | | | | 43 (18ga) | 4240 | 0.125 | 6505 | 0.250 | 11585 | 160 |
| HTT: | HTT5 | 2½ | 16 | 1% | 5/8 | 26 - #10 | 2-43 (2-18ga) | 4670 | 0.125 | 6970 | 0.250 | 12195 | |
| | | | | | | | 1-54 (1-16ga) | 4150 | 0.125 | 6425 | 0.250 | 12365 | |



- See pages 26-30 for anchor bolt options.
- 3. See page 21 for anchor bolt retrofit options.
- Stud design by Specifier. Tabulated loads are based on a minimum stud thickness for fastener connection.
- Deflection at ASD and LRFD Loads is the deflection of the holdown measured between the anchor bolt and strap portion of the holdown when loaded to the ASD and LRFD load, respectively. This movement is strictly due to the holdown deformation under a static load test attached to members listed in the table.
- 6. Nominal Tension Load is based on the average ultimate (peak) load from tests. AISI Lateral Design standard requires holdown to have nominal strength to resist lesser of amplified seismic load or the maximum force the system can deliver.

S/HDS & S/HDB Holdowns



S/HD15S

(S/HD8S and

S/HD10S similar)

11/8" S/HD15S 21/8" S/HD10S

21/4" S/HD8S

The S/HD series of holdowns is designed for installation with either screws or bolts into the studs or column. The S/HDS series installs with #14 screws and has been designed to utilize fewer fasteners to reduce installation time. The S/HDB series is ideal for bolt-on applications where the cold-formed stud manufacturer can pre-punch the bolt holes.

MATERIAL: See table


FINISH: Simpson Strong-Tie gray paint. Hot-dip galvanized is available; see Corrosion-Information, page 12–13.

INSTALLATION: • Use all specified fasteners; some models have extra fastener holes. See General Notes.

- · Anchor bolt washer is not required.
- Standard washers are required on stud bolt nuts for model S/HDB.
- Thin wall socket (OD=2" maximum) is required for S/HD15 to tighten the 1" anchor bolt.
- Stud bolts use A307.
- Boundary members (back-to-back studs) design shall be by Designer.

• S/HDS and S/HDB holdowns can be welded per Designer's recommendation and specification. To tie back-to-back stud members together, the Designer must determine the fasteners required to bind members to act as one unit. Welders and welding procedures shall be qualified as specified in AWS D1.3. Welded connections used for cold-formed steel structural members in which the thickness of the thinnest connected part is 0.18 inch or less shall comply to 2001 AISI NAS Specification Section E2.

CODE: See page 8 for Code Listing Key Chart.



2-#14 screws

required only for slotted studs. Slotted stud

design by Designer.

Not a bolt hole

61/4

0

0

S/HD15B

23⁄4" (Typical)

Available with additional corrosion protection. Check with Simpson Strong-Tie.

| | | Faste | eners | Stud | AS | SD | LR | FD | | | | | | | | | | | | |
|---------|------|---|-------------------|---|---------------|--|--------------|---|--------------------------------------|-----------|---------------|-----------|-----------|-----------|---------------|-------|-------|-------|-------|-------|
| Model | Н | Found. Anchor Diameter ¹ | Stud Fasteners | Member Thickness mil (ga) ⁴ | Tension Load | Deflection at ASD Load ⁶ | Tension Load | Deflection at LRFD Load ⁶ | Nominal Tension Load ⁷ | Code Ref | | | | | | | | | | |
| | | | | 2-33 (2-20ga) | 7335 | 0.120 | 11715 | 0.204 | 13720 | | | | | | | | | | | |
| S/HD8S | 11 | 7/8 | 17 - #14 | 2-43 (2-18ga) | 8750 | 0.086 | 13975 | 0.146 | 21435 | | | | | | | | | | | |
| 9/UD09 | 11 | 78 | | 2-54 (2-16ga) | 8855 | 0.106 | 14145 | 0.162 | 21700 | | | | | | | | | | | |
| | | | | Steel Fixture | 10840 | 0.053 | 17335 | 0.072 | 32525 | | | | | | | | | | | |
| | | | | 2-33 (2-20ga) | 7400 | 0.122 | 11815 | 0.192 | 13835 | | | | | | | | | | | |
| C/UD40C | 101/ | 7/8 | 00 #44 | 2-43 (2-18ga) | 11120 | 0.112 | 17755 | 0.124 | 20795 | | | | | | | | | | | |
| S/HD10S | 13½ | | 22 - #14 | 22 - #14 | 2-54 (2-16ga) | 12220 | 0.096 | 19520 | 0.145 | 29940 | | | | | | | | | | |
| | | | | Steel Fixture | 12375 | 0.043 | 19820 | 0.061 | 33535 | | | | | | | | | | | |
| | | | | 2-43 (2-18ga) | 12110 | 0.096 | 19340 | 0.164 | 22645 | | | | | | | | | | | |
| S/HD15S | 17 | 1 | 30 - #14 | 2-54 (2-16ga) | 13500 | 0.110 | 21565 | 0.130 | 33075 | | | | | | | | | | | |
| | | | | Steel Fixture | 15810 | 0.043 | 25320 | 0.065 | 42845 | FC1 | | | | | | | | | | |
| | | | | 2 - ¾ Dia | 2 3/ Dia | 0 3/ Dia | 0 3/ Dia | 0 3/ Dia | | | 2-33 (2-20ga) | 3895 | 0.081 | 5620 | 0.144 | 8645 | FG I | | | |
| S/HD8B | 11 | 7/8 | | | | | | | 2-43 (2-18ga) | 5345 | 0.098 | 7710 | 0.146 | 11865 | | | | | | |
| סטחויס | 11 | 78 | 2 - % Dia | 2-54 (2-16ga) | 8950 | 0.082 | 14280 | 0.141 | 20310 | | | | | | | | | | | |
| | | | | Steel Fixture | 9080 | 0.069 | 14545 | 0.104 | 22975 | | | | | | | | | | | |
| | | | | 2-33 (2-20ga) | 5840 | 0.070 | 8430 | 0.124 | 12970 | | | | | | | | | | | |
| C/UD40D | 101/ | 7/8 | 3 - ¾ Dia | 2-43 (2-18ga) | 8015 | 0.087 | 11565 | 0.120 | 17795 | | | | | | | | | | | |
| S/HD10B | 13½ | 78 | | 3 - ¾ Dia | 3 - ¾ Dia | 3 - ¾ Dia | 3 - ¾ Dia | 3 - ¾ Dia | 3 - ¾ Dia | 3 - ¾ Dia | 3 - ¾ Dia | 3 - ¾ Dia | 3 - ¾ Dia | 3 - ¾ Dia | 2-54 (2-16ga) | 12090 | 0.125 | 19720 | 0.230 | 28050 |
| | | | | Steel Fixture | 15635 | 0.102 | 24955 | 0.123 | 35495 | | | | | | | | | | | |
| | | | 4 - ¾ Dia | | | | | 2-43 (2-18ga) | 10690 | 0.118 | 15425 | 0.179 | 22165 | | | | | | | |
| S/HD15B | 17 | 1 | | 2-54 (2-16ga) | 16020 | 0.090 | 25565 | 0.121 | 36360 | | | | | | | | | | | |
| | | | | Steel Fixture | 18690 | 0.104 | 29825 | 0.139 | 42425 | | | | | | | | | | | |

- Designer shall specify the foundation anchor material type, length, embedment and configuration. Tabulated loads may exceed anchor bolt ASTM A36 or A307 tension capacities.
- 2. See pages 26-30 for anchor bolt options.
- 3. See page 21 for anchor bolt retrofit options.
- Stud design by Specifier. Tabulated loads are based on a minimum studs thickness for fastener connection.
- 5. 1/4" self-drilling screws can be substituted for #14.
- Deflection at ASD and LRFD Loads includes fastener slip, holdown elongation and anchor bolt elongation (L=4").
- Nominal Tension Load is based on the average ultimate (peak) load from tests. AISI Lateral Design standard requires holdown to have nominal strength to resist lesser of amplified seismic load or what the system can deliver.

STHD Strap Tie Holdown



The STHD is an embedded strap tie holdown with high load capacity and designed to reduce spalling.

FEATURES: • A slot below the embedment line allows for increased front to back concrete bond and reduced spalling.

Rim joist models accommodate up to a 17" clear span without any loss of strap fastening. Diamond holes for optional attachment to rim joist.

FINISH: Galvanized MATERIAL: 68 mil (12 ga)

INSTALLATION: • Use all specified fasteners. See General Notes.

- Install before concrete pour with a StrapMate, or other holding device.
- Screw strap from the bottom up. Strap may be bent one full cycle.
- Bending the strap 90° to aid wall placement may cause spalling behind the strap. If the spall is 1" or less, measured from the embedment line to the bottom of the spall, full loads apply. For spalls between 1" and 4" (see illustration), the allowable load is 0.90 of the table loads. Any portion of the strap left exposed should be protected against corrosion.
- · Where fewer fasteners are used in the structural member, reduce loads according to the code.
- Unless otherwise noted, do NOT install where: (a) a horizontal cold joint exists within the embedment depth between the slab and foundation wall or footing beneath, unless provisions are made to transfer the load, or the slab is designed to resist the load imposed by the anchor; or (b) slabs are poured over concrete block foundation walls.
- To get the full table load, the minimum center-to-center spacing is twice the embedment depth when resisting tension loads at the same time.
- There may be an increase in the amount of deflection if the strap is installed on the outside of the shear panel versus under the shear panel directly to the framing.

FOUNDATION CORNERS: Screw quantities may be reduced for less than le corner distance design loads—use the code allowable loads for fasteners in shear.

- To tie multiple stud members together, the Designer must determine the fasteners required to bind members to act as one unit.
- · Additional studs attached to the shearwall studs or post may be required by the Designer for wall sheathing fastener.

STHD STRAP TIE HOLDOWNS Built-in tab StrapMate® Additional diamond hole in RJ versions **BENEFITS** Built-in Tab: · Reduces spalling and costly retrofits StrapMate® No additional labor to install 6,658,806 Hold STHD away from form board StrapMate Locator Line: Easy inspection to ensure proper location · Allows adjustment without Built-in removing STHD Additional Diamond Hole: · One more fastener to help prevent the STHD RJ models from bowing out at the rim joist section

Typical


STHD14RJ

Rim Joist

Application


NEW FEATURES ON THE

STHD



| Model No. | Min | Strap I | ength (L) | | | | A | llowable | ASD Te | nsion Lo | ads 33 n | nil (20 g | a) | | |
|----------------------|-------|---------|-----------|-----|--------|------|---------|----------|--------|----------|----------|-----------|---------|-------|-------|
| Standard / | Stem | Std | Rim Joist | le | Screws | | | | En | d Distan | ce | | | | Code |
| Rim Joist | Wall | Model | Model | 9'' | OUICWS | 1/2" | 11/2" | le | 1/2" | 11/2" | le | 1/2" | 11/2" | le | Ref |
| Tilli Juist | Width | Model | Model | | | 2000 | psi Con | crete | 2500 | psi Con | crete | 3000 | psi Con | crete | |
| STHD8 / STHD8RJ | 6 | 21% | 351/8 | 8 | 18-#10 | 1760 | 2050 | 2345 | 1950 | 2210 | 2345 | 2135 | 2425 | 2425 | |
| STHD10 / STHD10RJ | 6 | 231/8 | 365⁄8 | 10 | 22-#10 | 2035 | 2575 | 3295 | 3730 | 3730 | 3730 | 3730 | 3730 | 3730 | |
| STHD14 / STHD14RJ | 6 | 31% | 39% | 14 | 30-#10 | 3235 | 4220 | 4805 | 5025 | 5025 | 5025 | 5025 | 5025 | 5025 | ILC1, |
| STHD8 / STHD8RJ | 8 | 21% | 351/8 | 8 | 18-#10 | 2170 | 2170 | 3180 | 2370 | 2370 | 3180 | 2370 | 2370 | 3180 | FC1 |
| STHD10 / STHD10RJ | 8 | 231//8 | 36% | 10 | 22-#10 | 2745 | 2745 | 3725 | 3730 | 3730 | 3730 | 3730 | 3730 | 3730 | |
| STHD14 / STHD14RJ | 8 | 31% | 39% | 14 | 34-#10 | 3885 | 4430 | 5785 | 5025 | 5025 | 5785 | 5025 | 5025 | 5785 | |


- 1. 'RJ' after the model indicates STHDs for rim joist applications, e.g. STHD8RJ.
- 2. For two pour with 4" slab or less. The STHD14 load at ½" edge 2000 psi is 3235 lbs. The STHD10 at the same condition is 2035 lbs.
- 3. Not all fastener holes need to be filled as additional fastener holes provided. Install fasteners symmetrically.
- Table loads apply to end installation applications provided there is a minimum end distance of le




Typical STHD End Installation (see footnote 6)

STHD Strap Tie Holdown






Single Pour Rebar Installation *Maintain minimum rebar cover, per ACI-318 concrete code requirements.




Two Pour Rebar Installation

*Maintain minimum rebar cover, per ACI-318 concrete code requirements.


POST-TENSION INFORMATION



DETAIL 1 When installed on a raised curb, use stemwall installation and loads (see pages 29-31) (rebar required)



DETAIL 2 Post-Tension Cable Placement Corner Installation (no rebar required)



Top View of Post-Tension Cable Placement

| Model | Distance | | Fasteners | Allowable ASD | Code | |
|-----------|----------------|----------------------|--|---------------|-------------------|------|
| No. | from Corner | 33 mil (20 ga) | 33 mil (20 ga) 43 mil (18 ga) 54 mil (16 ga) | | Tension Loads | Ref. |
| C/UDAUDOO | ½" Min | 16- #10 | 11- #10 | 6- #10 | 2705 | |
| S/HPAHD22 | 8" Min | 25- #10 ⁵ | 23- #10 | 23- #10 | 4740 ⁵ | |
| STHD8/ | 1⁄2" Min | 12- #10 | 8- #10 | 4- #10 | 2055 | 170 |
| STHD8RJ | 8" Min | 16- #10 | 11- #10 | 6- #10 | 2780 | 170 |
| STHD10/ | ½" Min | 12- #10 | 8- #10 | 4- #10 | 2055 | |
| STHD10RJ | 10" Min | 19- #10 | 13- #10 | 7- #10 | 3240 | |

- 1. Minimum concrete strength is 2500 psi.
- 2. Post-tension steel is minimum 1/2" diameter, 7-wire, lowrelaxation strand in accordance with ASTM A416, Grade 270 ksi, with a guaranteed ultimate strength of 41.3 k.
- 3. Anchorage is monostrand-type anchor system with current ICC approval using a ductile iron casting of at least 2.25" x 4.5" of bearing and reusable pocket formers on all stressing ends.
- It is the designer's responsibility to provide reinforcement to tie cold-joints and to resist bending stresses in the foundation due to anchor uplift.
- 5. For S/HPAHD attaching to 33 mil (20 ga) CFS, the allowable load is 4420 lbs.

S/PAHD & S/HPAHD Strap Tie Holdowns

A variety of steel-to-concrete connectors that satisfy engineering and code requirements. Allowable loads include a tested three-times safety factor in concrete with a one-piece design and no separate anchors required.

MATERIAL: S/HPAHD, HPAHD—118mil (10 ga) x 21/16"; S/PAHD—97 mil (12 ga) x 21/16". FINISH: Galvanized; see Corrosion Information, page 12–13.


INSTALLATION: • Use all specified fasteners.

- · Unless otherwise noted, do NOT install where: (a) a horizontal cold joint exists within the embedment depth between the slab and foundation wall or footing beneath, unless provisions are made to transfer the load, or the slab is designed to resist the load imposed by the anchor; or (b) slabs are poured over concrete block foundation walls.
- To get the full table load, the minimum center-to-center spacing is twice the embedment depth when resisting tension loads at the same time.
- FOUNDATION CORNERS: Screw quantities have been reduced when the load is limited by tested concrete pullout strength. Additional screw holes need not


FEATURES: Designed to be installed at the edge of concrete. Tests determined the pullout strength with one horizontal #4 rebar in the shear cone. Install before concrete pour with a StrapMate®, or other holding device. Pre-bent to control the embedment at the required angle; field-bending is not necessary. Installation holes allow nailing to the form, resulting in 1" deeper embedment; see illustration.

OPTIONS: See also S/HD Holdowns, S/LTT, S/HTT and HTT Tension Ties.


CODE: See page 8 for Code Listing Key Chart.




| Model No. | Minimum Stemwall Width | Embed. Depth l _e | Screws | ASD Tension Loads 33 mil (20 ga) | Model No. | Minimum Stemwall Width | Embed. Depth le | Screws | ASD Tension Loads 33 mil (20 ga) | Code Ref. |
|---|------------------------------|-----------------------------------|------------|---|---------------|------------------------------|-----------------------|-------------|---|--------------|
| Edg | e Installatio | n – 2500 p | si Concre | ete | Corr | er Installati | on – 2500 | psi Concr | ete | |
| Single Pour – see installation 1 (8" min from corner) | | | | | Single Pou | ır – see insta | llation 2 (1 | ⁄2" min fro | m corner) | |
| S/PAHD42 | 6 | 61/2" | 10- #10 | 1765 | S/PAHD42 | 6 | 61/2" | 4- #10 | 1225 | |
| 3/FAND42 | 8 | 072 | 13- #10 | 2300 | 3/FAND42 | 8 | 072 | 5- #10 | 1400 | ILC1, |
| S/HPAHD22 | 6 | 10" | 20- #10 | 3335 | S/HPAHD22 | 6 | 10" | 10- #10 | 1750 | |
| O/III AIIDZZ | 8 | 10 | 26-#10 | 4595 | O/TII ATIDZZ | 8 | 10 | 12- #10 | 2120 | |
| Double Pou | ır – see insta | Illation 3 (| 3" min fro | m corner) | Double Pou | ır – see insta | Illation 4 (1 | ⁄2" min fro | m corner) | FC1 |
| S/PAHD42 | 6 | 61/2" | 10-#10 | 1765 | S/PAHD42 | 6 | 61/2" | 4- #10 | 1225 | 101 |
| 5/PAND42 | 8 | 0 1/2 | 13-#10 | 2300 | 5/PAND42 | 8 | 0 1/2 | 5- #10 | 1400 | |
| S/HPAHD22 | 6 | 10" | 20- #10 | 3335 | S/HPAHD22 | 6 | 10" | 10- #10 | 1750 | |
| O/III AIIDZZ | 8 | 10 | 26-#10 | 4595 | 5/NPAND22 | 8 | 10 | 12-#10 | 2120 | |
| HPAHD22-2P | 6 | 147/16" | 20- #10 | 3335 | HPAHD22-2P | 6 | 147/16" | 10- #10 | 1750 | |
| TIF ATIDZZ-ZF | 8 | 17/10 | 26- #10 | 4595 | TIF MITUZZ-ZF | 8 | 17/10 | 12-#10 | 2120 | |




- 2. Calculate the loads using straight line interpolation for corner distances between ½" and 8".
- Loads are based on CFS members having a minimum thickness of 33 mil (20 ga).
- Not all fastener holes need to be filled as additional fastener holes provided. Install fasteners symmetrically.
- Strap may be bent one full cycle. (Bent horizontal 90° then bent vertical.) Bending the strap to aid wall placement may cause spalling behind the strap. Any portion of the strap exposed should be protected against corrosive conditions with industry standard practices.





INSTALLATION 1 Typical S/HPAHD Single-Pour Edge Installation

INSTALLATION 2 Typical S/HPAHD Single-**Pour Corner Installation**



Double-Pour Edge Installation.

Unless otherwise noted, all others must be installed with the bend embedment line at the cold joint between the slab and the foundation.

INSTALLATION 4 Typical S/HPAHD Double-**Pour Corner Installation**

PA/HPA Strap Tie Holdowns



Α

Cold-formed steel-to-concrete and concrete-block connectors that satisfy code requirements.

The PA's dual embedment line allows installation in concrete or concrete block.

MATERIAL: See table

FINISH: Galvanized. PA's available hot-dip galvanized (HDG) or ZMAX®. See Corrosion Information page 12-13.

INSTALLATION: • Minimum concrete strength is 2000 psi.

- Use all specified fasteners; some models have extra fastener holes. See General Notes.
- · Purlin Anchor must hook around rebar.

EDGE DISTANCE—Minimum concrete edge distance is 5".

Minimum concrete block left-to-right edge distance is 20".

CONCRETE BLOCK WALL—The masonry embedment line on the PA allows for 4" of grout embedment in a standard 8" concrete masonry unit. The minimum wall specifications are (see drawing at right):


- A One #4 vertical rebar, 32" long, 16" each side of anchor;
- **B** Two courses of grout filled block above and below the anchor (no cold joints allowed);
- A horizontal bond beam with two #4 rebars, 40" long, a maximum of two courses above or below the anchor.

All cells grouted with 2000 psi 3/8" aggregate grout. Grout shall be vibrated per the code. Rebar quantities, sizes and lengths are minimum requirements and may be increased per any additional wall design requirements.


OPTIONS: See S/LTT. S/HTT and HTT Tension Ties. CODES: See page 8 for Code Listing Key Chart.

The IBC 1620.2.1 states:

. . . Diaphragm to wall anchorage using embedded straps shall have the straps attached to or hooked around the reinforcing steel, or otherwise terminated to effectively transfer forces to the reinforcing steel.



HANGER NOT SHOWN FOR CLARITY



Available with additional corrosion protection. Check with Simpson Strong-Tie.

| Model | Connector Material | | w | Rafter/S | Fasteners tud/Joist T | | Allowa | ble ASD Tension | n Loads | Code |
|-------|-----------------------|-------|--------|-------------------|--------------------------|-------------------|----------------|-----------------|----------------|------|
| No. | Thick. mil (ga) | L | w | 33 mil (20 ga) | 43 mil (18 ga) | 54 mil (16 ga) | 33 mil (20 ga) | 43 mil (18 ga) | 54 mil (16 ga) | Rof |
| PA18 | | 181/2 | | 16- #10 | 16- #10 | 8- #10 | 2830 | 3685 | 3685 | |
| PA23 | 97 | 23¾ | 21/16 | 22- #10 | 16- #10 | 8- #10 | 3685 | 3685 | 3685 | |
| PA28 | (12 ga) | 321/2 | 2716 | 22- #10 | 16- #10 | 8- #10 | 3685 | 3685 | 3685 | FC1 |
| PA35 | | 35 | | 22- #10 | 16- #10 | 8- #10 | 3685 | 3685 | 3685 | 101 |
| HPA28 | 118 | 211/2 | 21/16 | 28- #10 | 20- #10 | 10- #10 | 4845 | 4845 | 4845 | |
| HPA35 | (10 ga) | 381/2 | ∠ 1/16 | 32- #10 | 22- #10 | 12- #10 | 5420 | 5420 | 5420 | |

MASONRY

| | Model | Connector Material | | | | Fasteners tud/Joist T | | Allowa | ble ASD Tension | ı Loads | Code |
|---|-------|-----------------------|-------|-------|-------------------|--------------------------|-------------------|----------------|-----------------|----------------|------|
| | No. | Thick. mil (ga) | L | W | 33 mil (20 ga) | 43 mil (18 ga) | 54 mil (16 ga) | 33 mil (20 ga) | 43 mil (18 ga) | 54 mil (16 ga) | Ref. |
| | PA18 | | 181/2 | | 16- #10 | 12- #10 | 6- #10 | 2815 | 2815 | 2815 | |
| | PA23 | 97 | 23¾ | 01/ | 16- #10 | 12- #10 | 6- #10 | 2815 | 2815 | 2815 | FC1 |
| • | PA28 | (12 ga) | 321/2 | 21/16 | 16- #10 | 12- #10 | 6- #10 | 2815 | 2815 | 2815 | 101 |
| • | PA35 | | 35 | | 16- #10 | 12- #10 | 6- #10 | 2815 | 2815 | 2815 | |

- 1. Allowable loads are for a horizontal installation into the side of a concrete or masonry wall.
- Install a minimum of 4 of the required fasteners between the embedment line and the first tooling hole.
- Not all fastener holes need to be filled as additional fastener holes provided. Install fasteners symmetrically.

ICFVL Ledger Connector System

The ICFVL Ledger Connector System is engineered to solve the challenges of mounting CFS ledgers to insulated concrete form (ICF) walls. The ICFVL is designed to provide both vertical and lateral, in-plane performance. There are many benefits over traditional anchor bolting, including better on center spacing in most cases, faster installation and no protrusions.

The embedded legs of the ICFVL are embossed for additional stiffness and the hole allows for concrete to flow through and around the connector. The exposed flange on the face of the ICF provides a structural surface for mounting a CFS ledger.

MATERIAL: ICFVL—68 mil (14 ga)

FINISH: Galvanized

INSTALLATION: ICFVL in ICF

- Snap a chalk line for the bottom of the ledger.
- · Mark required on-center spacing.
- · Use ICFVL to mark kerfs locations.
- · Cut kerfs as marked.
- . Insert ICFVL flush to the face of the ICF.
- Pour concrete.


CFS Ledger Attachment

- · Position the ledger level to the chalk line and against the ICFVL.
- Attach with four #14x3/4", #3 drill point screws (not provided).
- All screws should be located at least ½" from the edge of the ICFVL.
- · Space screws evenly.

CODES: See page 8 for Code Listing Key Chart.

WARNING:

Industry studies show that hardened fasteners can experience performance problems in wet environments. Accordingly, use this product in dry environments only.



Patent Pending


| Model No. | Fasteners | 54 mil | SD Loads (lbs) (16 ga) (14 ga) | |
|--------------|------------|----------|--|--|
| | | Download | Lateral F ₁ | |
| ICFVL | 4-#14x3⁄43 | 1660 | 1525 | |


- Fasteners for CFS ledger are not provided.
 Loads apply to ICF foam thicknesses of 2¾" or less. Contact Simpson Strong-Tie for allowable loads on thicker walls. Alternately, ½"x¾" fastener may be used.
- Concrete f'c = 2500 psi minimum.
- When combining download and lateral loads, Designer shall evaluate as follows: Design Download/Allowable Download + Design Lateral Load/Allowable Lateral Load ≤ 1.

These tables address vertical load applications only.

| | | | - | | | | | | | | | | |
|------------------------------|----------------|------|-----------|-------------|------------|-------------|------------|--------------------------|------|--------------|--|--|--|
| Ledger Material Thickness | | | ICFVL Sp | acing to Re | place Anch | or Bolts on | a CFS Ledg | er (in) ^{1,2,3} | | | | | |
| | Connector Type | | ½" Dia. A | nchors at | | | %" Dia. A | nchors at | | Code Ref. | | | |
| mil (ga) | Connector Type | 12" | 24" | 36" | 48" | 12" | 24" | 36" | 48" | | | | |
| (94) | | 0.C. | 0.C. | 0.C. | 0.C. | 0.C. | 0.C. | 0.C. | 0.C. | | | | |
| 68 (14 ga) | ICFVL | 11 | 22 | 33 | 44 | 9 | 18 | 27 | 36 | 170 | | | |
| 54 (16 ga) | ICFVL | 15 | 30 | 45 | 48 | 12 | 24 | 36 | 48 | 170 | | | |

- 1. The Designer may specify different spacing based on the load requirements.
- 2. See flier F-ICFVL for additional connection details.
- 3. CFS ledger values are based on steel Fu = 65 ksi.





Installation with ICFVL (minimum 54 mil)

STRONG FRAME™ Ordinary Moment Frame







The Strong Frame Ordinary Moment Frame Catalog

All of the information you need on our latest lateral force-resisting solution is contained in the *Strong Frame Ordinary Moment Frame* catalog. Frame and anchorage design information, installation instructions, prescriptive wall bracing requirements and installation details are all included in this useful tool. Visit *www.strongtie.com* to download or request a copy or call (800) 999-5099.

For years moment frames have been a common method of providing high lateral-force resistance when limited wall space and large openings control the structural design. Traditionally, the disadvantage with moment frames has been that they are time-intensive to design and labor-intensive to install. Simpson Strong-Tie has taken these factors into consideration and has created a cost-effective alternative to traditional frames – the Strong Frame ordinary moment frame. For CFS applications, the Strong Frame ordinary moment frame is available without the pre-installed wood nailers





FEATURES:

- Pre-designed moment frame solutions: Designers can choose from 196 engineered frames, in sizes up to 16 feet wide and 19 feet tall, rather than having to spend hours designing one.
- 100% bolted connections: Install frames faster with no field welding required. No need to have a welder on site, or a welding inspector.
- Frames fit in a standard 2x6 wall: No thicker walls additional framing or furring required.
- Greater quality control: Frames are manufactured in a quality-controlled environment and field-bolted connections eliminate questions about field welds.
- Convenient to store, ship and handle: Disassembled frames are more compact, minimizing deliveries and simplifying handling on the jobsite.
- Pre-assembled anchor-bolt assemblies: Anchor bolts are pre-assembled on a shear-lug
 plate that mounts on the form. This helps ensures correct anchor placement and creates
 more efficient anchor performance.
- Streamlined anchorage design: No more tedious anchorage calculations select an
 anchorage solution for your footing geometry from the anchorage tables and you are done.
- Post-installed anchorage solutions available for prescriptive applications: Simpson Strong-Tie® epoxy anchor solutions for higher load applications and solutions with the Simpson Strong-Tie Titen HD® screw anchor for prescriptive or lower-load applications.



Strong Frame OMFSL anchorage assemblies make design and installation faster and easier

The Steel Strong-Wall® provides high-capacity, narrow wall solutions for cold-formed steel framing. The wall installs easily in cold-formed steel framing, and pre-attached steel studs allow easy attachment of interior and exterior finishes.

MATERIAL: Vertical Panel—118 mil (10 ga)

FINISH: Vertical Panel—Galvanized Top and Base Plates—Simpson Strong-Tie gray paint (cold galvanizing available, contact Simpson Strong-Tie)

NOTES:

- For top-of-wall attachment, use 1/4" or #14 self-drilling screws (not provided) extended through the connection with 3 exposed threads minimum. Fill all screw holes.
- · Maximum height H is the maximum height allowed for the allowable shear loads.


CODES: ICC-ES ESR-1679; City of L.A. RR 25625; State of Florida FL5113

STEEL STRONG-WALL FOR COLD-FORMED STEEL PRODUCT DATA


| Model No. | W Max. | | Ţ | | hor Its | Number of Screws | |
|-------------|--------|------|------|------|------------|---------------------|--|
| | (in) | (in) | (in) | Qty. | Dia. | in Top of Wall | |
| S/SSW12x7 | 12 | 80 | 3½ | 2 | 3/4" | 4 | |
| S/SSW15x7 | 15 | 80 | 3½ | 2 | 1" | 6 | |
| S/SSW18x7 | 18 | 80 | 3½ | 2 | 1" | 9 | |
| S/SSW21x7 | 21 | 80 | 3½ | 2 | 1" | 12 | |
| S/SSW24x7 | 24 | 80 | 3½ | 2 | 1" | 14 | |
| S/SSW12x8X | 12 | 97 | 3½ | 2 | 3/4" | 4 | |
| S/SSW15x8X | 15 | 97 | 3½ | 2 | 1" | 6 | |
| S/SSW18x8X | 18 | 97 | 3½ | 2 | 1" | 9 | |
| S/SSW21x8X | 21 | 97 | 3½ | 2 | 1" | 12 | |
| S/SSW24x8X | 24 | 97 | 3½ | 2 | 1" | 14 | |
| S/SSW12x9X | 12 | 109 | 3½ | 2 | 3/4" | 4 | |
| S/SSW15x9X | 15 | 109 | 3½ | 2 | 1" | 6 | |
| S/SSW18x9X | 18 | 109 | 3½ | 2 | 1" | 9 | |
| S/SSW21x9X | 21 | 109 | 3½ | 2 | 1" | 12 | |
| S/SSW24x9X | 24 | 109 | 3½ | 2 | 1" | 14 | |
| S/SSW15x10X | 15 | 121 | 3½ | 2 | 1" | 6 | |
| S/SSW18x10X | 18 | 121 | 3½ | 2 | 1" | 9 | |
| S/SSW21x10X | 21 | 121 | 3½ | 2 | 1" | 12 | |
| S/SSW24x10X | 24 | 121 | 3½ | 2 | 1" | 14 | |

1. Specify height when ordering "X" models (example: S/SSW12x8X, H = 95").

NAMING SCHEME: S/SSW24x8X Steel Strong-Wall Height Modification Option (in.) Width for Cold-Formed Steel (in.) Nominal Height (ft.)



WALL PROFILES



STEEL STRONG-WALL®: Cold-Formed Steel on Concrete Foundations



2006 INTERNATIONAL BUILDING CODE®

| | | | | Seismic ² | | | Wind | |
|----------------|--------------------|----------------------------------|---|--|---|---|--|---|
| S/SSW Model | Max. H (in.) | Allowable Axial Load (lbs) | Allowable ASD Shear Load V (lbs) | Drift at Allowable Shear (in) | Uplift at Allowable Shear ⁶ (lbs) | Allowable ASD Shear Load V (lbs) | Drift at Allowable Shear (in) | Uplift at Allowable Shear ⁶ (lbs) |
| | | 1000 | 845 | 0.35 | 8460 | 1070 | 0.44 | 11405 |
| S/SSW12x7 | 80 | 4000 | 845 | 0.35 | 8460 | 1060 | 0.44 | 11265 |
| | | 7500 | 845 | 0.35 | 8460 | 885 | 0.37 | 8950 |
| | | 1000 | 1645 | 0.34 | 13340 | 1810 | 0.38 | 15135 |
| S/SSW15x7 | 80 | 4000 | 1640 | 0.34 | 13290 | 1640 | 0.34 | 13290 |
| | | 7500 | 1440 | 0.30 | 11290 | 1440 | 0.30 | 11290 |
| | | 1000 | 2800 | 0.33 | 18690 | 3375 | 0.40 | 24545 |
| S/SSW18x7 | 80 | 4000 | 2800 | 0.33 | 18690 | 3250 | 0.38 | 23135 |
| | | 7500 | 2800 | 0.33 | 18690 | 2980 | 0.35 | 20370 |
| | | 1000 | 4050 | 0.32 | 22590 | 4440 | 0.35 | 25710 |
| S/SSW21x7 | 80 | 4000 | 4050 | 0.32 | 22590 | 4440 | 0.35 | 25710 |
| | | 7500 | 4050 | 0.32 | 22590 | 4310 | 0.34 | 24635 |
| | | 1000 | 5250 | 0.30 | 24710 | 5250 | 0.30 | 24710 |
| S/SSW24x7 | 80 | 4000 | 5250 | 0.30 | 24710 | 5250 | 0.30 | 24710 |
| | | 7500 | 5250 | 0.30 | 24710 | 5250 | 0.30 | 24710 |
| | | 1000 | 645 | 0.42 | 7710 | 820 | 0.54 | 10360 |
| S/SSW12x8X | 97 | 4000 | 645 | 0.42 | 7710 | 775 | 0.51 | 9640 |
| | | 7500 | 610 | 0.40 | 7220 | 610 | 0.40 | 7220 |
| | | 1000 | 1280 | 0.42 | 12390 | 1415 | 0.47 | 14090 |
| S/SSW15x8X | 97 | 4000 | 1250 | 0.41 | 12025 | 1250 | 0.41 | 12025 |
| | | 7500 | 1070 | 0.35 | 9955 | 1070 | 0.35 | 9955 |
| S/SSW18x8X | | 1000 | 2140 | 0.41 | 16895 | 2785 | 0.54 | 24565 |
| | 97 | 4000 | 2140 | 0.41 | 16895 | 2680 | 0.52 | 23130 |
| | | 7500 | 2140 | 0.41 | 16895 | 2460 | 0.48 | 20400 |
| S/SSW21x8X | | 1000 | 3265 | 0.41 | 21905 | 3870 | 0.48 | 27930 |
| | 97 | 4000 | 3265 | 0.41 | 21905 | 3765 | 0.47 | 26790 |
| | | 7500 | 3265 | 0.41 | 21905 | 3460 | 0.43 | 23715 |
| | | 1000 | 4540 | 0.39 | 26335 | 4985 | 0.43 | 30045 |
| S/SSW24x8X | 97 | 4000 | 4540 | 0.39 | 26335 | 4890 | 0.42 | 29220 |
| | | 7500 | 4540 | 0.39 | 26335 | 4555 | 0.39 | 26455 |
| | 109 | 1000 | 545 | 0.48 | 7255 | 695 | 0.61 | 9735 |
| S/SSW12x9X | | 4000 | 545 | 0.48 | 7255 | 605 | 0.53 | 8210 |
| | | 7500 | 445 | 0.39 | 5755 | 445 | 0.39 | 5755 |
| | | 1000 | 1090 | 0.48 | 11725 | 1180 | 0.52 | 12955 |
| S/SSW15x9X | 109 | 4000 | 1025 | 0.45 | 10875 | 1025 | 0.45 | 10875 |
| | | 7500 | 850 | 0.37 | 8720 | 850 | 0.37 | 8720 |
| | | 1000 | 1835 | 0.47 | 16105 | 2365 | 0.61 | 22835 |
| S/SSW18x9X | 109 | 4000 | 1835 | 0.47 | 16105 | 2365 | 0.61 | 22835 |
| | | 7500 | 1835 | 0.47 | 16105 | 2150 | 0.55 | 19890 |
| | | 1000 | 2800 | 0.46 | 20855 | 3275 | 0.54 | 25900 |
| S/SSW21x9X | 109 | 4000 | 2800 | 0.46 | 20855 | 3025 | 0.50 | 23140 |
| | L I | 7500 | 2735 | 0.45 | 20220 | 2735 | 0.45 | 20220 |
| | | 1000 | 4005 | 0.46 | 26025 | 4220 | 0.48 | 27970 |
| S/SSW24x9X | 109 | 4000 | 3950 | 0.45 | 25540 | 3950 | 0.45 | 25540 |
| | | 7500 | 3630 | 0.41 | 22855 | 3630 | 0.41 | 22855 |
| | | 1000 | 945 | 0.53 | 11185 | 990 | 0.56 | 11845 |
| S/SSW15x10X | 121 | 4000 | 835 | 0.47 | 9645 | 835 | 0.47 | 9645 |
| | | 7500 | 665 | 0.37 | 7425 | 665 | 0.37 | 7425 |
| | | 1000 | 1605 | 0.53 | 15515 | 2045 | 0.67 | 21490 |
| S/SSW18x10X | 121 | 4000 | 1605 | 0.53 | 15515 | 1960 | 0.64 | 20225 |
| | | 7500 | 1605 | 0.53 | 15515 | 1715 | 0.56 | 16890 |
| | | 1000 | 2440 | 0.52 | 19970 | 2650 | 0.56 | 22275 |
| S/SSW21x10X | 121 | 4000 | 2405 | 0.51 | 19600 | 2405 | 0.51 | 19600 |
| | | 7500 | 2120 | 0.45 | 16730 | 2120 | 0.45 | 16730 |
| | | 1000 | 3425 | 0.50 | 24275 | 3425 | 0.50 | 24275 |
| S/SSW24x10X | 121 | 4000 | 3160 | 0.46 | 21875 | 3160 | 0.46 | 21875 |
| | 121 | 7500 | 2855 | 0.42 | 19275 | 2855 | 0.42 | 19275 |

NOTE:

For models with an "X" suffix, specify height when ordering (example: S/SSW12x8X, h=95").

- Allowable shear loads and anchor uplifts are applicable to installation on concrete with minimum f'_C = 2500 psi using the ASD basic (Section 1605.3.1) or the alternative basic (Section 1605.3.2) load combinations. Load values include evaluation of bearing stresses.
- 2. For seismic designs based on the 2006 IBC using R = 6.5. For other codes, use the seismic coefficients corresponding to light-frame bearing walls with wood structural panels or sheet steel panels.
- 3. Top-of-wall screws for the S/SSW shall be approved 1/4" or #14 selfdrilling screws with a minimum nominal shear strength (Pss) of 2000 lbs. Top of panel shall be connected to a minimum 43 mil (18 ga) thick steel member typical. S/SSW18 and wider panels up to 97 inches tall require connection to a minimum 54 mil (16 ga) thick steel member. When connected to a minimum 43 mil (18 ga) thick steel member, the allowable load shall be limited to 2720 lbs. for S/SSW18, 3625 lbs. for S/SSW21, and 4230 lbs. for S/SSW24.
- Allowable shear, drift, and uplift values may be interpolated for intermediate height or axial loads. See example on page 42.
- 5. High-strength anchor bolts are required for anchor tension (uplift) forces exceeding the allowable load for standard-strength bolts tabulated on pages 50–51. See pages 50–54 for SSWAB anchor bolt information and anchorage solutions.
- 6. Tabulated anchor tension (uplift) loads assume no resisting axial load. For anchor tension loads at design shear values and including the effect of axial load, refer to the Strong-Wall Selector™ software or use the equations on page 43. Drifts at lower design shear may be linearly reduced.
- 7. See page 42 for allowable out-ofplane loads and axial capacities.

STEEL STRONG-WALL®: Cold-Formed Steel on Concrete Foundations



ALLOWABLE OUT-OF-PLANE LOADS (PSF)1,3

| Model | Axial Load | Nominal Height of Panel (feet) | | | | | |
|----------|----------------------|--------------------------------|-----|-----|--|--|--|
| Width | (lbs) ^{2,4} | 8 | 9 | 10 | | | |
| | 1000 | 195 | 140 | 100 | | | |
| 12" wide | 4000 | 145 | 100 | 70 | | | |
| | 7500 | 85 | 50 | 25 | | | |
| | 1000 | 160 | 125 | 100 | | | |
| 15" wide | 4000 | 130 | 95 | 70 | | | |
| | 7500 | 90 | 65 | 45 | | | |
| 18" wide | 7500 | 300 | 210 | 155 | | | |
| 21" wide | 7500 | 255 | 180 | 130 | | | |
| 24" wide | 7500 | 265 | 190 | 135 | | | |

- 1. Loads shown are at ASD level in pounds per square foot (psf) of wall with no further increase allowed and are applicable to either the ASD Basic or Alternative Basic load combinations.
- 2. Axial load denotes maximum gravity load permitted on entire panel acting in combination with the out-of-plane load.
- 3. Load considers a deflection limit of h/240.
- 4. Allowable out-of-plane loads for the 12- and 15-inch walls may be linearly interpolated between the axial loads shown.

AXIAL CAPACITIES ON CONCRETE

| Model | | Compression with No Late | | | | | |
|----------|-------|--------------------------------|-------|-------|--|--|--|
| Width | | Nominal Height of Panel (feet) | | | | | |
| | 7 | 8 | 9 | 10 | | | |
| 12" wide | 20200 | 16300 | 13700 | 11100 | | | |
| 15" wide | 25300 | 21800 | 19200 | 16600 | | | |
| 18" wide | 42500 | 36000 | 31400 | 27000 | | | |
| 21" wide | 43700 | 35800 | 30300 | 25100 | | | |
| 24" wide | 51600 | 42900 | 36900 | 31100 | | | |

- 1. Compression capacity is lesser of wall-buckling capacity or 2500 psi uniform concrete bearing
- 2. Compression capacity of wall assumes concentric loading with no lateral loads present. See allowable in-plane or out-of-plane shear load tables for combined lateral and axial loading conditions.
- 3. Capacities are applicable to either the ASD Basic or Alternative Basic load combinations.

S/SSW SHEAR LOAD INTERPOLATION EXAMPLE

Given:

2006 IBC, Seismic, 2500 psi Concrete

Shear Load = 2000 lbs.

Axial = 4000 lbs.

S/SSW Wall Height Required: 8'-6" = 102"

Interpolate (See table on page 30):

S/SSW18x8X $V_1 = 2140 \text{ lbs.}, h_1 = 97$ "

S/SSW18x9X $V_2 = 1835 \text{ lbs.}, h_2 = 109$ "

Equation: $V_{allow} = \left(\frac{V_1 - V_2}{h_1 - h_2}\right) (h_{required} - h_1) + V_1$

 $V_{\text{allow}} = \left(\frac{2140 \text{ lbs.} - 1835 \text{ lbs.}}{97" - 109"}\right) (102" - 97") + 2140 \text{ lbs.} = 2013 \text{ lbs.} @ 102"$

 $V_{allow} = 2013 \text{ lbs.} > 2000 \text{ lbs.}$

>>> Use S/SSW18x9X H = 102"

STEEL STRONG-WALL®: Uplift Equations



EQUATIONS FOR CALCULATING UPLIFT FORCES AT BASE OF FIRST-STORY WALL

(Based on limiting concrete bearing on a 3½" wide base plate at the edge of the concrete)

These equations may be used to calculate uplift forces at the base of the 1st-story wall to aid Designers in developing anchorage solutions other than those shown on pages 50-54.



Equations have been revised and are based on a rectangular compression stress block.

2.5 ksi concrete

12 in. wall
$$T = \begin{bmatrix} 28.1 - \sqrt{788 - 5.95 (3.4P + Vh)} \end{bmatrix} - P$$
15 in. wall
$$T = \begin{bmatrix} 36.1 - \sqrt{1301 - 5.95 (4.6P + Vh)} \end{bmatrix} - P$$
18 in. wall
$$T = \begin{bmatrix} 45.0 - \sqrt{2025 - 5.95 (6.1P + Vh)} \end{bmatrix} - P$$
21 in. wall
$$T = \begin{bmatrix} 53.9 - \sqrt{2908 - 5.95 (7.6P + Vh)} \end{bmatrix} - P$$
24 in. wall
$$T = \begin{bmatrix} 62.8 - \sqrt{3950 - 5.95 (9.1P + Vh)} \end{bmatrix} - P$$

3.0 ksi concrete


12 in. wall
$$T = \begin{bmatrix} 33.7 - \sqrt{1135 - 7.14 (3.4P + Vh)} \end{bmatrix} - P$$
15 in. wall
$$T = \begin{bmatrix} 43.3 - \sqrt{1874 - 7.14 (4.6P + Vh)} \end{bmatrix} - P$$
18 in. wall
$$T = \begin{bmatrix} 54.0 - \sqrt{2916 - 7.14 (6.1P + Vh)} \end{bmatrix} - P$$
21 in. wall
$$T = \begin{bmatrix} 64.7 - \sqrt{4187 - 7.14 (7.6P + Vh)} \end{bmatrix} - P$$
24 in. wall
$$T = \begin{bmatrix} 75.4 - \sqrt{5688 - 7.14 (9.1P + Vh)} \end{bmatrix} - P$$

4.5 ksi concrete

12 in. wall
$$T = \begin{bmatrix} 50.5 - \sqrt{2554 - 10.71 \ (3.4P + Vh)} \end{bmatrix} - P$$
15 in. wall
$$T = \begin{bmatrix} 64.9 - \sqrt{4216 - 10.71 \ (4.6P + Vh)} \end{bmatrix} - P$$
18 in. wall
$$T = \begin{bmatrix} 81.0 - \sqrt{6560 - 10.71 \ (6.1P + Vh)} \end{bmatrix} - P$$
21 in. wall
$$T = \begin{bmatrix} 97.1 - \sqrt{9421 - 10.71 \ (7.6P + Vh)} \end{bmatrix} - P$$
24 in. wall
$$T = \begin{bmatrix} 113.1 - \sqrt{12,797 - 10.71 \ (9.1P + Vh)} \end{bmatrix} - P$$

Notes:

- 1. Equations may be used to calculate uplift forces at the base of first-story walls on concrete foundations.
- 2. Equations are based on the design methodology contained in AISC Steel Design Guide 1 – Base Plate and Anchor Rod Design, second edition using a rectangular compression stress block.



Forces at Base of Wall

T = Resulting anchorage tension (uplift) force (kips)

V = Design shear (kips)

P = Total vertical load (kips)

h = Wall height (inches)

For two-story stacked applications, substitute Mhase for Vh:

$$Vh = M_{base} \left(\frac{12}{1000}\right) kip - in$$

Where M_{base} = Design moment at base of wall (ft-lbs)

EXAMPLE 1 - Single-Story S/SSW:

Given:

C-CFS10 @ 2010 SIMPSON STRONG-TIE COMPANY INC

- S/SSW18x9X wall on 2.5 ksi concrete
- 2006 International Building Code®, Seismic
- Design Shear (V) = 1.5 kips < 1.835 kips (V_{allowable})
- P (Vertical Load) = 1.0 kip
- h = Wall height = 109"

$$T = \left[45.0 - \sqrt{2025 - 5.95 (6.1P + Vh)}\right] - P$$

$$T = \left[45.0 - \sqrt{2025 - 5.95 (6.1 \times 1 + 1.5 \times 109)}\right] - 1.0 = 12.1 \text{ kips}$$

EXAMPLE 2 – Two-Story Stacked S/SSW Condition:

- See Two-Story Design Example on page 49
- · S/SSW18x9X-STK wall on 2.5 ksi concrete
- 2006 International Building Code®, Wind
- M_{base} = 17,550 ft-lbs. (Moment at base of two-story stacked wall)
- Vh = 17,550 x $\left(\frac{12}{1000}\right)$ kip-in = 210.6 kip-in
- P (Vertical Load) = 2.0 kips

$$T = \left[45.0 - \sqrt{2025 - 5.95 (6.1P + Vh)}\right] - P$$

$$T = \left[45.0 - \sqrt{2025 - 5.95 (6.1 \times 2 + 210.6)}\right] - 2 = 16.6 \text{ kips}$$

SIMPSON

STEEL STRONG-WALL®: Cold-Formed Steel 1st-Story Floor Systems




Steel Strong-Wall® panels designed for use on concrete foundations can now be used with cold-formed steel floor systems by extending the anchor bolts and installing compression nuts and stud blocking below the wall.

MATERIAL & FINISH: See page 40.

For product data and naming scheme information, see page 40.

CFS First-Floor Wall Connection Kit

| Wall Width (in) | Model No. | Contents |
|--------------------|-----------|---|
| 12 | SSW12-1KT | (1) Shear-Transfer Plate |
| 15 | SSW15-1KT | (with #14 self-drilling screws) (2) ¾" or 1"x18" Threaded Rods |
| 18 | SSW18-1KT | F1554 Grade 36 |
| 21 | SSW21-1KT | (2) Coupler Nuts (2) Heavy Hex Nuts |
| 24 | SSW24-1KT | Installation Instructions |



.0.


Perpendicular floor framing at 2'-0" o.c. maximum (not shown for clarity) or install full-depth joist blocking within **BLOCKING/CONNECTION** 6" of each end of panel where floor framing is parallel.






underside of wall (Notchine of rim will be required)





ALTERNATE 1ST-FLOOR INSTALLATION

Specify taller wall model to allow for floor framing and use load values for installation on concrete pages 40-41.



SSWAB

0

0

DO NOT cut wall or enlarge existing holes

0

0

For a complete set of wall profile drawings, see page 40.

Shear-Transfer Plate Fasteners for Raised-Floor Applications

| Strong- Wall Width | Fastener #14 Screws | Quantity #10 Screws |
|--------------------------|---------------------------|---------------------------|
| 12" Wall | 4 | 6 |
| 15" Wall | 4 | 10 |
| 18" Wall | 6 | 12 |
| 21" Wall | 6 | 16 |
| 24" Wall | 7 | 18 |

SSW Shear-Transfer Plate installs with #10 self-drilling screws (Quik Drive TRSD34S1016 recommended, not provided) into the rim and #14 self-drilling screws into the Strong-Wall



screws min. sill track to rim each side.

(3) #8 self-drilling

EXTERIOR VIEW OF SHEAR-TRANSFER PLATE

C-CFS10 @ 2010 SIMPSON STRONG-TIE COMPANY INC

C-CFS10 @ 2010 SIMPSON STRONG-TIE COMPANY INC

STEEL STRONG-WALL®: Cold-Formed Steel 1st-Story Floor Systems



2006 International Building Code®

| | | Seismic ² | | | Wind | |
|-------------|-------------------------------------|----------------------------------|--------------------------------------|-------------------------------------|----------------------------------|---|
| S/SSW Model | Allowable ASD Shear Load V (lbs) | Drift at Allowable Shear (in) | Uplift at Allowable Shear 4 (lbs) | Allowable ASD Shear Load V (lbs) | Drift at Allowable Shear (in) | Uplift at Allowable Shear ⁴ (lbs) |
| S/SSW12x7 | 530 | 0.31 | 6165 | 530 | 0.31 | 6165 |
| S/SSW15x7 | 1355 | 0.35 | 11720 | 1395 | 0.36 | 12065 |
| S/SSW18x7 | 1850 | 0.27 | 12080 | 1850 | 0.27 | 12080 |
| S/SSW21x7 | 2100 | 0.20 | 11015 | 2100 | 0.20 | 11015 |
| S/SSW24x7 | 2450 | 0.17 | 10740 | 2450 | 0.17 | 10740 |
| S/SSW12x8X | 435 | 0.40 | 6135 | 435 | 0.40 | 6135 |
| S/SSW15x8X | 1050 | 0.42 | 11010 | 1150 | 0.46 | 12060 |
| S/SSW18x8X | 1525 | 0.36 | 12075 | 1525 | 0.36 | 12075 |
| S/SSW21x8X | 1900 | 0.29 | 12085 | 1900 | 0.29 | 12085 |
| S/SSW24x8X | 2270 | 0.24 | 12065 | 2270 | 0.24 | 12065 |
| S/SSW12x9X | 390 | 0.47 | 6185 | 390 | 0.47 | 6185 |
| S/SSW15x9X | 900 | 0.48 | 10605 | 1025 | 0.54 | 12080 |
| S/SSW18x9X | 1355 | 0.42 | 12055 | 1355 | 0.42 | 12055 |
| S/SSW21x9X | 1690 | 0.34 | 12080 | 1690 | 0.34 | 12080 |
| S/SSW24x9X | 2020 | 0.28 | 12065 | 2020 | 0.28 | 12065 |
| S/SSW15x10X | 785 | 0.53 | 10270 | 925 | 0.63 | 12100 |
| S/SSW18x10X | 1220 | 0.48 | 12050 | 1220 | 0.48 | 12050 |
| S/SSW21x10X | 1520 | 0.39 | 12060 | 1520 | 0.39 | 12060 |
| S/SSW24x10X | 1820 | 0.32 | 12065 | 1820 | 0.32 | 12065 |

- 1. Loads are applicable to 1st-Story Cold-Formed Steel Raised-Floor installations supported on concrete or masonry foundations using the ASD basic (Section 1605.3.1) or the alternative basic (Section 1605.3.2) load combinations. Load values include evaluation of anchor rod compression capacity and do not require further evaluation by the Designer.
- 2. For seismic designs based on the 2006 IBC using R = 6.5. For other codes, use the seismic coefficients corresponding to light-frame bearing walls with wood structural panels or sheet steel panels.
- 3. Minimum standard-strength anchor bolts required. See pages 50-54 for SSWAB anchor bolt information and anchorage solutions.
- Tabulated anchor tension (uplift) loads assume no resisting axial load. Anchor rod tension at design shear load and including the effect of axial load may be determined using the Strong-Wall Selector™ software or the following equation:

 $T = [(V \times h) / B] - P/2$, where: T = Anchor rod tension load (lbs)

- V = design shear load (lbs)
 h = Strong-Wall® height per page 40 (in)
- P = applied axial load (lbs)
- B = Anchor bolt centerline dimension (in) (6%" for SSW12, 9¼" for SSW15, 12¼" for SSW18, 15¼" for SSW21, and 18¼" for SSW24)
- 5. Allowable shear loads assume a maximum first-floor joist depth of 12".
- 6. Allowable shear loads are based on 1000 lbs. total uniformly distributed axial load acting on the entire panel in combination with the shear load. For allowable shear loads at 2000 lbs. uniformly distributed axial load, multiply table values by 0.92 for SSW12x models, and 0.96 for other SSW widths
- 7. Top-of-wall screws for the S/SSW shall be approved 1/4" or #14 self-drilling screws with a minimum nominal shear strength (Pss) of 2000 lbs. Top of panel shall be connected to a minimum 43 mil (18 ga) thick steel member typical.

A complete stacked-wall solution for two-story applications. Now there is a Steel Strong-Wall® option for two-story cold-formed steel installations that combines simplified installation with superior performance.

Nominal Height (ft.)

Nominal Height (ft.)

- · Some of the highest loads in the industry, and design procedures that account for cumulative overturning.
- · Complete concrete anchorage designs for two-story applications (foundation design by Designer).
- No bearing plates to install. Walls can be placed flush against a corner.

S/SSW18x8X

Width

(in.)

Width

(in.)

S/SSW18x10X-STK

- · Same anchor bolt template as single-story installation.
- · Compression loads transferred by nut/rod.

MATERIAL & FINISH: See page 40.

Steel Strong-Wall for **Cold-Formed Steel**

Steel Strong-Wall for

Cold-Formed Steel

NAMING SCHEME

Top Wall:

Bottom Wall:

For a complete set of wall profile drawings, see page 40.

Height Modification Option Stacked Wall (For Bottom Walls Only) **Height Modification Option**

COLD-FORMED STEEL TWO-STORY STACKED-WALL PRODUCT DATA - BOTTOM WALL


| Model No. | W | MAX H ¹ | T | Anchor Bolts | | Number of Screws |
|-----------------|------|--------------------|-------|--------------|------|---------------------|
| Mouel No. | (in) | (in) | (in) | Qty. | Dia. | in Top of Wall |
| S/SSW15x8X-STK | 15" | 97 | 3½" | 2 | 1" | 6 |
| S/SSW18x8X-STK | 18" | 97 | 31/2" | 2 | 1" | 9 |
| S/SSW21x8X-STK | 21" | 97 | 31/2" | 2 | 1" | 12 |
| S/SSW24x8X-STK | 24" | 97 | 31/2" | 2 | 1" | 14 |
| S/SSW15x9X-STK | 15" | 109 | 31/2" | 2 | 1" | 6 |
| S/SSW18x9X-STK | 18" | 109 | 3½" | 2 | 1" | 9 |
| S/SSW21x9X-STK | 21" | 109 | 31/2" | 2 | 1" | 12 |
| S/SSW24x9X-STK | 24" | 109 | 31/2" | 2 | 1" | 14 |
| S/SSW15x10X-STK | 15" | 121 | 31/2" | 2 | 1" | 6 |
| S/SSW18x10X-STK | 18" | 121 | 3½" | 2 | 1" | 9 |
| S/SSW21x10X-STK | 21" | 121 | 3½" | 2 | 1" | 12 |
| S/SSW24x10X-STK | 24" | 121 | 31/2" | 2 | 1" | 14 |

- 1. Specify height when ordering "X-STK" models
- 2. See page 40 for product data on top wall.

Two-Story Stacked-Wall Connection Kit

| Wall Width (in) | Model No. | Contents |
|--------------------|-----------|---|
| 15 | SSW15-2KT | (1) Shear-Transfer Plate (with |
| 18 | SSW18-2KT | #14 self-drilling screws, included) |
| 21 | SSW21-2KT | (2) 1"x48" Threaded Rods F1554 Grade 36 (6) Heavy Hex Nuts |
| 24 | SSW24-2KT | Installation Instructions |

1. Two heavy hex nuts included with each wall.



STEEL STRONG-WALL®: Two-Story Stacked on Concrete Foundations




INSTALLATION


- Do not cut the Steel Strong-Wall® or enlarge existing holes. Doing so will compromise the performance of the wall.
- Do not use an impact wrench to tighten nuts on the anchor bolts.

• Drill or notch the subfloor to allow the compression nut to sit flush with the underside of the 2nd-story wall (notching of the rim will be required).

Attach to top track with 1/4" or #14 self-drilling screws (not provided)

Shear-Transfer Plate Fasteners Fastener Quantity Strong-Wall #14 Screws 12" Wall 6





install shear-transfer plate Drill/notch subfloor to allow nut to sit flush with 0 underside of wall. (Notching of rim will be required)

Clip sill track as required to


SSW Shear-Transfer Plate installs with #10 self-drilling screws installed into rim (Quik Drive TRSD34S1016 recommended, not provided) and #14 self-drilling screws into the Strong-Wall® (included with SSW__-2KT)

> (3) #8 self-drilling screws min. sill track to rim each side


Rim 43 mil (18 ga) min.

Shear transfer by Designer (LTP5 shown)

EXTERIOR VIEW OF SHEAR-TRANSFER PLATE




Use SSW__-2KT connection



ALTERNATE 1ST-FLOOR INSTALLATION Specify taller wall model to allow for

floor framing and use load values for installation on concrete pages 41.

SSWAB1



Place Steel Strong-Wall® panel over the nuts (provided). Snug tight fit required. Do not use an impact wrench.

CONNECTION DETAIL

• 15/8" wrench/socket required for 1" nut.

STEEL STRONG-WALL®: Cold-Formed Steel Two-Story Stacked on Concrete Foundations



Second-Story Walls^{6, 8} - 2006 International Building Code

| | Seisr | mic ² | Wi | nd |
|-----------------------------|-------------------------------------|-------------------------------------|-------------------------------------|-------------------------------------|
| Second-Story Wall Models | Allowable ASD Shear Load V (lbs) | Drift at Allowable Shear (in) | Allowable ASD Shear Load V (lbs) | Drift at Allowable Shear (in) |
| S/SSW15x7 | 600 | 0.21 | 600 | 0.21 |
| S/SSW18x7 | 1080 | 0.21 | 1390 | 0.27 |
| S/SSW21x7 | 1650 | 0.21 | 1815 | 0.23 |
| S/SSW24x7 | 2295 | 0.21 | 2330 | 0.21 |
| S/SSW15x8X | 550 | 0.29 | 550 | 0.29 |
| S/SSW18x8X | 995 | 0.31 | 1275 | 0.39 |
| S/SSW21x8X | 1515 | 0.30 | 1650 | 0.33 |
| S/SSW24x8X | 1970 | 0.27 | 1970 | 0.27 |
| S/SSW15x9X | 510 | 0.35 | 510 | 0.35 |
| S/SSW18x9X | 940 | 0.38 | 1180 | 0.47 |
| S/SSW21x9X | 1435 | 0.37 | 1465 | 0.38 |
| S/SSW24x9X | 1755 | 0.31 | 1755 | 0.31 |
| S/SSW15x10X | 475 | 0.41 | 475 | 0.41 |
| S/SSW18x10X | 890 | 0.45 | 1060 | 0.54 |
| S/SSW21x10X | 1300 | 0.42 | 1300 | 0.42 |
| S/SSW24x10X | 1580 | 0.36 | 1580 | 0.36 |

- Allowable base moment and anchor uplifts are applicable to installation on concrete foundations with minimum f'c = 2,500 psi using the ASD basic (Section 1605.3.1) or the alternative basic (Section 1605.3.2) load combinations. Load values include evaluation of anchor rod compression at second story and bearing stresses at foundation.
- 2. For seismic designs based on the 2006 IBC using \bar{R} = 6.5. For other codes, use the seismic coefficients corresponding to light-frame bearing walls with wood structural panels or sheet steel panels.
- Two-Story Stacked-Wall installations may consist of any height combination of equal width wall models listed in these tables.
- 4. Loads are based on a 1000 lbs. maximum uniformly distributed total axial load acting on the second-story panel and a 2000 lbs. maximum uniformly distributed total axial load acting on the first-story panel in combination with the tabulated shear load and base moment.
- The designer must verify that the cumulative overturning moment at the base of the first-story Steel Strong-Wall does not exceed the allowable base moment capacity. See design example on page 49 for procedure.
- 6. The allowable second-story shear loads assume a maximum floor joist depth of 14".

- Allowable shear, drift, and base moment values may be interpolated for intermediate heights.
- Minimum ASTM F 1554 Grade 36 threaded rods are required at the second-story wall anchorage.
- High-strength anchor bolts are required at the first-story wall for anchor tension (uplift) forces exceeding the allowable load for standard strength bolts tabulated on pages 50–51. See pages 50–54 for SSWAB anchor bolt information and anchorage solutions.
- 10. Tabulated anchor tension (uplift) loads assume no resisting axial load. For anchor tension loads at design shear values and including the effect of axial load, refer to the Strong-Wall Selector software or use the equations on page 43. Drifts at lower design shear or base moment may be linearly reduced.
- 11.Top-of-wall screws for the S/SSW shall be approved $\ensuremath{\mbox{\sc M}}$ a minimum nominal shear strength (P_{SS}) of 2000 lbs. Top of panel shall be connected to a minimum 43 mil (18 ga) thick steel member typical. First-Story S/SSW 24x8X-STK requires connection to a minimum 54 mil (16 ga) thick steel member where the total applied shear load exceeds 4230 lbs.

FIRST-STORY WALLS ON CONCRETE FOUNDATIONS 5, 9, 11 - 2006 INTERNATIONAL BUILDING CODE

| | | Seismic ² | | Wind | | | |
|----------------------------|--|---|---|--|---|---|--|
| First-Story Wall Models | Allowable ASD Base Moment (ft-lbs) | Drift at Allowable Base Moment (in) | Uplift at Allowable Base Moment ¹⁰ (lbs) | Allowable ASD Base Moment (ft-lbs) | Drift at Allowable Base Moment (in) | Uplift at Allowable Base Moment ¹⁰ (lbs) | |
| S/SSW15x8X-STK | 10130 | 0.41 | 12065 | 10130 | 0.41 | 12065 | |
| S/SSW18x8X-STK | 17300 | 0.41 | 16895 | 22230 | 0.53 | 24075 | |
| S/SSW21x8X-STK | 26390 | 0.41 | 21905 | 31000 | 0.48 | 27545 | |
| S/SSW24x8X-STK | 36700 | 0.39 | 26335 | 40040 | 0.43 | 29770 | |
| S/SSW15x9X-STK | 9705 | 0.47 | 11440 | 9945 | 0.48 | 11790 | |
| S/SSW18x9X-STK | 16670 | 0.47 | 16110 | 21480 | 0.61 | 22835 | |
| S/SSW21x9X-STK | 25435 | 0.46 | 20855 | 28990 | 0.53 | 24950 | |
| S/SSW24x9X-STK | 36210 | 0.45 | 25860 | 37515 | 0.47 | 27145 | |
| S/SSW15x10X-STK | 9160 | 0.51 | 10665 | 9460 | 0.53 | 11090 | |
| S/SSW18x10X-STK | 16185 | 0.53 | 15515 | 20335 | 0.66 | 21060 | |
| S/SSW21x10X-STK | 24485 | 0.52 | 19845 | 25895 | 0.55 | 21355 | |
| S/SSW24x10X-STK | 33645 | 0.49 | 23460 | 33645 | 0.49 | 23460 | |

STEEL STRONG-WALL®: Cold-Formed Steel Two-Story Stacked on Concrete Foundations



STEEL STRONG-WALL® TWO-STORY DESIGN EXAMPLE Example: Cold-Formed Steel Two-Story Wall Design

Given:

2006 IBC, Wind, f'c = 2500 psi

V_{2nd-story wall} = 650 lbs.

V_{1st-story wall} = 650 lbs.

 $V_{total} = 650 \text{ lbs.} + 650 \text{ lbs.} = 1,300 \text{ lbs.}$

M_{allow} = Allowable ASD Base Moment (ft-lbs.) (See Cold-Formed Steel Two-Story Stacked Tables)

V_{allow} = Allowable ASD Shear Load V (lbs.) (See Cold-Formed Steel Two-Story Stacked Tables)

STEP 1 – Select First-Story Wall (See tables on page 48)

 $M_{base} = (650 \text{ lbs. } x 18 \text{ ft.}) + (650 \text{ lbs. } x 9 \text{ ft.}) = 17,550 \text{ ft-lbs.}$

Using First-Story Wall Table, select a 9-foot wall with M_{allow} ≥ M_{base}

Select S/SSW18x9X-STK

 $M_{allow} = 21,480 \text{ ft-lbs.} > 17,550 \text{ ft-lbs.}$ OK

STEP 2 - Check Second-Story Wall


Using the Second-Story Wall Table on page 48, check the capacity of an 8-foot wall with the same width as the First-Story Wall selected in Step 1:

Select S/SSW18x8X

 $V_{allow} = 1,275 lbs. > 650 lbs. <u>OK</u>$

>>> Use S/SSW18x8X over S/SSW18x9X-STK

Specify height when ordering "X" and "X-STK" models



STEEL STRONG-WALL®: Anchorage Solutions


SIMPSON Strong-T

SSWAB ANCHOR BOLTS

SSWAB anchor bolts in 3/4" and 1" diameters offer flexibility to meet specific project demands. Inspection is easy; the head is stamped with a "No Equal" symbol for identification, bolt length, bolt diameter, and optional "HS" for High Strength if specified.


MATERIAL: ASTM F1554 Grade 36; High-Strength (HS) ASTM A449

An additional nut for template installation is provided with each SSWAB. It may also be used for SSW installation.



| Steel Strong-Wall Width (in) | Model No. | Dia. (in) | Total Length (in) | le (in) |
|---------------------------------------|---------------|--------------|-------------------------|------------|
| | SSWAB¾x24 | 3/4 | 24 | 19 |
| 401 | SSWAB¾x24HS | 3/4 | 24 | 19 |
| 12" Model | SSWAB3/4x30 | 3/4 | 30 | 25 |
| Wiodei | SSWAB3/4x30HS | 3/4 | 30 | 25 |
| | SSWAB3/4x36HS | 3/4 | 36 | 31 |
| | SSWAB1x24 | 1 | 24 | 19 |
| 45" 40" 04" | SSWAB1x24HS | 1 | 24 | 19 |
| 15", 18", 21", 24" Models | SSWAB1x30 | 1 | 30 | 25 |
| 24 WOUGIS | SSWAB1x30HS | 1 | 30 | 25 |
| | SSWAB1x36HS | 1 | 36 | 31 |

SSWHSR EXTENSION KIT



STEEL STRONG-WALL® ANCHORAGE SOLUTIONS - 2500 psi CONCRETE

| Design | Concrete | Anchor | SSWAB | 34" ANCHOR E | BOLT | SSWAB 1" ANCHOR BOLT | | |
|-----------|------------|----------------|-------------------------------|--------------|------------|-------------------------------|-----------|------------|
| Criteria | Condition | Strength | ASD Allowable Uplift (lbs) | W (in) | de (in) | ASD Allowable Uplift (lbs) | W (in) | de (in) |
| | Cracked | Standard | 9600 | 25 | 9 | 17100 | 36 | 12 |
| Seismic | Gracked | High Strength | 19900 | 39 | 13 | 35300 | 56 | 19 |
| Seisifiic | Uncracked | Standard | 9600 | 21 | 7 | 17100 | 32 | 11 |
| | Ulicracked | High Strength | 19900 | 34 | 12 | 35300 | 49 | 17 |
| | | | 4500 | 12 | 6 | 5600 | 14 | 6 |
| | | Standard | 6900 | 16 | 6 | 12700 | 24 | 8 |
| | | | 9600 | 20 | 7 | 17100 | 30 | 10 |
| | Cracked | High Strength | 11100 | 22 | 8 | 22400 | 35 | 12 |
| | | | 13500 | 25 | 9 | 26800 | 39 | 13 |
| | | | 16000 | 28 | 10 | 31600 | 43 | 15 |
| Wind | | | 19900 | 33 | 11 | 35300 | 47 | 16 |
| vviiiu | | | 5600 | 12 | 6 | 5600 | 12 | 6 |
| | | Standard | 7800 | 15 | 6 | 12000 | 20 | 7 |
| | | | 9600 | 18 | 6 | 17100 | 26 | 9 |
| | Uncracked | | 11200 | 19 | 7 | 22100 | 30 | 10 |
| | | Lligh Ctrongth | 13900 | 22 | 8 | 26700 | 34 | 12 |
| | | High Strength | 15800 | 24 | 8 | 32100 | 38 | 13 |
| | | | 19900 | 29 | 10 | 35300 | 41 | 14 |

- 1. See pages 53-54 for foundation illustrations showing W and de dimensions.
- 2. Anchorage designs conform to ACI 318 Appendix D with no supplementary reinforcement and cracked or uncracked concrete as noted.
- Anchor strength indicates required grade of SSWAB anchor bolt. Standard or High-Strength (HS).
 Seismic indicates Seismic Design Category C through F. Detached 1 and 2 family dwellings in SDC C may use wind anchorage solutions. Seismic anchorage designs conform to ACI 318-05 Section D.3.3.4.
- 5. Wind includes Seismic Design Category A and B.
- 6. Foundation dimensions are for anchorage only. Foundation design (size and reinforcement) by Designer. The registered design professional may specify alternate embedment, footing size or anchor bolt.

STEEL STRONG-WALL®: Anchorage Solutions

STEEL STRONG-WALL® ANCHORAGE SOLUTIONS - 3500 psi CONCRETE

| Design | Concrete | Anchor | SSWAB | 34" ANCHOR E | BOLT | SSWAB | 1" ANCHOR B | OLT |
|-----------|------------|--------------------|-------------------------------|--------------|------------|-------------------------------|-------------|------------|
| Criteria | | Strength | ASD Allowable Uplift (lbs) | W (in) | de (in) | ASD Allowable Uplift (lbs) | W (in) | de (in) |
| | Cracked | Standard | 9600 | 22 | 8 | 17100 | 33 | 11 |
| Seismic | Grackeu | High Strength | 19900 | 36 | 12 | 35300 | 51 | 17 |
| Seisifiic | Uncracked | Standard | 9600 | 19 | 7 | 17100 | 28 | 10 |
| | Uliciackeu | High Strength | 19900 | 31 | 11 | 35300 | 44 | 15 |
| | | | 5300 | 12 | 6 | 6000 | 13 | 6 |
| | | Standard | 7400 | 15 | 6 | 13200 | 22 | 8 |
| | | | 9600 | 18 | 6 | 17100 | 27 | 9 |
| | Cracked | High Strength | 11400 | 20 | 7 | 23100 | 32 | 11 |
| | | | 14100 | 23 | 8 | 27800 | 36 | 12 |
| | | | 15900 | 25 | 9 | 31700 | 39 | 13 |
| Wind | | | 19900 | 30 | 10 | 35300 | 43 | 15 |
| vviiiu | | | 6600 | 12 | 6 | 6600 | 12 | 6 |
| | | Standard | 8300 | 14 | 6 | 12200 | 18 | 6 |
| | | | 9600 | 16 | 6 | 17100 | 23 | 8 |
| | Uncracked | | 11200 | 17 | 6 | 22400 | 27 | 9 |
| | | High Strength | 14300 | 20 | 7 | 27500 | 31 | 11 |
| | | i iigii streligiii | 16400 | 22 | 8 | 33100 | 35 | 12 |
| | | | 19900 | 26 | 9 | 35300 | 37 | 13 |

- See pages 53–54 for foundation illustrations showing W and d_e dimensions.
 Anchorage designs conform to ACI 318 Appendix D with no supplementary reinforcement and cracked or uncracked concrete as noted.
- 3. Anchor strength indicates required grade of SSWAB anchor bolt. Standard or High Strength (HS)
- 4. Seismic indicates Seismic Design Category C through F. Detached 1 and 2 family dwellings in SDC C may use wind anchorage solutions. Seismic anchorage designs conform to ACI 318-05 Section D.3.3.4.
- 5. Wind includes Seismic Design Category A and B.
- 6. Foundation dimensions are for anchorage only. Foundation design (size and reinforcement) by Designer. The registered design professional may specify alternate embedment, footing size or anchor bolt.

STEEL STRONG-WALL® ANCHORAGE SOLUTIONS - 4500 psi CONCRETE

| Design | Concrete | Anchor | SSWAB | 34" ANCHOR E | BOLT | SSWAB 1" ANCHOR BOLT | | | |
|-----------|------------|-----------------------|-------------------------------|--------------|------------|-------------------------------|-----------|------------|--|
| Criteria | Condition | Strength | ASD Allowable Uplift (lbs) | W (in) | de (in) | ASD Allowable Uplift (lbs) | W (in) | de (in) | |
| | Cracked | Standard | 9600 | 20 | 7 | 17100 | 30 | 10 | |
| Seismic | Grackeu | High Strength | 19900 | 33 | 11 | 35300 | 47 | 16 | |
| Seisillic | Uncracked | Standard | 9600 | 18 | 6 | 17100 | 26 | 9 | |
| | Ulicrackeu | High Strength | 19900 | 28 | 10 | 35300 | 41 | 14 | |
| | | | 6000 | 12 | 6 | 6000 | 12 | 6 | |
| | | Standard | 7600 | 14 | 6 | 12900 | 20 | 7 | |
| | | | 9600 | 17 | 6 | 17100 | 25 | 9 | |
| | Cracked | Cracked High Strength | 11000 | 18 | 6 | 22600 | 29 | 10 | |
| | | | 13900 | 21 | 7 | 27400 | 33 | 11 | |
| | | | 17000 | 24 | 8 | 31500 | 36 | 12 | |
| Wind | | | 19900 | 27 | 9 | 35300 | 40 | 14 | |
| Wind | | | 7500 | 12 | 6 | 7500 | 12 | 6 | |
| | | Standard | 8500 | 13 | 6 | 12700 | 17 | 6 | |
| | | | 9600 | 15 | 6 | 17100 | 22 | 8 | |
| | Uncracked | High Strength | 10500 | 15 | 6 | 22600 | 25 | 9 | |
| | | | 13800 | 18 | 6 | 26800 | 28 | 10 | |
| | | | 16200 | 20 | 7 | 32700 | 32 | 11 | |
| | | | 19900 | 24 | 8 | 35300 | 35 | 12 | |

- See pages 53–54 for foundation illustrations showing W and de dimensions.
 Anchorage designs conform to ACI 318 Appendix D with no supplementary reinforcement and cracked or uncracked concrete as noted.
 Anchor strength indicates required grade of SSWAB anchor bolt. Standard or High Strength (HS).
 Seismic indicates Seismic Design Category C through F. Detached 1 and 2 family dwellings in SDC C may use wind anchorage solutions. Seismic anchorage designs conform to ACI 318-05 Section D.3.3.4.
- 5. Wind includes Seismic Design Category A and B.

C-CFS10 @ 2010 SIMPSON STRONG-TIE COMPANY INC.

6. Foundation dimensions are for anchorage only. Foundation design (size and reinforcement) by Designer. The registered design professional may specify alternate embedment, footing size or anchor bolt.

STEEL STRONG-WALL®: Anchorage Solutions




STEEL STRONG-WALL® SHEAR ANCHORAGE


Foundation shear reinforcement to resist shear forces from Strong-Wall® panels located at the edge of concrete is shown in the table below. The SSW12 and SSW15 used in wind applications do not require shear reinforcement when the panel design shear force is less than the anchorage allowable shear load shown in the table below.

| | | SEIS | SEISMIC ³ | | WIND⁴ | | | | | |
|-------|----------|-----------------|---------------------------|---------------------|--------------|--|--------------|--------------|------|--|
| Model | Lt or Lh | Shear | Minimum Curb/ Stemwall | Reinforcement Width | | ASD Allowable Shear Load V ⁶ (lbs) | | | | |
| | (in) | Reinforcement | Width | | 6" Minimum C | urb/Stemwall | 8" Minimum C | urb/Stemwall | | |
| | | | (in) | | Uncracked | Cracked | Uncracked | Cracked | | |
| SSW12 | 9 | (1) #3 Tie | 6 | None required | _ | 1370 | 980 | 1605 | 1145 | |
| SSW15 | 12 | (1) #3 Tie | 6 | None required | _ | 1765 | 1260 | 2015 | 1440 | |
| SSW18 | 14 | (1) #3 Hairpin | 8 ⁵ | (1) #3 Hairpin | 6 | | | | | |
| SSW21 | 15 | (1) #3 Hairpin | 8 ⁵ | (1) #3 Hairpin | 6 | Hairpin reinforcement achieves maximum allowable shear load of the Steel Strong-Wall® panel. | | | | |
| SSW24 | 17 | (2) #3 Hairpins | 8 ⁵ | (2) #3 Hairpins | 6 | | | | | |


- 1. Shear anchorage designs conform to ACI 318-05 and assume minimum f'c = 2500 psi concrete. See pages 50–51 for tension anchorage.
- 2. Shear reinforcement is not required for panels installed on a cold-formed steel floor, interior foundation applications
- Steam reinforcement is not required for patients instanted on a cond-formed steamhour, interior roundation applications (panel installed away from edge of concrete), or braced-wall panel applications.
 Seismic indicates Seismic Design Category C through F. Detached 1 and 2 family dwellings in SDC C may use wind anchorage solutions. Seismic shear reinforcement designs conform to ACI 318-05 Section D.3.3.4.
 Wind includes Seismic Design Category A and B.
- 5. Where noted minimum curb/stemwall width is 6" when standard-strength SSWAB is used.
- 6. Use (1) #3 tie for SSW12 and SSW15 when the Steel Strong-Wall® panel design shear force exceeds the tabulated anchorage allowable shear load.
- 7. The registered design professional may specify alternate shear anchorage.



Hairpin Shear Reinforcement




Tie Shear Reinforcement




Hairpin Installation (Garage curb shown, other footing types similar)

CURB OR STEMWALL INSTALLATION




SLAB-ON-GRADE INSTALLATION



BRICK LEDGE INSTALLATION

C-CFS10 @ 2010 SIMPSON STRONG-TIE COMPANY INC.




Anchorage Solutions General Notes

- The Designer may specify alternate embedment, footing size or bolt grade.
 Footing dimensions and rebar requirements are for anchorage only.


Foundation design (size and reinforcement) by Designer.

SIMPSON Strong-Tie


INTERIOR INSTALLATION



Interior Section View



STEMWALL EXTENSION INSTALLATION




Anchorage Solutions General Notes

- The Designer may specify alternate embedment, footing size or bolt grade.
 Footing dimensions and rebar requirements are for anchorage only.

STEEL STRONG-WALL® ANCHOR BOLT LAYOUT

| Wall Model | Distance From End of Wall to Center of SSWAB's (A) | Distance From Center to Center of SSWAB's (B) | Distance From Exterior Face of Wall to Center of All SSWAB's (C) |
|---------------|--|---|--|
| S/SSW12 | 29/16" | 67/8" | 2" |
| S/SSW15 | 27/8" | 91⁄4" | 17⁄8" |
| S/SSW18 | 27/8" | 121⁄4" | 17⁄8" |
| S/SSW21 | 27/8" | 151⁄4" | 17⁄8" |
| S/SSW24 | 27/8" | 181⁄4" | 17⁄8" |



SIMPSON

STEEL STRONG-WALL®: Anchor Bolt Templates

STEEL STRONG-WALL® ANCHOR BOLT TEMPLATES

| Steel | Width | Steel Strong-Wall Template Model | | | | | |
|----------------------|-------|----------------------------------|------------|-------------|--|--|--|
| Strong-Wall Model | (in) | Reversible | Panel Form | Brick Ledge | | | |
| SSW12 | 12 | SSWT12 | SSWTPF12 | SSWTBL12 | | | |
| SSW15 | 15 | SSWT15 | SSWTPF15 | SSWTBL15 | | | |
| SSW18 | 18 | SSWT18 | SSWTPF18 | SSWTBL18 | | | |
| SSW21 | 21 | SSWT21 | SSWTPF21 | SSWTBL21 | | | |
| SSW24 | 24 | SSWT24 | SSWTPF24 | SSWTBL24 | | | |

*SSWT templates are reversible. Use the same template for interior or exterior applications. Template and nut configuration patent pending.

1. The height of the garage curb above the garage slab is critical for rough header opening at garage return walls.


> **SSWTPF** (Panel Form)

- 2. Templates are recommended and are required in some jurisdictions.
- 3. Foundation by Designer.


Top of concrete

4. Templates are the same for 4" or 6" thick walls.


An additional nut for template installation is provided with each SSWAB. It may also be used for SSW installation.



SSWT Exterior Installation* (May be used for Steel-Form Systems)



SSWTBL (Brick Ledge)



SIMPSON

strong-

S/JCT & S/HJCT Steel Joist Hangers

New, improved, higher load-capacity joist hangers. Additional fasteners in the new S/JCT and the increased thickness of the S/HJCT increase the allowable load capacity for use with C-Joists. Joist can be attached from either side or doubled up. This hanger can be used with either steel or wood headers.

MATERIAL: S/JCT- 68 mil (14 ga); S/HJCT- 97 mil (12 ga)

FINISH: Galvanized

INSTALLATION: • Attach hanger with specified fasteners.


Use round holes for minimum load, use round and triangle holes for maximum load.

• May be used for weld-on applications. The minimum required weld to the top flange is 1/8" x 21/2" fillet weld to each side of top flange. Consult the code for special considerations when welding galvanized steel.

FEATURES: • Uni-directional: Joist can be attached from left or right

- One size fits joists 8" through 14" deep.
- . Optional holes for additional load capacity.
- · Simplicity of design.
- · Quick and easy installation.
- Field skewable up to 45° left or right.

CODES: See page 8 for Code Listing Key Chart.




| | | Cold E | ormed Steel He | ador | | | | |
|-----------------|-----------------------|----------------------|---------------------|--------------|------|-----|--|--|
| Model No. | | Fasteners | Allowable 54 mil | Code Ref. | | | | |
| | Top | Face | Joist | Uplift | Down | | | |
| Straight Hanger | | | | | | | | |
| S/JCT (min) | 1-#10 | 2-#10 | 4-#10 | 940 | 1195 | 1 | | |
| S/JCT (max) | 1-#10 | 4-#10 | 6-#10 | 1435 | 2105 | | | |
| S/HJCT (min) | 2-#10 | 4-#14 | 6-#14 | 1510 | 2920 | | | |
| S/HJCT (max) | 2-#10 | 8-#14 | 9-#14 | 1670 | 3855 | 1 | | |
| | | Skewed | Hanger | | | | | |
| S/JCT (min) | 1-#10 | 2-#10 | 4-#10 | 940 | 1135 | FC1 | | |
| S/JCT (max) | 1-#10 | 4-#10 | 6-#10 | 940 | 1185 | | | |
| S/HJCT (min) | 2-#10 | 4-#10 | 6-#14 | 1510 | 2305 | | | |
| | | Welded H | langer ⁶ | | | | | |
| S/JCT (min) | 1/4" v 21/4" fillet u | eld to each side | 4-#10 | - | 940 | | | |
| S/HJCT (min) | | | 4-#14 | - | 1450 | | | |
| S/HJCT Skew | OI LOP | flange | 4-#14 | - | 1235 | | | |
| | | Attached to Ma | sonry - Straight | Hanger | | | | |
| S/HJCT (min) | 2-1/4" x 21/4" Titen | 4-1/4" x 21/4" Titen | 6-#14 | 710 | 1785 | 170 | | |


| | Wood Header | | | | | | | |
|--------------|-------------|---------------|--------|-----------------|---------------|------|--|--|
| Model No. | Fasteners | | | Allowable A | Code | | | |
| Mouel No. | Тор | Face | Joist | Uplift (160) | Down (100) | Ref. | | |
| | | Straight | Hanger | | | | | |
| S/JCT (min) | 1-10d | 2-10d | 4-#10 | 565 | 945 | | | |
| S/JCT (max) | 1-10d | 4-10d | 6-#10 | 960 | 1465 | | | |
| S/HJCT (min) | 2-10d | 4-SDS 1/4 x 3 | 6-#14 | 1210 | 2625 | | | |
| S/HJCT (max) | 2-10d | 8-SDS 1/4 x 3 | 9-#14 | 1475 | 2980 | FC1 | | |
| | | Skewed | Hanger | | | | | |
| S/JCT (min) | 1-10d | 2-10d | 4-#10 | 395 | 845 | | | |
| S/JCT (max) | 1-10d | 4-10d | 6-#10 | 790 | 1300 | | | |
| S/HJCT (min) | 2-10d | 4-SDS 1/4 x 3 | 6-#14 | 1210 | 1935 | | | |

- 1. Allowable loads for CFS headers are based on a single 54 mil (16 ga) steel.
- Allowable loads for wood headers are based on 4x10 minimum DFL, specific gravity = 0.50.
- Steel header must be braced to prevent web buckling per Designer specification.
- Steel joist shall be laterally braced per Designer specification.


Screws shall be installed using joist hanger holes screwing through the hanger into the joist.











- 7. For joists with up to a 0.50" gap (short cut) use an adjustment factor of 0.87.
- 8. For joists with a 0.50" to 0.90" gap (short cut) use an adjustment factor of 0.75











S/HJCT Installation on masonry header

S/LBV / S/B and S/BA Hangers



S/BA is the new Simpson Strong-Tie® top-flange hanger for cold-formed steel. The S/BA is a cost-effective alternative to heavier, special-order hangers. It is value engineered and tested to achieve higher allowable loads and increased performance. It may be fastened with screws or powder-actuated fasteners or welded to the header, providing more design options and greater versatility.

S/LBV and S/B hangers are manufactured with precision forming and quality control, providing dimensional accuracy and helping to ensure proper bearing area and connection.

MATERIAL: S/LBV, S/BA - 68mil (14 ga); S/B - 97mil (12 ga)


FINISH: Galvanized INSTALLATION:

- S/LBV, S/B, and S/BA may be used for weld-on applications; a minimum
 of 1/8" x 2" fillet weld on each top flange is required. Distribute the weld
 equally on both top flanges. Consult the code for special consideration
 when welding galvanized steel. Uplift loads do not apply.
- S/BA may be installed using powder-actuated fasteners. PDPAT-62KP (0.157 x 1/8") powder-actuated fastener shall be installed using the appropriate level of powder load so the entire pointed portion of the fastener penetrates through the steel. A powder-actuated fastener with a "tophat" crush sleeve is recommended in case the head of the fastener is not fully flush with the connector.
- Installation of powder-actuated fasteners may vary due to, but not limited to, the type of powder-actuated tool, cleanliness of tool, type of powder load and steel.


OPTIONS: Skew only:


 S/LBV and S/B series can be skewed to a maximum of 45 degrees.

CODES: See page 8 for Code Reference Key Chart




Top View S/B Hanger Skewed Right





S/LBV, S/B, and S/BA are acceptable for weld-on applications (S/LBV shown)



S/LBV Installation with a CFS steel header

| | Model | | Dimensions | | | | | | | Code | | |
|--|--|-----------|------------|----------------|-------------------------------|-----------------------|-------------|--------|-------|------|--|--|
| | Monei | W | Н | В | Тор | Face | Joist | Uplift | Down | Ref. | | |
| | Cold-Formed Steel Header – Straight Hanger | | | | | | | | | | | |
| | S/LBV | | 6 to 20 | 21/4 | 4 - #10 | 2 - #10 | 3 - #10 | 1010 | 3150 | FC1 | | |
| | S/B | See Table | 6 to 30 | 3 | 8 - #10 | 4 - #14 | 3 - #14 | 1855 | 5970 | FUI | | |
| NEW | S/BA | | See Table | 3 | 6 - #10 | | 1 - #10 | _ | 3475 | 160 | | |
| Cold-Formed Steel Header – Skewed Hanger | | | | | | | | | | | | |
| | S/LBV | See Table | 6 to 20 | 21/4 | 4 - #10 | 2 - #10 | 3 - #10 | 1010 | 2220 | FC1 | | |
| | S/B | See lable | 6 to 30 | 3 | 8 - #10 | 4 - #14 | 3 - #14 | 1855 | 4195 | FUI | | |
| | | | P | owder-Actuated | d Fastener or Welded to Steel | <u> Header – Stra</u> | ight Hanger | | | | | |
| | S/LBV | | 6 to 20 | 21/4 | 4 - 1/8" x 2" fillet weld | _ | 3 - #10 | | 2965 | FC1 | | |
| ~ | S/B | See Table | 6 to 30 | 3 | to each side of top flange | _ | 3 - #14 | | 5755 | 101 | | |
| NEW | S/BA | JEE IADIE | See Table | 3 | to each side of top hange | _ | 1 - #10 | | 2920 | 160 | | |
| NEW | S/BA | | See lable | 3 | 6 - 0.157" x 5/8" PAT | _ | 1 - #10 | | 26854 | 100 | | |



- 2. Cold-formed steel / steel-beam header must be braced to prevent buckling per Designer specification.
- 3. Powder-actuated fasteners may be installed in up to %" steel headers having a minimum Fy=36,000 psi.
- 4. Load is based on using the Simpson Strong-Tie® PDPAT-62KP powder-actuated fastener and a minimum Red (level 5) powder load.
- 5. Tabulated loads are based on testing with full bearing of 2½" flange-depth minimum with 68 mil (14 ga) CFS for S/LBV and S/BA hanger and 97 mil (12 ga) CFS for S/B hanger.

| S/LBV Series Model No. | S/B Series Model No. | W | | |
|---------------------------|-------------------------|----------------|--|--|
| S/LBV1.56 | S/B1.56 | 1%16 | | |
| S/LBV1.81 | S/B1.81 | 1 13/16 | | |
| S/LBV2.06 | S/B2.06 | 21/16 | | |
| S/LBV2.37 | S/B2.37 | 23/8 | | |
| S/LBV2.56 | S/B2.56 | 29/16 | | |
| S/LBV2.68 | S/B2.68 | 211/16 | | |
| S/LBV3.12 | S/B3.12 | 31/8 | | |
| S/LBV3.56 | S/B3.56 | 3%16 | | |
| S/LBV3.62 | S/B3.62 | 35/8 | | |
| S/LBV4.06 | S/B4.06 | 41/16 | | |
| S/LBV4.12 | S/B4.12 | 41/8 | | |
| S/LBV4.28 | S/B4.28 | 41/4 | | |
| S/LBV4.75 | S/B4.75 | 43/4 | | |
| S/LBV5.50 | S/B5.50 | 5½ | | |

| S/BA Series Model No. | W | Н |
|--------------------------|-------|----|
| S/BA2.12/8 | | 8 |
| S/BA2.12/10 | 21/8 | 10 |
| S/BA2.12/12 | | 12 |
| S/BA2.12/14 | | 14 |
| S/BA4.18/8 | | 8 |
| S/BA4.18/10 | 43/ | 10 |
| S/BA4.18/12 | 43⁄16 | 12 |
| S/BA4.18/14 | | 14 |

W/WP Hangers

This series of purlin hangers offer the greatest design flexibility and versatility. MATERIAL: Stirrup—97 mil (12 ga)

FINISH: Simpson Strong-Tie gray paint. Some models available hot-dip galvanized; specify HDG, see Corrosion Information on page 12–13.

INSTALLATION: Hangers may be welded to steel headers with 1/2" for W and 3/16" for WP by 11/2" fillet welds located at each end of the top flange.

OPTIONS: • W and H dimensions are modifiable.


SLOPED AND/OR SKEWED SEAT

- W/WP series may be skewed to a maximum of 84° and/or sloped to a maximum of 45°.
- For slope only, skew only, or slope and skew combinations, the allowable load is 100% of the table load.
- Specify the slope up or down in degrees from the horizontal plane and/or the skew right or left in degrees from the perpendicular vertical plane. Specify whether low side, high side or center of joist will be flush with the top of the header.

CODE: See page 8 for Code Listing Key Chart.

| NA1 - 1 | Di | mension | s | Fast | eners | A11 | |
|--------------|-------------|---------|--------|--------|--------|-------------------------|-----|
| Model No. | w | Н | В | Header | Joist | Allowable Down Loads | |
| W | 1½ - 4 | 4°- 30 | 2½ - 5 | Weld | 1- #10 | 2335 | 170 |
| WP | 1%16 - 71/2 | 4°- 30 | 2½ - 5 | Weld | 1- #10 | 3650 | 170 |

- 1. For hanger heights exceeding the joist height the allowable load is 0.50 of the table value.
- 2. The Designer shall ensure that the joist member adequately transfers load to the hanger.
- 3. Not all combinations of W, H, and B dimensions are available. Contact Simpson Strong-Tie.




HUC Hangers

MATERIAL: 68 mil (14 ga) FINISH: Galvanized INSTALLATION:

- HUC series hangers may be welded to supporting structural steel members.
- Use 1" weld segments equally spaced top and bottom, with half the segments on each side of hanger.
- Welds may be either Lap Joint (on outside edge of flanges) or Flare-Bevel Groove (on flange bend line).

| | Conne | ction Type | | | |
|-----------------|-------|---------------------|----------------------------|--------------|--|
| Model Series | Joist | Structural Steel | Max Allowable Down Load | Code Ref. | |
| | Screw | Weld | | | |
| HUC | #10 | 4 - 1" segments | 3280 | 170 | |
| пис | #10 | 6 - 1" segments | 4855 | 170 | |


- 1. Loads assume an E-70S-6 (60 ksi) filler rod.
- 2. Welds must conform to the current A.W.S. D1.3 structural welding code for sheet steel and must be performed by certified welder.
- 3. Designer shall ensure that the joist member adequately transfers load to hanger.
- Hanger-to-joist connection shall be made using screws on the side of the hanger where it meets the web of the joist.



Installation for CFS Built-Up Beam

C-CFS10 © 2010 SIMPSON STRONG-TIE COMPANY INC

The Designer is responsible for design of beam member.



TB/LTB Bridging



TB and LTB bridging are a cost effective way to provide bracing between floor joists when compared with field fabricated blocking and clip angles with multiple fasteners.

TB—Tension-type bridging with maximum fastener flexibility. Use two #10 screws of the seven screw holes at each end.


LTB—Staggered fastener pattern accommodates 6" to 12" web height. Use two #10 Screw of the holes at each end.


MATERIAL: LTB-27 mil (22 ga); TB-33 mil (20 ga)

FINISH: Galvanized INSTALLATION:

- \bullet Bridging will fit flange widths from 15%" to 3".
- Reference section R505.3.3 of the International Residential Code (IRC).

CODE: See page 8 for Code Listing Key Chart.





| Web | Cnooing | ТВ | | LTB | Code |
|--------|----------|-----------|----|-----------|--------------|
| Height | Spacing | Model No. | L | Model No. | Code Ref. |
| 6" | 12" o.c. | TB20 | 20 | LTB20 | |
| 8" | 12" o.c. | TB20 | 20 | LTB20 | |
| 10" | 12" o.c. | TB20 | 20 | | |
| 12" | 12" o.c. | TB27 | 27 | _ | 11.04 |
| 6" | 16" o.c. | TB27 | 27 | _ | |
| 8" | 16" o.c. | TB27 | 27 | - | |
| 10" | 16" o.c. | TB27 | 27 | - | |
| 12" | 16" o.c. | TB27 | 27 | _ | |
| 10" | 24" o.c. | TB36 | 36 | _ | |
| 12" | 24" o.c. | TB36 | 36 | _ | |

TJC37 Jack Truss Connector

TJC37 is a versatile connector for skewed members. Adjustable from 0 to 67.5 degrees (shipped with 67.5 degree bend). Screw hole locations allow for easy installation.

MATERIAL: 54 mil (16 ga) FINISH: Galvanized


INSTALLATION: • Use all specified fasteners; see General Notes.

- Can be installed filling round holes only, or filling round and triangle holes for maximum values.
- Position the skewed member on the inside of the bend line with the end of the member flush with the bend line.
- Bend the TJC37 to the desired position (one bend cycle only).

CODE: See page 8 for Code Listing Key Chart

| 88-4-1 | Faste | eners | All | owable Loa | ads | 0 |
|--------------|----------|---------|-----|------------|-----------|--------------|
| Model No. | Carrying | Carried | 4 | | | |
| NU. | Member | Member | 0° | 1°-60° | 61°-67.5° | Code Ref. |
| TJC37 (Min) | 4-#10 | 4-#10 | 660 | 565 | 475 | EC1 |
| TJC37 (Max) | 6-#10 | 6-#10 | 680 | 630 | 530 | FUI |

1. Allowable loads are for upward or downward direction.



S/DSC Drag Strut Connector


The S/DSC is used as a drag strut to transfer loads from roof framing to the wall plates below.

MATERIAL: 229 mil (3 ga) FINISH: Simpson Gray Paint

INSTALLATION: • Use all specified fasteners; see General Notes.

CODES: See page 8 for Code Listing Key Chart.

| 84-4-1 | | | Allowab | le Loads | Code Ref. | | |
|--------------|----|-----------|-------------|----------|--------------|--|--|
| Model No. | L | Fasteners | 43 mil | (18 ga) | | | |
| No. | | | Compression | Tension | | | |
| S/DSC4R/L | 22 | 40-#10 | 3220 | 4025 | FC1 | | |



The Simpson Strong-Tie AHEP is a structural purlin that also serves as an installation aid during the truss erection process. The AHEP attaches to the step-down hip trusses at the leading edge eliminating the need for drop top chords and C-stud fillers. The AHEP installs linearly, aligned with the end jacks, to maintain sheathing spacing from eave to hip or peak. Roof sheathing/decking attaches directly to the purlin. Adjustable in length, the AHEP is designed to accommodate a pitch range of 3/12 to 9/12.

MATERIAL: 33 mil (20 ga) FINISH: Galvanized

INSTALLATION: Use all specified fasteners. See General Notes.

CODES: See page 8 for Code Reference Key Chart.

Available June 2010

| Model | Faste | eners | Sheathing | All | owable I 33 mil | Down Lo: (20 ga) | ads | Code | |
|-------|---------|---------|----------------------|-------|--------------------|---------------------|-------|------|--|
| No. | Side | Truss | Option | 3/12 | Pitch | 9/12 | Pitch | Ref. | |
| | Flanges | Ends | | L/180 | 3/16" | L/180 | 3/16" | | |
| | | | | None | 285 | 360 | 160 | 175 | |
| AHEP | 4 - #10 | 4 - #10 | ½" Wood Sheathing | 285 | 360 | 205 | 225 | 170 | |
| | | | · . | | | | | | |

- Designer shall insure attached members are adequately designed to resist applied loads.
- 2. Straight line interpolation can be used to determine allowable loads for pitches between 3/12 and 9/12.

Side-Flange **AHEP**

TBD22 Truss Brace Diagonal


The TBD22 diagonal truss brace offers a time-saving substitute for hat channel or C-stud diagonal bracing that helps meet the prescriptive recommendations of CFSBCSI. The TBD22 travels in a box like a flat strap (160 feet per carton), and is formed into an A-shape as it is pulled from the carton to provide rigidity and prevent sagging between trusses during installation. As it is fastened to the trusses the brace flattens, allowing sheathing to be installed over it, saving the time typically needed to remove bracing prior to applying the sheathing or decking.

MATERIAL: 27 mil (22 ga) FINISH: Galvanized

INSTALLATION: Use all specified fasteners; see General Notes

- Strap does not have holes for fasteners. Screws shall be installed in the dimpled areas and placed to maintain a minimum of 1/4" strap edge distance and a minimum of ½" center to center distance.
- TBD22 strap span diagonally at approximately 45 degrees.
- · Strap shall not be slack, but tight and ready to engage in tension.
- To resist construction forces, diagonal X-bracing is required at each end and every 10 truss spaces (20' max.). Refer to SBCA CFS-BCSI for additional information.
- At the end of the TBD22 braces, trusses shall be laterally restrained to resist out-of-plane forces.
- · Bracing locations shown in the drawing are recommendations for temporary bracing only. Installation of TBD22 for permanent bracing shall be by the Building Designer or Engineer of Record.

CODES: See page 8 for Code Reference Key Chart.



| Madal | Fast | eners | Allowable Te | ension Loads | Code | |
|--------------|-------------|--------------|----------------|----------------|------|--|
| Model No. | Strap Ends | Intermediate | Truss Memb | Ref. | | |
| NU. | Strap Ellus | Trusses | 27 mil (22 ga) | 33 mil (20 ga) | nei. | |
| TBD22 | 2 - #10 | 2 - #10 | 380 | 510 | 160 | |
| | | | | | | |

Load based on truss steel properties of Fy=50 ksi and Fu=65 ksi. Reduce load directly proportionally for lower steel strength per AISI 2001 Chapter F, Section F1.1 (c).

Typical TSR2-24

. Installation

TSBR and S/TSR Truss Spacer Restraint

The TSBR and the S/TSR captures the on-center spacing of CFS truss chords and webs and laterally restrains the truss members, allowing quicker, easier and safer installations. Its tubular shape provides strength in both compression and tension. S/TSR installs in a linear fashion and has a low profile that can be sheathed over, eliminating the need to remove bracing prior to applying the sheathing or decking.

MATERIAL: 27 mil (22 ga) FINISH: Galvanized

INSTALLATION: • Use all specified fasteners; see General Notes.

CODES: See page 8 for Code Reference Key Chart.

Available June 2010

| | | | | | | | - | | |
|---------------|---------|----------------|-----|------|-------------|-----------------|---------------------------------|-----------------------------|--------------|
| | | Dimensi | ons | | Faste | eners | Allowable | e Loads | |
| Model No. | W | L ² | Н | В | Bend End | Straight End | Compression 33 mil (20ga) | Tension 33 mil (20ga) | Code Ref. |
| TSBR2-24 | 1½ | 251/2 | | | 1 - #10 | 1 - #10 | 455 | 215 | |
| 130112-24 | 1 72 | 23 72 | | | 2 - #10 | 2 - #10 | 455 | 215 575 | |
| S/TSR1.5-24 | 1 ½ | 25 ½ | 1 | 13/4 | 1 - #104 | 2 - #10 | 455 | 425 | 170 |
| S/TSR1.5-24T3 | 1 ½ | 25 1/2 | | | 1 - #104 | 2 - #10 | 360 | 425 | |
| S/TSR1.62-24 | 1 1 1/8 | 25% | | | 1 - #104 | 2 - #10 | 455 | 425 | |



S/TSR

- 1. Designer shall insure attached members are
- adequately designed to resist applied loads. Length, L, equals the effective out-to-out dimension of the braced trusses.
- For use with the Alpine or TrusSteel chord profile.
- Requires 2 #10 screws installed at each end of the row of restraints.

STC/STCT/DTC Roof Truss Clips



For alignment control between a roof truss and nonbearing walls; the 1½" slot permits vertical truss chord movement when loads are applied.

MATERIAL: 43 mil (18 ga) FINISH: Galvanized


INSTALLATION: • Use all specified fasteners; see General Notes.

- Use STC or DTC depending on required loads.
- STC / STCT / DTC may be used with proprietary material sections. Contact material supplier for specific installation details.
- Use STCT where truss or rafter is separated from the top plate of the nonbearing wall.
- · Install slot screws in the middle of the slot.

CODE: See page 8 for Code Listing Key Chart

| | Faste | eners | А | a) | | | | | |
|--------------|-------|-------|----------------|----------------|----------------|----------------|--|----------------|--------------|
| Model No. | Base | Slot | Witho | ut Gap | 1⁄4" Ma | x. Gap | 1⁄4" <g< th=""><th>ap≤½"</th><th>Code Ref.</th></g<> | ap≤½" | Code Ref. |
| | Dase | 3101 | F ₁ | F ₂ | F ₁ | F ₂ | F ₁ | F ₂ | |
| STC | 2-#8 | 1-#8 | 185 | 35 | 135 | 35 | 75 | 35 | FC1 |
| STCT | 2-#8 | 1-#8 | _ | _ | _ | _ | _ | _ | 180 |
| DTC | 4-#8 | 2-#8 | 200 | 160 | 200 | 160 | 145 | 160 | FC1 |

- 1. Truss or rafter must be bearing on top plate to achieve the allowable loads under "WITHOUT GAP."
- 2. Clips are required on both sides of the truss to achieve F₁ loads in both directions (stagger parts to avoid screw interferences).



S/GTC Girder Truss Connector

The S/GTC truss connector is designed to connect a carried truss to a girder truss vertical member.

MATERIAL: 33 mil (20 ga) FINISH: Galvanized


INSTALLATION: • Use all specified fasteners; see General Notes.

- Install the connector onto the girder truss member first.
- May be used with proprietary material sections with web material dimensions from 1%" to 1%". Contact material supplier for product specific installation details.

CODE: See page 8 for Code Listing Key Chart

| | Faste | eners | Trusses | | | |
|--------------|-------------------|--------------------|-----------------------------------|--------------------|--------------|--|
| Model No. | Carried Member | Carrying Member | Material Thickness mil (ga) | Allowable Loads | Code Ref. | |
| | 4-#10 | 4-#10 | 27 (22) | 355 | | |
| S/GTC | 4-#10 | 4-#10 | 33 (20) | 425 | 170 | |
| 5/616 | 4-#10 | 4-#10 | 43 (18) | 450 | 170 | |
| | 4-#10 | 4-#10 | 54 (16) | 485 | | |

- 1. Trusses shall be laterally braced per Designer specification.
- 2. Allowable loads are for one connector. Up to three connections may be installed; use an adjustment factor of 0.90 to total tabular load.



Typical S/GTC Installation
The S/GTC works for many proprietary truss shapes including
Alpine, Amkey, Nucon, Nutruss and Steelcon.

S/HTC Heavy Truss Clips

S/HTC provides a slotted connection from the truss or joist to the top track when isolation of two members is required.

MATERIAL: 43 mil (18 ga) FINISH: Galvanized


INSTALLATION: • Use all specified fasteners.

· Screws in vertical slots shall not be driven completely flush against the connector when vertical movement

CODES: See page 8 for Code Listing Key Chart.

| | Faste | Fasteners | | Allowable Loads 43 mil (18 ga) | | | | |
|--------------|--------|-----------|----------------|--------------------------------|----------------|----------------|-------|--|
| Model No. | Top | Truss | Withou | t Gap¹ | With 11 | Code Ref. | | |
| | Track | iiuss | F ₁ | F ₂ | F ₁ | F ₂ | 1101. | |
| S/HTC4 | 4 - #8 | 3 - #8 | 320 | 460 | 85 | 175 | FC1 | |

- 1. Truss or rafter must be bearing on top plate to achieve the allowable loads under "WITHOUT GAP."
- Installed with maximum 1½" space between rafter or truss and top plate under "WITH 1½" GAP." Where loads are not required, space is not limited to 1¼ ".



Straps & Ties

LTS/MTS/HTS Twist Straps


Twist straps provide a tension connection between two members. They resist uplift at the heel of a truss economically. The 3" bend section eliminates interference at the transition points between steel members.

MATERIAL: See table

FINISH: Galvanized. Some products available in stainless steel and ZMAX®; see Corrosion Information, page 12-13.

INSTALLATION: Use all specified fasteners. See General Notes.

CODES: See page 8 for Code Listing Key Chart.




LTS12 (MTS and HTS similar)

Available with additional corrosion protection. Check with Simpson Strong-Tie.

| | Connector | | F | asteners (Total |) | Allowable Tension Loads | |
|--------|-----------------------|----|----------------|-------------------|----------------|----------------------------------|----------------|
| Model | Material Thickness | L | Rafte | er/Stud/Joist Thi | ickness | 33 mil (20 ga) 43 mil (18 ga) | Code Ref. |
| No. | mil (ga) | | 33 mil (20 ga) | 43 mil (18 ga) | 54 mil (16 ga) | 54 mil (16 ga) | |
| LTS12 | | 12 | 10-#10 | 6-#10 | 6-#10 | 775 | ILC1, LC1, FC1 |
| LTS16 | 43 | 16 | 10-#10 | 6-#10 | 6-#10 | 775 | |
| LTS18 | (18 ga) | 18 | 10-#10 | 6-#10 | 6-#10 | 775 | FC1 |
| LTS20 | | 20 | 10-#10 | 6-#10 | 6-#10 | 775 | |
| MTS12 | | 12 | 12-#10 | 8-#10 | 6-#10 | 995 | ILC1, LC1, FC1 |
| MTS16 | | 16 | 12-#10 | 8-#10 | 6-#10 | 995 | |
| MTS18 | E 4 | 18 | 12-#10 | 8-#10 | 6-#10 | 995 | |
| MTS20 | 54 | 20 | 12-#10 | 8-#10 | 6-#10 | 995 | |
| MTS30 | (16 ga) | 30 | 12-#10 | 8-#10 | 6-#10 | 995 | |
| MTS24C | | 24 | 12-#10 | 8-#10 | 6-#10 | 995 | |
| MTS30C | | 30 | 12-#10 | 8-#10 | 6-#10 | 995 | FC1 |
| HTS16 | | 16 | 16-#10 | 12-#10 | 6-#10 | 1415 | |
| HTS20 | | 20 | 18-#10 | 12-#10 | 6-#10 | 1450 | |
| HTS24 | 68 | 24 | 18-#10 | 12-#10 | 6-#10 | 1450 | |
| HTS28 | (14 ga) | 28 | 18-#10 | 12-#10 | 6-#10 | 1450 | |
| HTS30 | | 30 | 18-#10 | 12-#10 | 6-#10 | 1450 | |
| HTS30C | | 30 | 18-#10 | 12-#10 | 6-#10 | 1450 | |

- 1. Not all fastener holes need to be filled as additional fastener holes are provided. Install fasteners symmetrically.
- 2. Install half of the fasteners on each end of strap to achieve full loads.
- 3. All straps except the MTS30 and HTS30 have the twist in the center of the strap.
- 4. Twist straps do not have to be wrapped over the truss to achieve the load.
- 5. May be installed on the inside face of the stud.



MTS30 (HTS30 similar)

MTS30C (HTS30C `similar)

HRS/ST/FHA/PS/LSTA/LSTI/S/MST/MSTA/MSTC/MSTI Strap Ties



Straps are load rated and provide the correct thickness and number of fasteners the specifier is looking for compared with field fabricated straps.


Install Strap Ties where top or bottom plates are cut, at wall intersections, and as ridge ties. Reduce the allowable load based on the size and quantity of fasteners used.

Refer to applicable code for minimum edge and end distances.

FINISH: PS-hot-dip galvanized (HDG); all others-galvanized. Some products are available in stainless steel or ZMAX®; see Corrosion Information, page 12-13.


INSTALLATION: Use all specified fasteners. See General Notes.

CODES: See page 8 for Code Listing Key Chart.



| | Connector Material | Dimer | nsions | Bolts | | Code |
|-------|-----------------------|-------|--------|-------|-----|------|
| No. | Thickness mil (ga) | W | L | Qty | Dia | Ref. |
| PS218 | 474 " | 2 | 18 | 4 | 5/8 | |
| PS418 | 171 mil (7 ga) | 4 | 18 | 4 | 5/8 | 180 |
| PS720 | (1 ya) | 63/4 | 20 | 8 | 1/2 | |

PS strap design loads must be determined by the Designer for each illustration.
 Hole diameter in the part may be oversized to accommodate the HDG. Designer must determine if the oversize creates an unacceptable installation.



C-CFS10 © 2010 SIMPSON STRONG-TIE COMPANY INC.

HRS/ST/FHA/LSTA/LSTI/S/MST/MSTA/MSTC/MSTI Strap Ties



Available with additional corrosion protection. Check with Simpson Strong-Tie.

CODES: See page 8 for Code Listing Key Chart.

| | | | | | npson Suong-me | | 00520 | - Ooo pago c | 7101 0000 E | Taking Ney Onart. |
|--------------------|-----------------------|-----------------|----------|--------------------|--------------------|--------------------------|-------------------|-------------------|-------------------|-------------------|
| Model | Connector Material | Dimen | sions | | Fasteners (Tota | 1) | Allowab | le ASD Tensi | on Loads | Code |
| No. | Thick. mil (ga) | w | L | | r/Stud/Joist Thi | ckness 54 mil (16 ga) | 33 mil (20 ga) | 43 mil (18 ga) | 54 mil (16 ga) | Ref. |
| LSTA9 | | 11/4 | 9 | 8- #10 | 8- #10 | 8- #10 | 705 | 1120 | 1190 | |
| LSTA12 | | 11/4 | 12 | 10- #10 | 10- #10 | 8- #10 | 885 | 1190 | 1190 | |
| LSTA15 | | 11/4 | 15 | 12- #10 | 12- #10 | 10- #10 | 1060 | 1190 | 1190 | |
| LSTA18 | | 11/4 | 18 | 14- #10 | 12- #10 | 10- #10 | 1190 | 1190 | 1190 | FC1 |
| LSTA21 | 33 | 11/4 | 21 | 14- #10 | 12- #10 | 10- #10 | 1190 | 1190 | 1190 | |
| LSTA24 | (20 ga) | 11/4 | 24 | 14- #10 | 12- #10 | 10- #10 | 1190 | 1190 | 1190 | |
| ST292 | | 21/16 | 95/16 | 12- #10 | 10- #10 | 10- #10 | 1060 | 1240 | 1240 | 11.01 |
| ST2122 | | 21/16 | 1213/16 | 16- #10 | 12- #10 | 10- #10 | 1415 | 1502 | 1502 | ILC1, |
| ST2115 | | 3/4 | 165/16 | 8- #10 | 6- #10 | 4- #10 | 630 | 630 | 630 | LC1, FC1 |
| ST2215 | | 21/16 | 165/16 | 20- #10 | 14- #10 | 10- #10 | 1765 | 1825 | 1825 | 101 |
| LSTA30 | | 11/4 | 30 | 18- #10 | 12- #10 | 10- #10 | 1555 | 1555 | 1555 | |
| LSTA36 | | 11/4 | 36 | 18- #10 | 16- #10 | 14- #10 | 1555 | 1555 | 1555 | |
| LSTI49 | | 3¾ | 49 | 32- #10 | 32- #10 | 20- #10 | 2830 | 4050 | 4050 | |
| LSTI73 | 43 | 3¾ | 73 | 46- #10 | 32- #10 | 20- #10 | 4050 | 4050 | 4050 | |
| MSTA9 | (18 ga) | 11/4 | 9 | 8- #10 | 8- #10 | 8- #10 | 705 | 1050 | 1555 | |
| MSTA12 | (10 ga) | 11/4 | 12 | 10- #10 | 10- #10 | 8- #10 | 885 | 1315 | 1555 | FC1 |
| MSTA15 | _ | 11/4 | 15 | 12- #10 | 12- #10 | 10- #10 | 1060 | 1555 | 1555 | _ |
| MSTA18 | _ | 11/4 | 18 | 14- #10 | 12- #10 | 10- #10 | 1235 | 1555 | 1555 | |
| MSTA21 | _ | 11/4 | 21 | 16- #10 | 12- #10 | 10- #10 | 1415 | 1555 | 1555 | |
| MSTA24 MSTA30 | | 11/4 | 30 | 18- #10 22- #10 | 12- #10 16- #10 | 10- #10 | 1555 | 1555 1950 | 1555 | |
| | - | 1½ 1½ 2½6 | 36 | | | 12-#10 | 1945 | | 1950 | |
| MSTA36 ST6215 | - | | 165/16 | 24- #10 20- #10 | 18- #10 16- #10 | 16- #10 10- #10 | 1950 1765 | 1950 2025 | 1950 2025 | ILC1, |
| ST6224 | - | 21/16 | 235/16 | 28- #10 | 20- #10 | 12- #10 | 2455 | 2455 | 2455 | LC1, FC1 |
| ST9 | - <u>.</u> . | | 9 | 8- #10 | 8- #10 | 8- #10 | 705 | 1050 | 1350 | 201,101 |
| ST12 | 54 1½ (16 ga) 1½ | | 11% | 10- #10 | 10- #10 | 8- #10 | 885 | 1315 | 1350 | - |
| ST18 | | 11/4 | 173/4 | 14- #10 | 12- #10 | 12- #10 | 1235 | 1350 | 1350 | _ |
| ST22 | | 11/4 | 215/8 | 20- #10 | 20- #10 | 20- #10 | 1350 | 1350 | 1350 | |
| MSTC28 | | 3 | 281/4 | 36- #10 | 36- #10 | 30- #10 | 3180 | 4600 | 4600 | FC1 |
| MSTC40 | | 3 | 401/4 | 52- #10 | 46- #10 | 46- #10 | 4595 | 4600 | 4600 | 1 101 |
| MSTC52 | | 3 | 521/4 | 54- #10 | 42- #10 | 42- #10 | 4600 | 4600 | 4600 | |
| MSTC66 | 68 | 3 | 65¾ | 66- #10 | 46- #10 | 30- #10 | 5795 | 5795 | 5795 | |
| MSTC78 | (14 ga) | 3 | 773/4 | 66- #10 | 46- #10 | 30- #10 | 5795 | 5795 | 5795 | |
| ST6236 | (14 ya) | 21/16 | 3313/16 | 40- #10 | 30- #10 | 18- #10 | 3535 | 3760 | 3760 | ILC1, LC1, FC1 |
| HRS6 | | 1% | 6 | 6- #10 | 6- #10 | 6- #10 | 530 | 790 | 1600 | |
| HRS8 | | 1% | 8 | 10- #10 | 10- #10 | 10- #10 | 885 | 1315 | 2670 | |
| HRS12 | | 1% | 12 | 14- #10 | 14- #10 | 12- #10 | 1235 | 1840 | 2710 | |
| FHA6 | | 17/16 | 6% | 8- #10 | 8- #10 | 8- #10 | 705 | 1050 | 2045 | |
| FHA9 | | 17/16 | 9 | 8- #10 | 8- #10 | 8- #10 | 705 | 1050 | 2045 | |
| FHA12 | | 17/16 | 115/8 | 8- #10 | 8- #10 | 8- #10 | 705 | 1050 | 2045 | |
| FHA18 | | 17/16 | 173/4 | 8- #10 | 8- #10 | 8- #10 | 705 | 1050 | 2045 | FC1 |
| FHA24 | 97 | 17/16 | 237/8 | 8- #10 | 8- #10 | 8- #10 | 705 | 1050 | 2045 | |
| FHA30 | (12 ga) | 17/16 | 30 | 8- #10 | 8- #10 | 8- #10 | 705 | 1050 | 2045 | |
| MSTI26 | | 21/16 | 26 | 26- #10 | 26- #10 | 22- #10 | 2300 | 3420 | 5025 | 4 |
| MSTI36 | - | 21/16 | 36 | 36- #10 | 36- #10 | 22- #10 | 3180 | 4735 | 5025 | _ |
| MSTI48 | - | 21/16 | 48 | 48- #10 | 40- #10 | 22- #10 | 4240 | 5025 | 5025 | - |
| MSTI60 | - | 21/16 | 60 | 58- #10 | 40- #10 | 22- #10 | 5025 | 5025 | 5025 | |
| S/MST27 | - | 21/16 | 27 | 30- #10 | 30- #10 | 22- #10 | 2650 | 3945 | 5025 | 11.01 |
| S/MST37 S/MST48 | - | 21/16 | 37 | 42- #10 54- #10 | 40- #10 40- #10 | 22- #10 24- #10 | 3710 4770 | 5025 | 5025 | ILC1, |
| S/MST60 | 118 | 2½16 2½16 | 48 60 | 68- #10 | 52- #10 | 30- #10 | 4770 6010 | 5155 6650 | 5155 6650 | LC1, FC1 |
| S/MST72 | (10 ga) | 21/16 | 72 | 76- #10 | 52- #10 | 30-#10 | 6650 | 6650 | 6650 | 101 |
| 3/1013172 | (10 ga) | Z /16 | 12 | 70-#10 | J2-#10 | 30-#10 | 0000 | 0000 | 0000 | |

- 1. Use half of the fasteners in each member being connected to achieve the listed loads.
- 2. Loads are based on lesser of steel capacity or fastener calculation.
- 3. Not all fastener holes need to be filled as additional fastener holes are provided. Install fasteners symmetrically.

CS/CMST Coiled Straps


CMSTC provides fastener slots for easy installation and coined edges. CS, CMST and CMSTC are continuous utility straps which can be cut to length on the job site. Packaged in lightweight (about 40 pounds) cartons.

FINISH: Galvanized. Some products available in ZMAX® coating; see Corrosion Information, page 12-13.

INSTALLATION: • Use all specified fasteners. See General Notes.

- · Refer to the applicable code for minimum edge and end distances.
- The table shows the maximum allowable loads and the screws required to obtain them. See footnote #1. Fewer screws may be used; reduce the allowable load by the code lateral load for each fastener subtracted from each end.

CODES: See page 8 for Code Listing Key Chart.



Available with additional corrosion protection. Check with Simpson Strong-Tie.

| | Model | Total Material length Thickness | Material | | D. | Fasteners (Tota | <u> </u> | Allowable Tension Loads 33 mil (20 ga) | Code |
|---|----------------------|---------------------------------|------------|---|--|-----------------|----------|--|-------------|
| | No. | mil (ga) | | *************************************** | Rafter/Stud/Joist Thickness 33 mil (20 ga) 43 mil (18 ga) 54 mil (16 ga) | | | 43 mil (18 ga) 54 mil (16 ga) | Ref. |
| ĺ | CMST12 ² | 40'-3" | 97 (12 ga) | 3 | 104- #10 | 70- #10 | 40- #10 | 9080 | ILC1. |
| ĺ | CMST14 ² | 52½' | 68 (14 ga) | 3 | 72- #10 | 50- #10 | 28- #10 | 6365 | LC1, |
| | CMSTC16 ³ | 54' | 54 (16 ga) | 3 | 54- #10 | 36- #10 | 30- #10 | 4600 | FC1 |
| | CS14 | 100' | 68 (14 ga) | 11/4 | 28- #10 | 18- #10 | 12- #10 | 2305 | |
| | CS16 | 150' | 54 (16 ga) | 11/4 | 18- #10 | 12- #10 | 8- #10 | 1550 | |
| | CS18S | 100' | 40 (40) | 11/4 | 14- #10 | 10- #10 | 6- #10 | 1235 | ILC1, |
| ĺ | CS18 | 200' | 43 (18 ga) | 11/4 | 14- #10 | 10- #10 | 6- #10 | 1235 | LC1, FC1 |
| | CS20 | 250' | 33 (20 ga) | 11/4 | 12- #10 | 8- #10 | 6- #10 | 945 | . 51 |
| | CS22 | 300' | 27 (22 ga) | 11⁄4 | 10- #10 | 6- #10 | 6- #10 | 775 | |

- 1. Use half of the fasteners in each member being connected to achieve the listed loads.
- 2. For CMST straps: End Length (inches) = ½ total fasteners x 7/6" + 1" when all holes filled. Double length if only round holes filled.
- 3. For CMSTC16 straps: End Length (inches) = ½ total fasteners x ¾" + 1" when all holes filled. Double length if only round holes filled.
- 4. For CS straps: End Length (inches) = ½ total fasteners + 1".
- 5. Total Cut Length = End Length + Clear Span + End Length.
- No. of Screws Used x Table Load 6. Calculate the connector value for a reduced number of screws as follows: Allowable Load = No. of Screws in Table

Example: CMSTC16 on 54 mil with 24 screws: $\frac{24 \text{ Screws (Used)}}{24 \text{ Screws (Used)}} \times 4600 \text{ lbs} = 3680 \text{ lbs}$ 30 Screws (Table)

7. Loads are based on lesser of steel strap capacity and 2001 AISI NAS fastener calculation.

Straps & Ties


MATERIAL: SSP/DSP—43 mil (18 ga); TSP—54 mil (16 ga) FINISH: Galvanized. Some products available in ZMAX®;

see Corrosion Information, page 12-13.

INSTALLATION: • Use all specified fasteners; see General Notes.

• DSP/SSP-top track installation-fill all round and triangle holes


CODES: See page 8 for Code Listing Key Chart.



These products are available with additional corrosion protection. Additional products on this page may also be available with this option, check with Simpson Strong-Tie for details.

| | | | Fa | steners | | Allowable l | Jplift Loads | | |
|--|--------------|----------|----------------------|---------|--------------|------------------|------------------|--------------|--|
| | Model No. | Studs | Top 1 | [rack | Bottom Track | 33 mil (20ga) | 43 mil (18ga) | Code Ref. | |
| | | CFS | Wood | CFS | CFS | (Logu) | (logu) | | |
| | | | | _ | 2 - #10 | 355 | 625 | | |
| | SSP | 4 - #10 | _ | 2 - #10 | _ | 340 | 600 | | |
| | 55P | 4 - # 10 | 2 - #10 ³ | 1 - #10 | _ | 405¹ | 715¹ | | |
| | | | 2 - 10d | 1 - #10 | _ | 480¹ | 840¹ | | |
| | | 8 - #10 | _ | _ | 4 - #10 | 430 | 695 | | |
| | DSP | | _ | 4 - #10 | _ | 475 | 775 | FO4 | |
| | מסט | | 4 - #10 ³ | 2 - #10 | _ | 585¹ | 955¹ | FC1 | |
| | | | 4 – 10d | 2 - #10 | _ | 730¹ | 1200¹ | | |
| | | 6 - #10 | _ | _ | 3 - #10 | 345 | 645 | | |
| | TSP | 0-#10 | _ | 3 - #10 | _ | 370 | 700 | | |
| | 101 | 0 //10 | 3 - #10 ³ | 3 - #10 | _ | 360¹ | 685¹ | | |
| | | 9 - #10 | 3 - 10d | 3 - #10 | _ | 480¹ | 905¹ | | |

- 1. For wood plates, noted values only apply to DF/SP members where wood top plates are used. For SPF values, multiply by 0.86.
- For wood plates are used. For a values, minimply 90.00.
 For wood plates, when cross-grain tension cannot be avoided, mechanical reinforcement to resist such forces should be considered.
- 3. Screws installed into wood plates with a minimum #10x3/4".



Stud Plate Ties



The SP stud plate tie is a plate-to-stud connection providing uplift resistance.


MATERIAL: See table

FINISH: Galvanized. Available with ZMAX® coating; see Corrosion Information, page 12-13. INSTALLATION: • Use all specified fasteners.

CODES: See page 8 for Code Listing Key Chart.

Available with additional corrosion protection. Check with Simpson Strong-Tie.

| | Connector | Dime | nsions | . . | Allowable | |
|--------------|-----------------------------------|-------|--------|-------------------|--------------------------------|--------------|
| Model No. | Material Thickness mil (ga) | W | L | Stud Fasteners | Uplift Loads 33 mil (20 ga) | Code Ref. |
| SP4 | 33 (20ga) | 31/16 | 71/4 | 6 - #10 | 825 | |
| SP6 | 33 (20ga) | 5%16 | 73/4 | 6 - #10 | 825 | |
| SP8 | 43 (18ga) | 75/16 | 85/16 | 6 - #10 | 930 | |
| SPH4 | 43 (18ga) | 31/16 | 83/4 | 12 - #10 | 1490 | FC1 |
| SPH4R | 43 (18ga) | 41/16 | 81/4 | 12 - #10 | 1490 | FUI |
| SPH6 | 43 (18ga) | 5%16 | 91/4 | 12 - #10 | 1490 | |
| SPH6R | 43 (18ga) | 61/16 | 83/4 | 12 - #10 | 1490 | |
| SPH8 | 43 (18ga) | 75/16 | 8% | 12 - #10 | 1490 | |



MATERIAL: See table

FINISH: Galvanized. Available with ZMAX® coating; see Corrosion Information Connectors, page 12-13.

INSTALLATION: • Use all specified fasteners.

- The S/H1 can be installed with flanges facing outwards (reverse of illustration 1) when installed inside a wall for truss applications.
- · Hurricane ties do not replace solid blocking.
- S/H2.5. S/H3 and H6 ties are only shipped in equal quantities of rights and lefts.

To Rafters

/ Truss

3 - #10

3 - #10

5 - #10

4 - #10

2 - #10

4 - #10

8 - #10

Available with additional corrosion protection. Check with Simpson Strong-Tie.

Fasteners

To Top

Track

2 - #10

1 - #10

2 - #10

8 - #10

2 - #10

1. Loads are based on attachment of cold-formed steel members having a minimum thickness of

2. Hurricane ties are shown installed on the outside of wall for clarity. Installation inside of wall is

4. H10S can have an offset of maximum 3/4" from the center of the vertical stud based on AISI General Provisions Standard Section C1 (In-Line Framing) for a reduced uplift of 890 lbs. provided

CODE: See page 8 for Code Listing Key Chart.

Connector

Material

Thickness

mil (ga)

43 (18ga)

43 (18ga)

43 (18ga)

43 (18ga)

43 (18ga)

54 (16ga)

54 (16ga)

43 (18ga)

Model

No.

S/H1

S/H2

H2A

S/H2.5

S/H3


Н6

H7Z

H₁₀S

33 mil (20 ga).

edge distances are met.



Allowable Loads

33 mil (20 ga)

100

90

90

90

Uplift

305

315

450

390

375

950

985

930³

To Stud

1 - #10

3 - #10

5 - #10

4 - #10

8 - #10

8 - #10

8 - #10

Lateral


F2


115


100


125

125



















acceptable. For Continuous Load Path, connections in the same area must be on same side of wall. 3. H10S with CFS members having a minimum thickness of 43mil (18 ga) the allowable load is 1260 lbs.

Code

Ref.

ILC1.

LC1, FC1

170

ILC1.

_C1, FC1


170































Installation


(3)


MATERIAL: 43 mil (18 ga) FINISH: Galvanized

INSTALLATION: • Use all specified fasteners.

- S/H1A can be installed with flanges facing outwards, reverse of illustration, when installed inside a wall for truss applications
- · S/H1A does not replace solid blocking.
- S/H1A may be used with proprietary material sections. Contact material supplier for specific installation details.

CODE: See page 8 for Code Listing Key Chart.





| | Model | Fasteners | | | Truss | Allowable Uplift Loads | | | | |
|-----|--------|-----------|--------|--------|------------------------------------|------------------------|-------------------|----------------|--------------|--|
| No. | | Tuusa | Тор | Stud | Thickness ² mil (ga) | Plate / Wa | all Stud Thicknes | s mil (ga) | Code Ref. | |
| | | Truss | Track | Stuu | (92) | 33 mil (20 ga) | 43 mil (18 ga) | 54 mil (16 ga) | | |
| ľ | | 4- #10 | 3- #10 | 1- #10 | 27 (22 ga) | 470 | 470 | 470 | | |
| | S/H1A | 4- #10 | 3- #10 | 1-#10 | 33 (20 ga) | 510 | 550 | 690 | FC1 | |
| | O/IIIA | 4- #10 | 3- #10 | 1-#10 | 43 (18 ga) | 510 | 550 | 690 |] 101 | |
| | | 4- #10 | 3- #10 | 1- #10 | 54 (16ga) | 520 | 675 | 850 | | |

Tabulated loads based on truss members with yield strength, Fy, of 50 ksi and tensile strength, Fu, of 65 ksi. Reduce tabulated load proportionally for lower truss member steel strength. For example: 43 mil (18 ga) truss member with a yield strength, Fy of 33 ksi and a tensile strength, Fu, of 45 ksi is connected to 43 mil top track and wall stud. The adjusted allowable load is then 550 lbs. x minimum [33/50 or 45/60]=363 lbs.

S/PSPN Protecting Shield Plate

S/PSPN58 and S/PSPN516 protecting shield plate fastener stoppers meet IRC, IBC and the International Plumbing Code. S/PSPN516 meets the code plumbing protection requirements as well as having additional fasteners if the Designer chooses to use it as a track splice strap.

MATERIAL: 54 mil (16 ga)

FINISH: Galvanized, available in ZMAX® INSTALLATION: S/PSPN - #10 screws. CODES: See page 8 for Code Listing Key Chart.

S/PSPN516 at top plates

- International Residential Code® 2000/2003/2006 P2603.2.1
- International Plumbing Code 2000/2003/2006 305.8

S/PSPN516 at bottom plate.

• International Plumbing Code - 2000/2003/2006 305.8

S/PSPN58 at top plates and bottom plate.


International Plumbing Code – 2000/2003/2006 305.8

Note that the IBC section 2308.9.8 and the IRC section 602.6.1 require a 54 mil (16 ga) strap with 6-16d nails and 8-16d nails respectively each side at a hole or notch in a wood top, sill or sole plate. The Designer or local building jurisdiction may permit an equivalent fastener strength (i.e. screws in lieu of nails) to be used for the same condition in a CFS top or bottom track.

These products are available with additional corrosion protection. Additional products on this page may also be available with this option, check with Simpson Strong-Tie for details.

| Model No. | W | L | Code Ref. |
|-----------|---|--------|-----------|
| S/PSPN58 | 5 | 8 | 190 |
| S/PSPN516 | 5 | 165/16 | 190 |

- 1. #10 self-tapping screws may be used to attach S/PSPN to CFS framing with quantity determined by Designer.
- 2. PSPN516 with 6 #10 self-tapping screws each side achieves an allowable shear capacity of 1060 lbs and 1580 lbs to 33 mil (20 ga) track and to 43 mil (18 ga) track, respectively.



115%"

H Hybrid Connectors Seismic & Hurricane Ties for Wood Truss or Joist-to-CFS Wall



Designed to provide seismic and wind ties for wood trusses or joists-to-CFS walls, this versatile line may be used for general purposes, strongback attachments, and as all-purpose ties where one member crosses another.

HS24 attaches the bottom chord of a truss or rafter at pitches from 0:12 to 4:12 to steel top plates.

Material: See table

Finish: Galvanized. Selected products available in stainless steel or ZMAX® coating. See Corrosion Information, page 12-13.


Installation: • Use all specified fasteners. See General Notes

• H1 can be installed with flanges facing inward (reverse of illustration 1).


Available with additional corrosion protection. Check with Simpson Strong-Tie.

- · Hurricane ties do not replace solid blocking.
- H2.5, H3, and H6 ties are only shipped in equal quantities of rights and lefts.


Codes: See page 8 for Code Listing Key Chart.









H2A




- Loads are based on attachment of coldformed steel vertical stud members having a minimum thickness of 33 mil (20 ga).
- 3. Hurricane Ties are shown installed on the outside of wall for clarity. Installation inside of wall is acceptable. For Continuous Load Path, connections must be on same side of wall
- 4. When cross-grain bending or cross-grain tension cannot be avoided, mechanical reinforcement to resist such force should be considered.
- 5. H10S can have an offset of maximum 34" from the center of the CFS vertical stud based on AISI General Provisions Standard Section C1 (In-Line Framing) for a reduced uplift of 890 lbs. (DF/SP) and 765 lbs. (SPF) provided all edge distances are met.











H2 Installation






H6 Stud-to-Top-Plate Installation










8 HS24 Installation



4 H3 Installation

H10S Installation


Straps & Ties

VGT and S/VGT2.5 Variable-Pitch Girder Tiedowns



The variable-pitch girder tiedown, S/VGT2.5, is a high-capacity tiedown for single-or multi-ply CFS girder trusses. It attaches with self-drilling screws from the side of the truss. The VGT uses Simpson Strong-Tie SDS series screws for wood truss applications. They both

FINSISH: Galvanized



| Model No. | Outsitu | No. of | Fasto | eners | Allowable Uplift Loads ² | | Code | |
|----------------|-----------|----------------|-------------|--------------|-------------------------------------|---------------------------|------|--|
| Model No. | Quantity | Truss Plies | Anchor Dia. | Girder Truss | 3/12 | 8/12 | Ref. | |
| | Cold-Form | ned Steel | Connection | | 54mil | (16ga) | | |
| CAICTO F (min) | 1 | 1 | 1 - 1/8 | 16 - #14 | 3050 | 2620 | | |
| S/VGT2.5 (min) | 2 | 2 | 2 - 1/8 | 32 - #14 | 6100 | 5240 | 170 | |
| CAICTO E (mov) | 1 | 1 | 1 - 1/8 | 20 - #14 | 3860 | 3130 | 170 | |
| S/VGT2.5 (max) | 2 | 2 | 2 - 1/8 | 40 - #14 | 7720 | 6260 | | |
| | | | | | | Jplift Loads ³ | | |

| | Hyb | orid Conne | ection | | | Jplift Loads³ 8/12 | Code Ref. |
|--------|-----|------------|-------------|-----------------|------|-----------------------|-----------|
| | | | DF/SP (160) | SPF/HF (160) | | | |
| | 1 | 2 | 1 - 5% | 16 - SDS1/4"x3" | 4940 | 3555 | |
| VGT | 2 | 2 | 2 - 5/8 | 32 - SDS1/4"x3" | 7185 | 5175 | |
| | 2 | 3 | 2 - 5/8 | 32 - SDS1/4"x3" | 8890 | 6400 | F26 |
| VGTR/L | 1 | 2 | 1 - 5% | 16 - SDS1/4"x3" | 2230 | 1605 | |
| VGTN/L | 2 | 2 | 2 - 5/8 | 32 - SDS1/4"x3" | 5545 | 3990 | |

- Designer shall insure attached members are adequately designed to resist applied loads.
- Straight-line interpolation can be used to determine allowable loads for pitches between 3/12 and 8/12.
- Allowable loads on wood have been increased 60% for wind or earthquake loading with no further increase allowed; reduce where other load duration factors govern.

Installation in CMU

masonry connections. MATERIAL: See table

FINISH: Galvanized. Some products available in stainless steel and ZMAX®; see Corrosion Information,

The MTSM and HTSM offer high strength truss to


page 12-13.

INSTALLATION: • Use all specified fasteners.

See General Notes.

• May be attached to either side of a grouted block wall. A minimum of one #5 horizontal rebar shall be installed in the top course of this wall.

CODES: See page 8 for Code Listing Key Chart.



| | MTS | M20 |
|--------|-----------------|--|
| MTSM16 | SMPSON Storegue | SWESON Storics of the control of the |

HTSM16 HTSM20

| | Connector Fasteners | | | | | | | | |
|------------------------------|---------------------|----|-----------------------------|----------------|----------------|-------------------|-------------------|-----------------------------------|--------------|
| Model Material No. Thick. | | | Rafter/Stud/Joist Thickness | | | OMIL | 0 | Allowable Loads 33 mil (20 ga) | Code Ref. |
| 140. | mil (ga) | | 33 mil (20 ga) | 43 mil (18 ga) | 54 mil (16 ga) | CMU | Concrete | oo iiii (20 gu) | 1101. |
| MTSM16 | 54 (16 ga) | 16 | 5- #10 | 4- #10 | 3- #10 | 4- 1/4x21/4 Titen | 4- 1/4x11/4 Titen | 860 | |
| MTSM20 | 54 (10 ya) | 20 | 5- #10 | 4- #10 | 3- #10 | 4- 1/4x21/4 Titen | 4- 1/4x11/4 Titen | 860 | FC1 |
| HTSM16 | 68 (14 ga) | 16 | 7- #10 | 5- #10 | 3- #10 | 4- 1/4x21/4 Titen | 4- 1/4x11/4 Titen | 1175 | FUI |
| HTSM20 | 00 (14 ya) | 20 | 7- #10 | 5- #10 | 3- #10 | 4- 1/4x21/4 Titen | 4- 1/4x11/4 Titen | 1175 | |

- 1. All straps have additional fastener holes.
- Twist straps do not have to be wrapped over the truss to achieve the wall.
- 3. Minimum edge distance in concrete block for Titen screw is 1½".
- May be installed on the inside face of the wall.
- 5. Min. $f'_m = 1500 \text{ psi}$ and $f'_c = 2500 \text{ psi}$.

LTA1, S/HGAM10 and H10S Seismic & Hurricane Ties

The LTA1 develops high uplift at a minimum heel height. Great in areas where a strap over the heel is not required. The side tab acts as a locator in the masonry block and the four embedded hooks provide for a positive bond in the concrete grout.


The H10S and the S/HGAM10 attaches to truss joist and provides good uplift resistance.

MATERIAL: See table FINISH: Galvanized


INSTALLATION: • Use all specified fasteners. See General Notes.

- S/HGAM10 can be installed into grouted concrete block.
- · Titen® screws are provided.
- · Hurricane ties do not replace solid blocking.
- Attach to grouted concrete block with a minimum one #5 rebar horizontal in the top lintel block.

CODES: See page 8 for Code Listing Key Chart



U.S. Patent 6,560,943




Typical LTA1 Installation

| | Connector | | Allowable Uplift Loads | | Code | | |
|------------|-----------------------|-------------------|------------------------|-----------------------|-----------------|--------|-------|
| Model | Material Thickness | | Fasteners | | | 43 mil | Ref. |
| No. | mil (ga) | To Rafter / Truss | To CMU | To Concrete | (20 ga) (18 ga) | | 1101. |
| LTA1 | 43 (18 ga) | 8- #10 | _ | _ | 1415 | 1420 | 170 |
| S/HGAM10KT | 68 (14 ga) | 4- #14 | 4- 1/4" x 23/4" Titen | 4- 1/4" x 13/4" Titen | 810 | 850 | LC1 |
| H10S | 43 (18 ga) | 8- #10 | 2- %" x 4" Titen HD | 2- %" x 4" Titen HD | 915 | 1245 | 170 |


1. Min. $f'_m = 1500 \text{ psi}$ and $f'_c = 2500 \text{ psi}$.

C-CFS10 @ 2010 SIMPSON STRONG-TIE COMPANY INC


- 2. Minimum edge distance 1½" using Titen screws.
- 3. Products shall be installed such that the Titen screws
- and Titen HD anchors are not exposed to the weather.













MATERIAL: 33 mil (20 ga) FINISH: Galvanized INSTALLATION:

• Use all specified fasteners. See General Notes. **CODES:** See page 8 for Code Listing Key Chart.

| | Tuna of | Diversion of | Fast | eners | Allamable Lands | 0 | |
|-----------|-----------------------|----------------------|-----------|--------|-----------------------------------|------|--|
| Model No. | Type of Connection | Direction of Load | | | Allowable Loads 43 mil (18 ga) | Ref. | |
| | 1 | | 7- #10 | 7- #10 | 1045 | | |
| LTP5 | 2 | G | 7- #10 | 7- #10 | 1110 | FC1 | |
| | 3 | | 7-8d x 1½ | 7- #10 | 730 | | |

- 1. Allowable loads are for one anchor.
- 2. Allowable loads are based on steel (stud & sheet) of 43 mil (18 ga) minimum.
- 3. Allowable load for Type 3 connection assumes Cd = 1.60.





Note: When attaching an LTP5 framing anchor over sheathing, the screws must penetrate and engage the steel framing. A minimum of 3 threads shall penetrate past the steel.

L & S/LS Reinforcing & Skewable Angles



L and S/LS angles are load rated and provide the correct thickness and number of fasteners the specifier is looking for compared with field fabricated clip angles.

General utility reinforcing angles with multiple uses.

S/LS—Field-adjustable angles attach members intersecting at angles.

MATERIAL: L-54 mil (16 ga); S/LS-43 mil (18 ga)

FINISH: Galvanized. Some products available in stainless steel or ZMAX®; see Corrosion Information, page 12–13.

INSTALLATION: • Use all specified fasteners.


- S/LS—field-skewable; bend one time only.
- Joist must be constrained against rotation when using a single S/LS per connection.

CODE: See page 8 for Code Listing Key Chart.

Available with additional corrosion protection. Check with Simpson Strong-Tie.

| | | | | Allowable Loads | | | | | |
|---|---------------|--------|-----------|-----------------|----------------|----------------|----------------|----------------|--------------|
| I | Vlodel No. | Length | Fasteners | 33 mil (| 20 ga) | 43 mil (18 ga) | 54 mil | (16 ga) | Code Ref. |
| | NU. | | | F ₁ | F ₂ | F ₁ | F ₁ | F ₂ | |
| L | .30 | 3 | 4- #10 | 200 | 60 | 420 | 610 | - | ILC1, |
| L | .50 | 5 | 6- #10 | 475 | - | 630 | 750 | 110 | LC1, |
| L | .70 | 7 | 8- #10 | 705 | - | 840 | 1100 | 100 | FC1 |
| L | .90 | 9 | 10- #10 | 795 | - | 1050 | 1740 | - | 170 |
| S | S/LS50 | 47/8 | 4- #10 | 200 | - | 420 | 500 | - | ILC1, |
| S | S/LS70 | 63/8 | 6- #10 | 465 | - | 630 | 715 | - | LC1, FC1 |
| | | | | | | | | | |

- 1. Loads are for one part only.
- 2. Code approval is limited for specific steel thickness. Refer to Code Report for additional information.



Typical L50 Installation

S/LS Top View

ONLY.

PSCL/PSCA Panel Sheathing Clips



Simpson Strong-Tie® Panel Sheathing Clips are used to brace unsupported sheathing edges. The PSCA is a new version of the PSCL with less material for a more cost effective solution. Model sizes include: PSCL¾, PSCA¼6, PSCL√16, PSCA¹5½2, PSCL¹5½2, PSCL¹½, PSCL5½8; PSCL¹9½2, PSCL3¼2.


MATERIAL: 33 mil (20 ga) FINISH: Galvanized INSTALLATION:

- Use the same size sheathing clip as the wood panel thickness.
- Spans may be reduced for low slopes (per the APA Residential Design/ Construction Guide).

CODES: See page 8 for Code Listing Key Chart.

| Span | Wood | Maximu | m Roof Span | PSCLs | Code Ref. |
|--------|--------------------|-----------|--------------|----------|--------------|
| Rating | Panel Thickness | With PSCL | Without PSCL | Per Span | |
| 24/0 | 3/8 | 24 | 20 | 1 | |
| 24/16 | 7/16 | 24 | 24 | 1 | |
| 32/16 | 15/32, 1/2 | 32 | 28 | 1 | 180 |
| 40/20 | 5/8, 19/32 | 40 | 32 | 1 | |
| 48/24 | 3/4 | 48 | 36 | 2 | |

- Span rating and Maximum Roof Sheathing Spans are for reference only, refer to IBC Table 2304.7 (3) for additional important information.
- 2. Max. roof sheathing span with single PSCA is 24". For spans greater than 24" use two PSCAs.



TP/TPA Tie Plates


TPs are screw-on tie plates. TPAs are flanged for added support.

MATERIAL: 33 mil (20 ga) FINISH: Galvanized INSTALLATION:

 Holes are sized for #8 or #10 screw.

CODES: See page 8 for Code Listing Key Chart.

| Model | Dimens | sions | Number of | Code |
|-------|--------|-------|------------|------|
| No. | W | L | Nail Holes | Ref. |
| TP15 | 113/16 | 5 | 13 | |
| TPA37 | 31/2 | 7 | 32 | |
| TPA39 | 31/2 | 9 | 41 | |
| TP35 | 31/8 | 5 | 23 | |
| TP37 | 31//8 | 7 | 32 | |
| TP39 | 31//8 | 9 | 41 | |
| TP311 | 31//8 | 11 | 50 | 180 |
| TP45 | 41/8 | 5 | 30 | |
| TP47 | 41//8 | 7 | 42 | |
| TP49 | 41//8 | 9 | 54 | |
| TP411 | 41//8 | 11 | 66 | |
| TP57 | 5¾ | 7 | 60 | |
| TPA57 | 5 | 7 | 49 | |



Special Order Custom Clips and Angles



Simpson Strong-Tie can make a variety of flat and bent steel shapes, which includes clips and angles for CFS applications.

MATERIAL: 229 mil (3 ga) maximum, 43 mil (18 ga) minimum mill certified steel

FINISH: Galvanized, Simpson Strong-Tie gray paint, stainless steel. Contact Simpson Strong-Tie for availability.

TO OBTAIN A QUOTE:

- Supply a CAD drawing in .dwg or .dxf format complete with all dimensions, hole diameter and centerline locations, bend angles, steel strength (Min Fy and Fu),thickness (mils and/or ga) and finish: (galvanized to G-60, G-90, G-185), Simpson Strong-Tie Gray Paint, or stainless steel (specify).
- Total shape and size up to a maximum of 48" x 48" (approx. 1/16" tolerance).
- Simpson Strong-Tie does not provide product engineering or load values for special order custom clips and angles
- Contact Simpson Strong-Tie for pricing information
- Refer to Important Information & General Notes, starting on page 8 for additional information.

EXAMPLE SPECIFICATION:

QUANTITY: XX pieces

DIMENSIONS: Per the attached CAD drawing (.dwg or .dxf format)

- Drawing must be fully dimensioned including:
 - · Overall dimensions
 - · Leg dimensions
 - Bend Angles (if required)
 - · Hole sizes and centerlines (if required)

MATERIAL SPECIFICATION: (Contact Simpson Strong-Tie for availability)


THICKNESS: 54 mil (16 ga.)

STRENGTH: Min. Yield Strength (Fy) = 33 ksi, Min. Tensile Strength

(Fu) = 45 ksi

FINISH: G-90 galvanizing

Total Number of parts required for this specification: XX



CONTINUOUS LOAD PATH CONSIDERATIONS





Modern design and construction practices use structural connectors to form a continuous load path that can effectively resist wind and seismic forces by reinforcing the structure from the roof to the foundation.

Simpson Strong-Tie® connectors are designed to enable structures to resist the movement, stress, and loading that results from natural events such as earthquakes and high velocity winds. When properly installed, our connectors will perform in accordance with the specifications set forth in this catalog, given the correct fastener is used, in the provided holes, into the recommended base material.

In cold-formed steel framing, connectors such as holdowns, straps, angles and hurricane ties are often field-fabricated. However, field-fabricated connectors in general have not been designed and tested to determine their ultimate and allowable load capacity and are typically not code listed. Field-fabricated connectors consume valuable man-hours on the jobsite and typically do not have prepunched holes. Because of this, the installer may not be properly locating the fasteners to achieve the intended design load.

Simpson Strong-Tie connectors are the most thoroughly tested and evaluated products in the industry, value engineered for the lowest installed cost at the highest rated performance levels. Our connectors save the contractor time in the field, and when properly specified and installed, provide an easier installation, at a lower installed cost, and are warranted for accuracy of design. This should be taken in consideration when considering field-fabricated connectors.





This shows a continuous load transfer path from the trusses to the foundation. A qualified Designer should ensure that correct quantities, fasteners and installation methods are used to achieve full design load values.

The Designer can also refer to our current Wood Construction Connectors catalog.

Many of the connectors listed there may be used for cold-formed steel construction, using the screw values found in this catalog.

This catalog reflects changes in the allowable loads and configurations of some Simpson Strong-Tie Company Inc. products. **This catalog is effective until December 31, 2011,** and supersedes all information in all earlier publications, including catalogs, brochures, fliers, technical bulletins, etc. Use this edition as a current printed reference. Information on allowable loads and configurations is updated annually.

We post our catalogs on www.strongtie.com. Please visit our site, and sign up for any information updates. Allowable loads in this catalog are for the described specific applications of properly-installed products. Product modifications, improper loading or installation procedures, or deviations from recommended applications will affect connector allowable load-carrying capacities.



Every day we work hard to earn your business, blending the talents of our people with the quality of our products and services to exceed your expectations. This is our pledge to you.



Wood Construction Connectors

Includes specifications and installation instructions on wood-to-wood and wood-toconcrete structural connectors. Includes load tables and material specifications.

Anchoring and Fastening Systems for Concrete and Masonry

Includes application information, specifications and load values for anchoring adhesive and mechanical anchors. P.A.T. and carbide drill bits.

Quik Drive® Systems Catalog

A complete line of laborsaving auto-feed systems and specialty fasteners for a wide range of commercial and residential construction applications.

Strong-Wall® Shearwalls

All the information on our Strong-Wall shearwalls is now in one easy to use catalog: technical data, installation information, structural details and more. The catalog also features new solutions for two-story and balloon frame applications as well as an extensive section on braced frame requirements under the various building codes.

Anchor Tiedown Systems

This system is designed to provide the over-turning holdown capacity for multi-story commercial buildings. This holdown application is easy to specify, install and inspect.

High Wind Framing **Connection Guide**

Developed for designers and engineers as a companion to the AF&PA Wood Frame Construction Manual.

Code Compliant Repair and Protection Guide

Developed for building professionals to help explain products and techniques related to the installation of utilities in wood frame construction.

Strong Frame™ Ordinary Moment Frame

The Strong Frame Ordinary Moment Frame catalog contains complete information on the Strong Frame ordinary moment frame including product information, detail installation instructions and technical data. Performance date is available for engineered designs as well as prescriptive wall-bracing applications.

Simpson Strong-Tie Free CD-ROM

Our CD-ROM features our latest catalogs, fliers, technical bulletins, code reports, product list prices, UPC information, and the Simpson Strong-Tie Connector Selector program. It also includes the Drawing Library.

Home Office

5956 W. Las Positas Blvd. Pleasanton, CA 94588 Tel: 925/560-9000 Fax: 925/847-1603

Northwest USA

5151 S. Airport Way Stockton, CA 95206 Tel: 209/234-7775 Fax: 209/234-3868

Southwest USA 12246 Holly Street Riverside, CA 92509 Tel: 714/871-8373 Fax: 951/369-2889

Northeast USA

2600 International St. Columbus, OH 43228 Tel: 614/876-8060 Fax: 614/876-0636

Southeast USA

2221 Country Lane McKinney, TX 75069 Tel: 972/542-0326 Fax: 972/542-5379

Quik Drive Factory 436 Calvert Drive Gallatin, TN 37066 Tel: 888/487-7845 Fax: 615/451-9806

Eastern Canada

5 Kenview Boulevard Brampton, ON L6T 5G5 Tel: 905/458-5538 Fax: 905/458-7274

Western Canada

11476 Kingston Street Maple Ridge, B.C. V2X 0Y5 Tel: 604/465-0296 Fax: 604/465-0297

Simpson Strong-Tie Anchor Systems

Addison, IL 60101 Tel: 630/543-2797 Fax: 630/543-7014

Specials Factories Kent, WA Eagan, MN

Distribution Centers Enfield, CT High Point, NC Jacksonville, FL Jessup, MD

International Facilities

Please visit our website for contact details